

ENQUIRIES: G. Frantz

Attention: Ms Vivienne Thomson

EnviroAfrica CC
P.O. Box 5367
Helderberg
7135

Tel : 021 851 1616
Email: vivienne@enviroafrica.co.za

COMMENTS ON THE DRAFT BASIC ASSESSMENT REPORT (DBAR) FOR THE PROPOSED LOUW'S BOS CEMETERY AND MEMORIAL PARK ON REMAINDER OF LOUW'S BOS FARM NO. 502, STELLENBOSCH.

The Directorate: Pollution & Chemicals & Chemicals Management (D: PCM) hereby acknowledges receipt of the above-mentioned application on 29 August 2019 and has the following comment:

1. Sanitation

- a. The site layout plan 1 (Appendix B1) shows various ablution (toilet) facilities located throughout the site. It is not clear from the layout plan or the DBAR if all ablution facilities will be connected to a common septic tank. This must be clarified in the next phase of the BAR.
- b. The position of the septic tank/s must be updated/displayed on the preferred site layout plan in appendix B1.
- c. In the event that the municipality cannot service the septic tanks (due to municipal strikes or tanker trucks broken down etc.) the applicant must devise a contingency plan for the alternate safe pumping of the septic tank/s. This contingency plan must be included in the operational phase of the EMP.
- d. Written confirmation must be sought from the Engineering and Technical Services Department of the Stellenbosch Municipality, advising that adequate capacity exists at the Stellenbosch Waste Water Treatment Works to accept the sewage load (via tanker trucks) from the proposed development.

2. Geotechnical Study

- a. It is recommended that no traditional burials take place in the vicinity of trial pit 8, which had groundwater seepage at 1.5m, in order to reduce the risk of pathogenic contamination of groundwater resources.

Please contact Gunther Frantz at the contact details indicated, should you have any enquiries to these comments.

Yours faithfully,



WILNA KLOPPERS
DIRECTOR: POLLUTION AND CHEMICALS MANAGEMENT

DATE: 6 September 2019.

CC: D'mitri Matthews (Development Management: Region 1)
D'mitri.Matthews@westerncape.gov.za