



Kamiesberg Municipality

KAMIESKROON OXIDATION POND SYSTEM

DESIGN REPORT

Rewvisions				
No	Date	Compiled	Reviewed	Description
00	2020-05-19	BVi Consulting Engineers	E Myburgh	Original draft for review

SUBMITTED BY:

BVi Consulting Engineers

19 May 2020



BVi Regional Office
17A Keerom Street
SPRINGBOK
8240
Tel: +27 27-712 9990
Fax: +27 27-712 9991
E-mail: spk@bvinam.co.za

REVIEWED BY CLIENT

(MARK APPROPRIATE BOX WITH AN "X")

A REVIEWED AND ACCEPTED.

B REVIEWED AND ACCEPTED AS NOTED.

C WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES AS INDICATED. REVISE & RE-SUBMIT FOR REVIEW.

D REVISE AND RE-SUBMIT FOR REVIEW.

E WORK MAY NOT PROCEED.

F NO FURTHER REVIEW REQUIRED.

CLIENT APPROVAL:

NAME: _____ SIGNATURE: _____ DATE: _____

NAME: _____ SIGNATURE: _____ DATE: _____

NAME: _____ SIGNATURE: _____ DATE: _____

TABLE OF CONTENTS

1. INTRODUCTION	4
 1.1 BACKGROUND	4
1.1.1 <i>General</i>	4
1.1.2 <i>Population</i>	4
2. EXISTING SERVICES.....	5
2.1 Sewer Supply Network	5
2.2 Oxidation Ponds	5
3. EVALUATION OF OXIDATION POND SYSTEM	6
3.1 Anaerobic, Primary and Secondary Ponds.....	6
3.1.1 <i>Anaerobic Ponds</i>	6
3.1.2 <i>Primary and Secondary Ponds</i>	7
3.1.3 <i>Evaporation Ponds</i>	7
4. DESIGN AREAS AND VOLUMES	7
4.1 Final Design Sizes	8
5. PROPOSED WORK	9
6. COST ESTIMATE.....	10
7. CONCLUSION.....	10

1. INTRODUCTION

BVi Consulting Engineers was appointed by Kamiesberg Municipality as engineering project managers to evaluate the capacity of the existing oxidation pond system in Kamieskroon. In addition, an investigation was done to determine the current and existing demand on the oxidation pond system to determine what upgrades, if any, are necessary.

1.1 BACKGROUND

1.1.1 GENERAL

Kamieskroon is situated next to the N7 national road in the Northern Cape, about 65km from Springbok and 45km from Garies. It is a small rural village which falls under the low-income category and the people of Kamieskroon mostly depend on work on nearby commercial farms and to a lesser extent the mines in the Namakwa District.



Figure 1: Location of Kamieskroon in the Northern Cape

1.1.2 POPULATION

The most recent information with regards to the population is 1 670 according to the number of plots and assuming that there are approximately 4.5 people per household. Refer to Table 1 for the number of plots and residents in Kamieskroon. A population increase of 0.5% per annum is assumed, resulting in a future population of 1 845 in 2039.

Table 1: Number of plots and residents in Kamieskroon

Description of Items	Current 2019		Future 2039	
	Plots	Residents	Plots	Residents
Calculated number	371	1670	410	1845

2. EXISTING SERVICES

2.1 Sewer Supply Network

The sewer network of Kamieskroon consists of uPVC pipes with a total length of ± 3,4km. The network consists of two (2) gravitational networks that connect to the oxidation ponds. The one network connects directly to the oxidation ponds and the other connects to a sewer pump station from where the sewage is pumped to the oxidation ponds. The main sewer pump station is located to the North of the town near the entrance of the town from the N7 National Road.

2.2 Oxidation Ponds

Kamieskroon has an oxidation pond system located about 420 metres north of the nearest residential area, Kroonsig. The system consists of the following:

- Two (2) anaerobic ponds
- One (1) primary pond
- Three (3) secondary ponds

Refer to Annexure A for a layout of the existing oxidation pond system and to Table 2 for the capacity of the existing system.

After surveys have been completed at the ponds, the existing capacity of the ponds was calculated as follows, the total current capacity is calculated at 7 727 m³ and is currently overflowing.:

Table 2 Existing Oxidation Pond System

Existing Oxidation Ponds					
	Type	Number	Total Volume (m ³)	Total area (m ²)	Total Area (ha)
1	Anaerobic Ponds	2	1077	556	0.05
2	Primary Ponds	1	2324	2045.26	0.21
3	Secondary Ponds	3	3604	3316.128	0.33
4	Tertiary Ponds				
5	Evaporation Ponds				
	Total		7724	6473	0.59

This oxidation pond system does not comply with the specifications of the Department of Water and Sanitation. The ponds do not have any lining installed, allowing the possible infiltration of sewage water into the water table.

3. EVALUATION OF OXIDATION POND SYSTEM

3.1 Anaerobic, Primary and Secondary Ponds

Using the current and future populations the required capacity for the oxidation pond system were calculated using the following assumptions:

Sewer flow calculations

- Persons per household – 4.5
- Sewage flow/household – 400 l/day
- Peak flow factor – 2.5
- Oxidation pond calculations
- Biological Oxygen Demand/ person – 50 g/capita/day
- Anaerobic pond BOD removal – 50%

The daily sewer inflow was calculated using the population data along with the parameters mentioned and are shown in Table 3.

Table 3: Projected Sewer Inflow

Year	Population	Residences	Projected Flow m ³ /day		
			m ³ /day	Average Flow(l/s)	Peak Flow (l/s)
2019	1 670	371	148	1.72	4.30
2029	1 755	390	156	1.81	4.51
2039	1 845	410	164	1.90	4.75

3.1.1 ANAEROBIC PONDS

According to the flow calculations the town of Kamieskroon requires two anaerobic ponds with a capacity of 985 m³ each. This will enable the anaerobic ponds to be used in parallel and the ponds can be alternated to ensure that the sedimentation build up in the ponds are controlled and that the pond depths will not be decreased over the 20-year life span of the oxidation pond system. The existing ponds will be upgraded and lined, to provide the required capacity. The existing ponds are slightly larger than the required capacity, but to save costs. The ponds will be used as is, with minor upgrades required along with the lining installation.

3.1.2 PRIMARY AND SECONDARY PONDS

The primary and secondary ponds are similar in nature and the function of these ponds are to provide sufficient retention/maturation periods for the sewer inflow. According to the design calculations, the Primary and Secondary Ponds require a combined volume of 6 610 m³. The existing primary and secondary ponds can only provide a combined volume of 5 928m³ if they are used individually and are therefore not sufficient to accommodate the future population growth. If two of the secondary ponds were to be combined, it would provide sufficient capacity. Refer to Annexure B for the layout of the combined ponds.

3.1.3 EVAPORATION PONDS

Calculations were made taking into account the daily sewer inflow and the daily evaporation tempo, to determine the minimum evaporation area required to ensure that the ponds do not overflow within the 20-year design period. These calculations take into account the gradual increase of water levels that will eventually lead to the ponds overflowing. The evaporation tempo varies between 5 mm/ha/day in the winter to 10mm/ha/day during the summer months. The calculations are shown in Annexure C.

4. DESIGN AREAS AND VOLUMES

The total design volumes and areas for the anaerobic, primary and secondary ponds are shown in Table 3. According to the calculations, in Annexure C, the Evaporation Ponds would need to have minimum evaporation area of 12 200 m² with a minimum volume of 11 067 m³, also shown in Table 4.

Table 4: Final Design Capacities of the Upgraded Oxidation Pond System

Design Volumes and Areas					
	Type	Number	Design Volume (m ³)	Design Area (m ²)	(ha)
1	Anaerobic Ponds	2	1112	572	0.05
2	Primary Ponds	1	2298	2541	0.25
3	Secondary Ponds	3	4312	3577	0.36
4	Evaporation Ponds	3	11195	12226.	1.22
Total			18 918	18 916	1.9

* There are two anaerobic ponds, the ponds will be used in parallel

In an attempt to minimize costs, the designs were done to utilise as much of the existing ponds as possible with minimum upgrades and changes required. The existing and design volumes are compared in Table 5. You will note that the existing anaerobic ponds have sufficient capacity. The combination of two of the secondary ponds into one pond is required to provide sufficient capacity for the primary and secondary ponds. The existing system however did not have any evaporation ponds and new lined evaporation ponds will therefore be required for the upgraded oxidation pond system.

Table 5: Comparison of existing and final design capacities

	Type	Existing Volume (m ³)	Design Volume (m ³)	Existing Area (m ²)	Design Area (m ²)	Comment
1	Anaerobic Ponds*	1077	1112	556	572	Existing Sufficient
2	Primary Ponds	2 324	2298	2 045	2 541	Combined areas insufficient
3	Secondary Ponds	3 604	4312	3 316	3 577	
4	Evaporation Ponds		11195		12 226	No Existing Evaporation Ponds
	Total	7 005	18 918	5 918	18 916	

* Two anaerobic ponds used in parallel

4.1 Final Design Sizes

The current system does not have any evaporation ponds. The design for the ponds, taking into account the upgrades to the existing system, shows that the area required to provide sufficient evaporation area for the ponds for the next 20 years, is 12 266 m².

Taking into account the available area for the oxidation pond system, the volumes and areas for the various ponds for the upgrade are shown in Table 6. Refer to Annexure B for the layout of the ponds.

Table 6: Design Volumes and Areas

		Volume (m ³)	Area (m ²)
Pond 1	Anaerobic	1112.8	572
Pond 2	Anaerobic	1112.8	572
<i>Total Anaerobic Ponds</i>		2225.6	1144
Pond 3	Primary	2298	2541
<i>Total Primary Ponds</i>		2298	2541
Pond 4	Secondary	1305	1486
Pond 5	Secondary	3007	2091
<i>Total Secondary Ponds</i>		4312	3577
Pond 6	Evaporation Ponds	2769	3036
Pond 7	Evaporation Ponds	2769	3036
Pond 8	Evaporation Ponds	2769	3036
Pond 9	Evaporation Ponds	2888	3158
<i>Total Evaporation Ponds</i>		11195	12266

5. PROPOSED WORK

The current oxidation ponds are located South of the Kamieskroon town. The existing ponds and surrounding areas have been surveyed and it has been found that the existing ponds can be expanded to accommodate the increase in sewage flow from town.

The following activities are proposed to upgrade the oxidation pond system:

- The existing oxidation ponds should be upgraded to meet the specifications of the Department of Water and Sanitation and be used as anaerobic, primary and secondary ponds. New in- and outlet structures should be constructed and the ponds must be lined with 2mm HDPE – Lining. The lining will ensure that the ponds are sealed off.
- The size of the existing anaerobic ponds is sufficient, minor upgrades are required along with the lining of the ponds.
- The size of the existing primary ponds is sufficient; however, the ponds need to be lined.
- Two of the secondary ponds must be combined to provide one larger pond to provide sufficient capacity. These ponds must also be lined.
- The construction of four new evaporation ponds connecting to the existing system with in-and outlet structures and lined with 2mm HDPE – linings and geomembranes will be required as part of the upgrade.
- The construction of security fences around the extension of the oxidation pond system and the evaporation ponds will be part of the work.

Standard detail for the design of oxidation pond systems are shown in Annexure D. Some of the design parameters to take into account are the following:

- 0.8 m freeboard
- 1:2.5 embankment slopes
- 2 mm HDPE lining

6. COST ESTIMATE

The cost estimations for the project includes the scope of works as given in section 5. The total estimated cost is estimated at R 20 572 046.05 as shown in Table 7 below.

Table 7: Total Estimated Cost

Item	Description	Amount
1	Preliminary and General Costs	R 1,183,236.00
2	Earthworks and Lining at Existing Ponds	R 2,506,450.00
3.	Security Fencing at Existing Ponds	R 34,530.00
4.	Construction of New Oxidation Ponds	R 8,727,750.00
5.	Pipe Trenches for Sewer Pipeline	R 111,350.00
6.	Construction of Sewer Pipeline	R 52,300.00
7.	Security Fencing at New Oxidation Ponds	R 399,980.00
	Sub Total	R 13,015,596.00
8.	Plus 10% Contingencies	R 1,301,559.60
	Sub Total	R 14,317,155.60
9.	Plus 10% Contract Price Adjustments and Increases	R 1,431,715.56
	Sub Total	R 15,748,871.16
10.	Environmental Impact Assessment	R 250,000.00
11.	Engineering Expenses	R 1,889,864.54
	Sub Total	R 17,888,735.70
12.	Plus 15% VAT	R 2,683,310.35
	Total Estimated Expenses	R 20,572,046.05
	Number of Residents	1,590.00
	Unit Cost per Consumer (excluding VAT)	R 11,250.78

7. CONCLUSION

The capacity of the existing oxidation pond system is insufficient. The existing ponds also does not comply with the Department of Water and Sanitation guidelines. The upgrade and extension of the existing oxidation pond system, consisting of the upgrade and lining of existing ponds as well as the construction of evaporation ponds are recommended.

For any questions, contact this office, Tel: 027 7129990

Thank you

Annexure A :

Drawing: Existing Oxidation Pond System



NOTE / DRAWING		APPROVED BY COUNCIL / CLIENT			DATE	INITIAL	REVISION NUMBER	REVISION DESCRIPTION	CLIENT		PROJECT			APPROVED BY IMA		
<small>DRAWING NOT FOR CONSTRUCTION TO SCALE REDUCE DRAWING</small>					-	-	-	-								
<input checked="" type="checkbox"/> PRELIMINARY INFO ONLY FOR TENDER FOR CONSTRUCTION AS-BUILT		CITY ENGINEER / CLIENT _____ <small>AMPHOWENIS CODE</small> REG. NO. _____ DATE _____									KAMIESKROON OXIDATION PONDS <small>GENERAL LAYOUT:</small> DRAWING TITLE: W.CLOTHS DRAWN: W.CLOTHS CHECKED: W.CLOTHS PLAN NUMBER: 31212.01S-100-01 DRAWN BY: A DATE DRAWN: 21/04/2020					
<small>A&E: J - IMPORT DRAWINGS TE: J - TECHNIC DRAWINGS A/3: J - APPROV DRAWINGS Z: J - M-BUST R: J - OTHER</small>		<small>J: BY CIVIL A: BY ARCHITECT E: BY MECHANICAL OR ELECTRICAL D: BY IMA</small>			<small>COPYRIGHT: THIS DRAWING IS THE PROPERTY OF IMA CONSULTING ENGINEERS. IT MAY NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART, NOR MAY IT BE USED FOR ANY PURPOSE OTHER THAN FOR WHICH IT WAS PROVIDED. IT MAY NOT BE RELEASED FOR ANY PURPOSE OTHER THAN FOR WHICH IT WAS PROVIDED.</small>											

Annexure B:

Drawing: Layout of Upgraded Oxidation Pond System



DRAWING NOT PRINTED TO SCALE REDUCED FROM A1 TO A3	ISSUE DATE	DRAWING NUMBER	REVISED BY
	19 May 2020	A1	B
	X PRELIMINARY		
	INFO ONLY		
	FOR TENDER		
	FOR CONSTRUCTION		
AS-BUILT			

APPROVED BY COUNCIL / CLIENT			DATE	INITIAL	NUMBER	REVISION DESCRIPTION
CITY ENGINEER / CLIENT	REQ. NO.	DATE				
AMENDMENT'S CODE						
A.C. / BEFORE TENDER	IA: BY CLIENT					
/ B.D. / TRADER DRAWING	IB: BY ARCHITECT					
I.C. / AFTER TENDER	IC: BY MECHANICAL OR ELECTRICAL					
/ A.B. / AS BUILT	ID: BY BM					
	IE: BY OTHER					
COPYRIGHT THIS DRAWING IS THE PROPERTY OF BM CONSULTING P/L LTD. IT IS UNLAWFUL AND CONFIDENTIAL AND IS SUPPLIED ON THE EXPRESS UNDERSTANDING THAT IT IS NOT TO BE COPIED FOR ANY PURPOSES OTHER THAN THAT FOR WHICH IT WAS PROVIDED. ANY PERSON REPRODUCING THE DRAWINGS CONSTITUTES AN INFRINGEMENT OF THE PROPRIETARY						



PROVINCE	OFFICE	TELEPHONE	FAX	E-MAIL
Gauteng	Central	(011) 466 1000	(011) 466 1001	gauteng@valve.com
Pretoria	Central	(012) 466 1000	(012) 466 1001	pretoria@valve.com
Northern Cape	Johannesburg	(011) 466 1000	(011) 466 1001	northern_cape@valve.com
Northern Cape	Upington	(053) 110 0000	(053) 110 0001	upington@valve.com
Northern Cape	Port Elizabeth	(041) 544 0000	(041) 544 0001	port_elizabeth@valve.com
Northern Cape	East London	(043) 410 0000	(043) 410 0001	east_london@valve.com

KAMIESKROON
OXIDATION PONDS

GENERAL LAYOUT

APPROVED BY		
ENGINEER/TECHNOLOGIST	REG. NO.	DATE
ROLE	NAME	DRAWN BY S. CLOTH
DRAWSN	S. CLOTH	CHECKED BY W. CLOTH
PLATE NUMBER	REVISION NO.	DATE SIGNED
31212.02S-100-01	B	19/05/2020

Annexure C: Evaporation Pond Calculations

Total Area for Oxidation Ponds System													
		Anearobic Primary and Secondary ponds				Evaporation Ponds		TOTAL					
Area		7262.00				12266		19528.00		m2			
Volume		8835.6				11195		20030.60		m3			
		January	feb	March	April	May	June	July	August	September	October	November	December
Volume sewer inflow		4601.8	644.3	685.5	2080.4	979.2	740.8	667.9	636.4	790.6	953.7	783.8	1138.3
Average Evaporation Tempo (m)		0.310	0.280	0.310	0.210	0.217	0.150	0.155	0.155	0.210	0.310	0.300	0.310
Evaporation (m3) (evap temp x total pond area)		6053.7	5467.8	6053.7	4100.9	4237.6	2929.2	3026.8	3026.8	4100.9	6053.7	5858.4	6053.7

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Volume inflow	4601.8	4156.4	4601.8	4453.3	4601.8	4453.3	4601.8	4601.8	4453.3	4601.8	4453.3	4601.8
	0.310	0.280	0.310	0.210	0.217	0.150	0.155	0.155	0.210	0.310	0.300	0.310
	6053.7	5467.8	6053.7	4100.9	4237.6	2929.2	3026.8	3026.8	4100.9	6053.7	5858.4	6053.7
	-1451.9	-1311.4	-1451.9	352.5	364.2	1524.1	1574.9	1574.9	352.5	-1451.9	-1405.1	-1451.9
	0.0	0.0	0.0	352.5	716.7	2240.8	3815.7	5390.7	5743.1	4291.2	2886.1	1434.2
2020	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4624.8	4177.2	4624.8	4475.6	4624.8	4475.6	4624.8	4624.8	4475.6	4624.8	4475.6	4624.8
	0.310	0.280	0.310	0.210	0.217	0.150	0.155	0.155	0.210	0.310	0.300	0.310
	6053.7	5467.8	6053.7	4100.9	4237.6	2929.2	3026.8	3026.8	4100.9	6053.7	5858.4	6053.7
	-1428.9	-1290.6	-1428.9	374.7	387.2	1546.4	1597.9	1597.9	374.7	-1428.9	-1382.8	-1428.9
2021	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4647.9106	4198.1128	4647.9106	4497.978	4647.9106	4497.978	4647.9106	4647.9106	4497.978	4647.9106	4497.978	4647.9106
	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
	-1405.7694	-1269.7272	-1405.7694	397.098	410.3346	1568.778	1621.0706	1621.0706	397.098	-1405.769	-1360.422	-1405.769
2022	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4671.150153	4219.103364	4671.150153	4520.4679	4671.15015	4520.4679	4671.1502	4671.1502	4520.4679	4671.1502	4520.4679	4671.1502
	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
	-1382.529847	-1248.736636	-1382.52985	419.58789	433.574153	1591.2679	1644.3102	1644.3102	419.58789	-1382.53	-1337.932	-1382.53
2023	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4694.505904	4240.198881	4694.505904	4543.0702	4694.5059	4543.0702	4694.5059	4694.5059	4543.0702	4694.5059	4543.0702	4694.5059
	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
	-1359.174096	-1227.641119	-1359.1741	442.19023	456.929904	1613.8702	1667.6659	1667.6659	442.19023	-1359.174	-1315.33	-1359.174
2024	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4717.978433	4261.399875	4717.978433	4565.7856	4717.97843	4565.7856	4717.9784	4717.9784	4565.7856	4717.9784	4565.7856	4717.9784
	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
	-1335.701567	-1206.440125	-1335.70157	464.90558	480.402433	1636.5856	1691.1384	1691.1384	464.90558	-1335.702	-1292.614	-1335.702
2025	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4741.568325	4282.706875	4741.568325	4588.6145	4741.56833	4588.6145	4741.5683	4741.5683	4588.6145	4741.5683	4588.6145	4741.5683
	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
	-1312.111675	-1185.133125	-1312.11167	487.73451	503.992325	1659.4145	1714.7283	1714.7283	487.73451	-1312.112	-1269.785	-1312.112
2026	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	4765.276167	4304.120409	4765.276167	4611.5576	4765.27617	4611.5576	4765.2762	4765.2762	4611.5576	4765.2762	4611.5576	4765.2762
	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
	-1288.403833	-1163.719591	-1288.40383	510.67758	527.700167	1682.3576	1738.4362	1738.4362	510.67758	-1288.404	-1246.842	-1288.404
2027	Jan	Feb	Mar	Apr	May	Jun	Jul					

Volume of water in ponds	-1240.631939	-1120.570784	-1240.63194	556.90845	575.472061	1728.5884	1786.2081	1786.2081	556.90845	-1240.632	-1200.612	-1240.632
	1855.366276	734.7954921	0	556.90845	1132.38051	2860.969	4647.177	6433.3851	6990.2935	5749.6616	4549.05	3308.4181
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4837.113301	4369.005562	4837.113301	4681.0774	4837.1133	4681.0774	4837.1133	4837.1133	4681.0774	4837.1133	4681.0774	4837.1133
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1216.566699	-1098.834438	-1216.5667	580.19739	599.537301	1751.8774	1810.2733	1810.2733	580.19739	-1216.567	-1177.323	-1216.567
	2091.851387	993.0169495	0	580.19739	1179.73469	2931.6121	4741.8854	6552.1587	7132.3561	5915.7894	4738.4668	3521.9001
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4861.298867	4390.85059	4861.298867	4704.4828	4861.29887	4704.4828	4861.2989	4861.2989	4704.4828	4861.2989	4704.4828	4861.2989
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1192.381133	-1076.98941	-1192.38113	603.60277	623.722867	1775.2828	1834.4589	1834.4589	603.60277	-1192.381	-1153.917	-1192.381
	2329.518924	1252.529514	60.14838175	663.75116	1287.47402	3062.7568	4897.2157	6731.6745	7335.2773	6142.8962	4988.979	3796.5978
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4885.605362	4412.804843	4885.605362	4728.0052	4885.60536	4728.0052	4885.6054	4885.6054	4728.0052	4885.6054	4728.0052	4885.6054
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1168.074638	-1055.035157	-1168.07464	627.12519	648.029362	1798.8052	1858.7654	1858.7654	627.12519	-1168.075	-1130.395	-1168.075
	2628.523181	1573.488024	405.4133854	1032.5386	1680.56794	3479.3731	5338.1385	7196.9038	7824.029	6655.9544	5525.5596	4357.4849
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4910.033389	4434.868867	4910.033389	4751.6452	4910.03339	4751.6452	4910.0334	4910.0334	4751.6452	4910.0334	4751.6452	4910.0334
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1143.646611	-1032.971133	-1143.64661	650.76521	672.457389	1822.4452	1883.1934	1883.1934	650.76521	-1143.647	-1106.755	-1143.647
	3213.838338	2180.867205	1037.220594	1687.9858	2360.4432	4182.8884	6066.0818	7949.2752	8600.0404	7456.3938	6349.639	5205.9924
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4934.583556	4457.043211	4934.583556	4775.4034	4934.58356	4775.4034	4934.5836	4934.5836	4775.4034	4934.5836	4775.4034	4934.5836
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1119.096444	-1010.796789	-1119.09644	674.52344	697.007556	1846.2034	1907.7436	1907.7436	674.52344	-1119.096	-1082.997	-1119.096
	4086.895952	3076.099163	1957.002719	2631.5262	3328.53372	5174.7372	7082.4807	8990.2243	9664.7477	8545.6513	7462.6547	6343.5583
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4959.256473	4479.328428	4959.256473	4799.2805	4959.25647	4799.2805	4959.2565	4959.2565	4799.2805	4959.2565	4799.2805	4959.2565
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1094.423527	-988.5115725	-1094.42353	698.40046	721.680473	1870.0805	1932.4165	1932.4165	698.40046	-1094.424	-1059.12	-1094.424
	5249.134733	4260.623161	3166.199634	3864.6001	4586.28057	6456.361	8388.7775	10321.194	11019.594	9925.1709	8866.0514	7771.6278
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	4984.052756	4501.72507	4984.052756	4823.2769	4984.05276	4823.2769	4984.0528	4984.0528	4823.2769	4984.0528	4823.2769	4984.0528
Evaporation (m3) (evap temp x area)	0.31	0.28	0.31	0.21	0.217	0.15	0.155	0.155	0.21	0.31	0.3	0.3102804
Volume available of water in Ponds	6053.68	5467.84	6053.68	4100.88	4237.576	2929.2	3026.84	3026.84	4100.88	6053.68	5858.4	6053.68
Volume of water in ponds	-1069.627244	-966.1149303	-1069.62724	722.39686	746.476756	1894.0769	1957.2128	1957.2128	722.39686	-1069.627	-1035.123	-1069.627
	6702.000589	5735.885658	4666.258414	5388.6553	6135.13203	8029.2089	9986.4216	11943.634	12666.031	11596.404	10561.281	9491.6536
Volume inflow	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average Evaporation Tempo (m/month)	5008.973019	4524.233695	5008.973019	4847.3932	5008.97302	4847.3932	5008.973	5008.973	4847.3932	5008.973	4847.3932	5008.973
Evaporation (m3) (evap temp x area)												

Annexure D

Drawings: Standard Detail for Oxidation Ponds

