



*Calvinia, Hantam municipality
Additional groundwater supply, Northern
Cape (2018).*

REPORT:

GEOSS Report No: 2018/10-18

PREPARED FOR:

Gert Meiring
BVI - Upington Office
Director - Civil Department
55 Bult Street
Upington
8800
South Africa

PREPARED BY:

Charles Peek
GEOSS - Geohydrological and Spatial
Solutions International (Pty) Ltd
Unit 12, Technostell Building,
9 Quantum Street,
TechnoPark
Stellenbosch 7600
Tel: (021) 880-1079
Email: info@geoss.co.za
(www.geoss.co.za)



23 October 2018

EXECUTIVE SUMMARY

BVi Consulting Engineers have been appointed by the Hantam Municipality to conduct a feasibility study and find a long-term solution for the bulk water supply to Calvinia in the Northern Cape. It has recently faced water shortages due to drought conditions in the area. The current water usage for the town equates to approximately 14.5 L/s. GEOSS was subcontracted, as groundwater consultants, in order to site additional boreholes to be drilled and tested for sustainable supply to the town, with a target of 45 L/s.

Current supply boreholes were reassessed and six new areas were investigating for possible groundwater development:

- Rhenosterhoek Farm
- Nature reserve
- Ceres Karroo area (Kruitberg)
- Keiskie
- Downes
- North-west region

The study included an initial remote geological and topographical investigation of the area and lineament mapping; this preceded the site visit. The site visit included a hydrocensus, an evaluation of the site geology and geophysics.

Thirty-one boreholes were drilled, of which twelve were viable for testing. The total estimate sustainable yield from these boreholes is 68 L/s which meets the target yield of the project, although it will require careful management, informed by groundwater level monitoring, to ensure it is correctly utilised.

Overall the groundwater quality is classified as “good to moderate”. The fluoride concentration of all the tested sites is a concern (of varying degrees) and should be addressed before production begins. Exploration borehole Cal_Phase3_4A had an anomalous high iron concentration of 22 mg/L, typical iron concentrations range between 0.024 – 0.3 mg/L in the Calvinia area.

It is recommended that monitoring equipment be installed in the boreholes, in order to ensure data informed management. The boreholes will also need to be authorised via a Water Use License Application.

Ooooo OOO oooooO

TABLE OF CONTENTS

1. INTRODUCTION	1
2. TERMS OF REFERENCE	1
3. REGIONAL SETTING	2
3.1 General	2
3.2 Climate	2
3.3 Regional Geology	3
3.3.1 Unconsolidated units	3
3.3.2 Sedimentary units	3
3.3.3 Dolerite Intrusions	3
3.3.4 Breccia Pipes	4
3.4 Regional Hydrogeology	4
3.4.1 Aquifer type and yield	4
3.4.2 Groundwater quality	4
4. SITE VISIT - HYDROCENSUS	5
4.1 Site visit	5
4.1.1 Production boreholes	5
5. DESKTOP STUDY AND GROUNDWATER EXPLORATION	7
5.1 Desktop study	7
5.2 Exploration study	8
5.3 Exploration Borehole sites	9
6. DRILLING RESULTS	10
7. PUMPING TESTS: EXISTING PRODUCTION BOREHOLE	13
7.1 Ceres Road	13
7.2 Sandgat 3	14
7.3 Sandgat 4	15
7.4 Sandgat 5	16
7.5 De Vlok Bh	17
7.6 Witvaal	18
7.7 Golf course Bh	19
7.8 Summary of results	20
8. PUMPING TEST: EXPLORATION BOREHOLES (2018)	21
8.1 Cal_Nat1 (Cal_DV1)	21
8.2 Cal_Nat2 (Cal_DV3)	23
8.3 Cal_Nat3 (Cal_DV4)	24
8.4 Cal_KB1 (Cal_S2_3)	25
8.5 Cal_S2_4	26
8.6 Cal_S2_10	27
8.7 Cal_Nat 5	28
8.8 Cal_Nat6	29
8.9 Cal_Phase3_6	30
8.10 Cal_Phase3_4A	31

8.11	Cal_Phase3_9.....	32
8.12	Re-Drill 39602	33
8.13	summary of results.....	34
9.	CHEMISTRY	35
9.1	Groundwater quality analysis for existing production boreholes	35
9.2	Groundwater quality analysis on newly drilled exploration boreholes 2018.....	37
10.	DISCUSSION.....	42
11.	RECOMMENDATIONS	42
12.	ACKNOWLEDGEMENTS	43
13.	REFERENCES	43
14.	APPENDIX A: MAPS	45
15.	APPENDIX B: GEOPHYSICS.....	54
16.	APPENDIX C: LABORATORY RESULTS – BEMLAB/ A.L ABBOT AND ASSOCIATES.....	58
17.	APPENDIX D: – PUMPING TEST DATA SHEETS – AB PUMPS.....	102
18.	APPENDIX E: – BOREHOLE LOGS – H & A DRILLING	160

LIST OF FIGURES

Figure 1: Long term annual climatic data for Calvinia (online, meteo-climat-bzh access 2017)	3
Figure 2: Constant Discharge Test and Recovery of Ceres Road BH	13
Figure 3: Constant Discharge Test and Recovery of Sandgat3	14
Figure 4: Constant Discharge Test and Recovery of Sandgat 4.....	15
Figure 5: Constant Discharge Test and Recovery of Sandgat 5.....	16
Figure 6: Constant Discharge Test and Recovery of De Vlok Bh.....	17
Figure 7: Constant Discharge Test and Recovery of Witvaal.....	18
Figure 8: Constant Discharge Test and Recovery of Golf course	19
Figure 9: Constant Discharge Test and Recovery of Cal_DV1. (A) 22 L/s CDT and recovery. (B) 15 L/s CDT and Recovery.....	22
Figure 10: Constant Discharge Test and Recovery of Cal_DV3	23
Figure 11: Constant Discharge Test and Recovery of Cal_DV4	24
Figure 12: Constant Discharge Test and Recovery of Cal_s2-3.....	25
Figure 13: Constant Discharge Test and Recovery of Cal-S2-4.....	26
Figure 14: Constant Discharge Test and Recovery of Cal-S2-10.....	27
Figure 15: Constant Discharge Test and Recovery of Cal_Nat 5.....	28
Figure 16: Constant Discharge Test and Recovery of Cal_Nat 6.....	29
Figure 17: Constant Discharge Test and Recovery of Cal_phase3_6	30
Figure 18: Constant Discharge Test and Recovery of Cal_Phase3_4A.....	31
Figure 19: Constant Discharge Test and Recovery of Cal_Phase3_9	32
Figure 20: Constant Discharge Test and Recovery of Re_drill39602	33

LIST OF TABLES

Table 1: Calvinia Production boreholes information.....	5
Table 2: Temporal data water level data was provided by DWS.....	6
Table 3: Exploration boreholes.....	9
Table 4: Drilling results summary.....	11
Table 5: Summary of existing boreholes yield test.....	20
Table 6: Summary of exploration boreholes yield test.....	34
Table 7: Classification table for specific limits.....	35
Table 8: Water chemistry of existing production boreholes.....	36
Table 9: 2018 exploration borehole results classified according the SANS241-1:2015.....	38
Table 10: Classification table for the groundwater results (DWAF, 1998).....	40
Table 11: Classified existing production borehole results.....	40
Table 12: Classified exploration borehole results.....	41

ABBREVIATIONS

CGS	The Council of Geoscience
CDT	Constant discharge test
DWA	Department of water affairs
DWAF	Department of Water and Forestry
L/s	litres per second
m	metres
mamsl	meters above mean sea level
mbch	metres below collar height
mbgl	metres below ground level
mm/a	millimetres per annum
mS/m	milliSiemens per meter
NGA	National Groundwater Archive

GLOSSARY OF TERMS

- Aquifer:** a geological formation, which has structures or textures that hold water or permit appreciable water movement through them [from National Water Act (Act No. 36 of 1998)].
- Borehole:** includes a well, excavation, or any other artificially constructed or improved groundwater cavity which can be used for the purpose of intercepting, collecting or storing water from an aquifer; observing or collecting data and information on water in an aquifer; or recharging an aquifer [from National Water Act (Act No. 36 of 1998)].
- Fractured aquifer:** Fissured and fractured bedrock resulting from decompression and/or tectonic action. Groundwater occurs predominantly within fissures and fractures.
- Groundwater:** water found in the subsurface in the saturated zone below the water table or piezometric surface i.e. the water table marks the upper surface of groundwater systems.
- Intergranular Aquifer:** Generally unconsolidated but occasionally semi-consolidated aquifers. Groundwater occurs within intergranular interstices in porous medium. Typically occur as alluvial deposits along river terraces.
- Intergranular and fractured aquifers:** Largely medium to coarse grained granite, weathered to varying thicknesses, with groundwater contained in intergranular interstices in the saturated zone, and in jointed and occasionally fractured bedrock.
- Transmissivity:** the rate at which a volume of water is transmitted through a unit width of aquifer under a unit hydraulic head (m^2/d); product of the thickness and average hydraulic conductivity of an aquifer.

Suggested reference for this report:

GEOSS (2018). Calvinia, Hantam municipality- Additional groundwater supply, Northern Cape.: GEOSS Report number: 2018/10-18. GEOSS - Geohydrological & Spatial Solutions International (Pty) Ltd. Stellenbosch, South Africa.

Cover photo:

Borehole drilling within the Calvinia nature reserve.

GEOSS project number:

2017_03-2026.

Reviewed by:

Julian Conrad (23 October 2018)

1. INTRODUCTION

BVi Consulting Engineers have been appointed by the Hantam Municipality to conduct a feasibility study to find a long-term solution for the bulk water supply to Calvinia in the Northern Cape.

Calvinia is a small town in the Northern Cape province of South Africa, located 380 km north-east of Cape Town in the Namakwa District (**Map 1, Appendix A**). It is currently facing water shortages due to low levels in the Karee dam and the bulk supply is limited due to problems with the supply boreholes water levels declining. The current water usage for the town is 1250 cubes/pd, this equates to 14.5 L/s. Groundwater in the region does show potential and a revised assessment is required of the groundwater options for groundwater supply. This includes investigating the following areas and re-assessing current supply boreholes:

- Rhenosterhoek Farm
- Nature reserve
- Ceres Karroo area (Kruitberg)
- Keiskie
- Downes
- North-west region

The study included an initial remote geological and topographical investigation of the area and lineament mapping; this preceded the site visit. The site visit included a hydrocensus, an evaluation of the site geology and geophysics.

2. TERMS OF REFERENCE

The project Terms of Reference were to assess the existing utilised groundwater resources and develop additional groundwater resources by:

- Obtain all relevant data to the project (i.e. obtain data from the National Groundwater Archive (NGA), etc), including geological maps and geohydrological maps. Any relevant groundwater reports will also be sourced.
- Evaluating the potential of locating additional boreholes within the current well fields
- Map potential groundwater bearing structures and formations on the satellite imagery and aerial photographs using the ArcGIS desktop software. The lineaments will be mapped using false-colour composites and grey-scale pansharpened aerial images. The satellite lineament data will then be overlain on the 1:50 000 scale digital geological maps. The geological data of the area will be digitised and attributed from the published geological and other relevant maps. The boreholes and other relevant groundwater information will be superimposed on GIS generated maps for analysis.

- Surface geological and geophysical (electromagnetic and magnetic) mapping will be conducted in detail in areas where boreholes with groundwater potential may occur
- Analyse the data, using geohydrological methods and address the questions set out in the project objectives.
- Manage drilling and yield testing of additional boreholes
- Undertake safe yield and water quality assessment of current supply boreholes. The test pumping data will be analysed using various methods (Theis, Cooper-Jacob and FC).
- A 24, 48 or 72-hour sustainable pumping schedule for each borehole will be determined as well as alternative pumping schedule to maximise the boreholes. Optimum allowable water level drawdown and pump depth will be advised.

3. REGIONAL SETTING

3.1 *General*

Calvinia falls under the jurisdiction of the Hantam Local Municipality in Namakwa District which is located in the southern part of the Northern Cape Province. The town is just south of the Hantam mountains on the banks of the Oorlogskloof River. The town is 380 km north of Cape Town and 400 km south west of Upington. The town's elevation is approximately 1050 m above mean sea level, and positioned on a water divide, with streams radiating outwards in all directions. The town is located in quaternary catchment E40B, but positioned close to the boundary with E40A (East) and D58B (North). The Hantam Local Municipality is the Water Services Authority and the Water Services Provider for all the settlements under its jurisdiction (DWA, 2009).

The Town is dependent on the Karee Dam located 4.5 km north of the town, during dry periods when the dam is empty the town use its alternative groundwater source as a backup. The town currently uses six production boreholes located east of the town.

3.2 *Climate*

Hantam Municipal Area lies in an area that falls on the boundary between regions with summer and winter rainfall, and rainfall therefore occurs throughout the year. The long-term average climatic data for Calvinia (1981 – 2010) indicate an approximate rainfall of 198 mm/a for the period (**Figure 1**). The data indicates that >70% of the rainfall occurs during the summer months (November to April). December and January are the wettest months whilst June and July are the driest.

Climate data for Calvinia (1981-2010)													
Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Average high °C	32	32.3	30.1	26	21.5	18.2	17.9	19.4	22.5	25.9	28.2	30.3	25.3
Daily mean °C	22.7	22.9	21.1	17.4	13.8	10.8	10.5	11.2	13.7	16.8	19.1	21.1	16.8
Average low °C	13.4	13.8	12.3	9.5	6.4	3.8	3.6	3.4	5	7.9	10	12	8.3
Average rainfall mm	29.49	26.94	27.31	18.56	9.33	0.64	1.09	5.07	11.41	18.87	22.48	27.73	198.92
Average rainy days (≥ 1.0 mm)	1	1	3	4	3	4	4	4	4	3	2	2	35

Figure 1: Long term annual climatic data for Calvinia (online, meteo-climat-bzh access 2017)

3.3 Regional Geology

The Geological Survey of South Africa (now the Council for Geoscience) has mapped the area at 1:250 000 scale (3118 Calvinia). The geological setting is shown in **Map 3 (Appendix A)**. The geology underlying Calvinia can be broken down into different lithologies.

3.3.1 Unconsolidated units

Alluvial and colluvium deposits are limited in thickness and extent in the Calvinia area. They comprise mostly of weathering products of argillaceous rocks which have been deposited by sheet wash process. Majority of the alluvial is located within the Oorlogskloof River and Vlakfontein River channel. The thickness of the alluvium material varies between 5 – 30 meters below ground level.

3.3.2 Sedimentary units

The sediments in the Calvinia area belong to the Ecca Group of the Karoo Sequence. The formation present in the area is:

- Tierberg Shale Formation (Ecca Group)

These formations are all argillaceous in nature. The formation consists of quartzitic sandstone and subordinate shale bands. The Tierberg Formation comprises upward – coarsening sequence of thin laminated, dark-brown to light grey shale. Thin yellow weathering layers of volcanic ash may be present.

3.3.3 Dolerite Intrusions

An attempt was made to correlate the dolerite sheets with those of the Calvinia area some 80 km away (DWAF, 1981). A regular horizontal dolerite sheet with a thickness of 120 m was identified in Calvinia with an upper contact of 880 mamsl. This may correlate with the Rheebofsfontein Sheet which displays the same thickness but is at a lower elevation (~ 100 m lower).

The outcrop of dolerite in Calvinia with a lower contact at 1 010 – 1 040 mamsl may correspond with the Loeriesfontein Sheet. These correlations are tentative, but are potentially important considering the significant bearing that dolerite sheets have on groundwater occurrence in this geological setting.

3.3.4 Breccia Pipes

Additionally, there are a number of breccia pipes in the study area. These have been drilled by the Council for Geoscience and Department of water Affairs for investigation and water supply. They are evident in the field as dome shaped hills, as the pipes and surrounding metamorphosed rock is more resistant to weathering than the host rock. From aerial photography the pipes are evident as a dark spherical structure surrounded by a white alteration halo in the surrounding sedimentary formation.

The pipes consist of baked and dislocated shale and mudstone of the Prince Albert and Whitehill Formations, but molten, recrystallized and contorted sediments containing clasts from underlying strata are also found. These pipes resulted from localised hydrothermal activity generated by the emplacement of the lowermost dolerite sills.

3.4 *Regional Hydrogeology*

3.4.1 Aquifer type and yield

According to the 1:500 000 scale groundwater map of Calvinia (3118) the area does host a fractured aquifer. These semi-confined aquifers are formed by jointing and fracturing within the solid bedrock. (**Map 4, Appendix A**). The average borehole yield in the region has been classified as 0.5 to 2 L/s according to Department of Water Affairs and Forestry (DWAF 1998).

Primary or intergranular aquifers do occur within the area along the river banks/channels of the Oorlogskloof River. Groundwater flows within the unconsolidated sediment and weathered bedrock formations. The average thickness of the unconsolidated and weathered zone is 25 – 35 meters. In general, these aquifers are poorly developed and vulnerable to drought conditions.

3.4.2 Groundwater quality

Based on the DWAF (1998) classification the regional groundwater quality underlying the town and its surrounds is good to marginal with an associated electrical conductivity (EC) of 70 – 300 mS/m. (**Map 5, Appendix A**).

4. SITE VISIT - HYDROCENSUS

4.1 Site visit

Prior to the field work being carried out all relevant borehole data was obtained for the area and current production boreholes. In addition, the field work was used as an opportunity to collect as much anecdotal information as possible. The individual boreholes were visited to determine their state.

4.1.1 Production boreholes

Calvinia currently has seven production boreholes of which six are used for Town supply (**Table 1**). Calvinia-Ceres Rd BH was identified as a potential site during the site visit to conduct a pumping test. The Breccia BH was initially a study site for a potential artificial recharge scheme conducted by Dr. Murray. The borehole is used to store water during times of excess surface water for the purpose of supplying water during periods of drought. Currently (2018) the borehole is not been used to supply water.

Table 1: Calvinia Production boreholes information

Bhole ID	Latitude	Longitude	Elevation (mamsl)	Pump Depth (m)
Calvinia-Ceres Rd_BH	-31.635482	19.749442	1067	-
Golf_course_BH	-31.482959	19.763893	979	200
Witwal_BH	-31.452398	19.811102	1004	-
Sandgat_3_BH	-31.498032	19.874576	1007	17.00
Sandgat_4_BH	-31.502987	19.875842	1006	?38
Sandgat_5_BH	-31.509516	19.850230	1005	200
Breccia_BH	-31.485347	19.900996	1066	>100
Deon_Vlok_BH	-31.481290	19.968414	1083	250

Temporal data was provided by DWS for the period of October 2017 – April 2018. The data indicates water level, yield and volume abstracted. **Table 2**

Table 2: Temporal data water level data was provided by DWS

Bh ID	Water level Oct 2017 (mbgl)	Sustainable Yield (m ³ /h)	Sustainable Yield (L/s)	Sust. Yield (m ³ /day)	Water level 10 Feb 2018 (mbgl)	Delivery on 10 Feb 2018 (m ³ /h)	Sustainable Yield (L/s)	on 10 Feb 2017 (m ³ /d)	Water level 23 Feb 2018 (mbgl)	Delivery on 23 Feb 2018 (m ³ /h)	Sustainable Yield (L/s)	on 23 Feb 2017 (m ³ /d)
Sandgat 3		5	1.5	129.60	12	5.14	1.43	123.36	12	4.4	1.2	105.6
Sandgat 4		3	0.8	69.12	30	2.9	0.81	69.6	30	4	1.1	96
Sandgat 5		11	3	259.20	40	3.15	0.88	75.6	40	3.4	0.9	81.6
Deon Vlok		58	16	1382.40	61.6	24	6.67	576	57.9	30	8.3	720
Witwal		36	10	864.00	54.9	6.8	1.89	163.2	57.5	5.7	1.6	136.8
Golfcourse BH		7	2	172.80	60	10.9	3.03	261.6	70.5	10.5	2.9	252

Water level 2 Mar 2018 (mbgl)	Delivery on 2 Mar 2018 (m ³ /h)	Sustainable Yield (L/s)	on 2 Mar 2017 (m ³ /d)	Water level 6 Apr 2018 (mbgl)	Delivery on 6 Apr 2018 (m ³ /h)	Sustainable Yield (L/s)	on 6 Apr 2017 (m ³ /day)	Water level 10 Apr 2018 (mbgl)	Delivery on 10 Apr 2018 (m ³ /h)	Sustainable Yield (L/s)	on 10 Apr 2017 (m ³ /d)
12	4	1.1	96	12	3.8	1.1	91.2		3.75	1.0	90
30	3.6	1.0	86.4	30	2.75	0.8	66		2.83	0.8	67.92
40	3.4	0.9	81.6	40	2.47	0.7	59.28		2.43	0.7	58.32
63	26	7.2	624	80.3	17	4.7	408		17.6	4.9	422.4
58.4	6.3	1.8	151.2	65.3	6.8	1.9	163.2		6.8	1.9	163.2
69	10	2.8	240	?	1.9	0.5	45.6		0	0.0	0

5. DESKTOP STUDY AND GROUNDWATER EXPLORATION

5.1 *Desktop study*

The desktop study was conducted using the following information in order to identify higher potential areas for groundwater exploration;

- National Ground water archive (NGA)
- 1: 50 000 and 1: 250 000 Geological Maps
- South African airborne magnetic data
- Lineament maps provided by the CGS
- Climatic data for the region.
- Previous reports (Private and government sector)

The desktop study was stipulated to target areas either owned by municipality or government initially and then private owned land. Previous reports/literature indicated that groundwater is generally located within alluvial channels, dolerite dykes or dolerite sills. The above-mentioned data was collated into a Geographical information system (GIS) software package. Five areas of interest were identified which met the criteria of geological structures, and sufficient recharge/rainfall. The Nature reserve located 1 km north of Calvinia was re assessed for groundwater potential and the re-drilling of existing abandoned/dilapidated boreholes.

A study area identified by SRK Consulting (Report No: 345429/4) 18 km to the north-east of Calvinia on a farm known as Rhenosterhoek was assessed for groundwater potential. The report identified the area as a potential area for groundwater exploration, however, GEOSS reassessed the area and data. Based on GEOSS assessment the area was classified as a low priority due to changes in climatic data and limited information pertaining to aquifer yield potential.

- Rhenosterhoek Farm (SRK study area)
- Ceres Karoo area / Kruitberg (Study area 1)
- Keiskie/ Keiskie road (Study area 2)
- Downes (study area 3)
- North-west region along the R355 (Study area 4)
- Nature reserve (Re-drilling of existing boreholes)
- De Vlok farm (Study area 5)

The 1:250 000 and 1:50 000 geological maps were also used where possible, to increase the level of geological detail used in understanding target areas. The geological maps used in conjunction with aerial imagery were used to conduct lineament and fault mapping was at site specific scales, to more closely define target areas. These target areas were then compared to the available groundwater information surrounding them, to obtain estimate outcomes and expectations of groundwater exploration in these sites.

5.2 *Exploration study*

Once the desktop study targets had been identified, field work was completed to finalise the exploration drill sites. The field work took the form of onsite structural verification (field geology), where the target structures were visible at surface. In areas where the target structures were covered by alluvium, geophysical techniques were used to further define the exploration drill sites.

The electromagnetic geophysical techniques were used, the method is a no intrusive and rapid for covering large areas. the geophysical survey was undertaken using a CMD-DUO Electromagnetic conductivity meter which measures the ground conductivity of the subsurface. It is a rapid data acquisition instrument that can be successfully applied to groundwater exploration. The CMD-DUO induces a changing electromagnetic (EM) field with a known frequency into the subsurface using a sender coil. This changing EM field induces current flow in conductive subsurface areas (for example fractured sandstone saturated with groundwater), which is measured by the receiver coil. This is then automatically converted to ground conductivity. In general, the ground conductivity measured has a direct correlation with formation porosity and groundwater salinity; i.e. if porosity of the formation or groundwater salinity increases, this will be reflected as a higher ground conductivity measurement (Telford et al, 1990).

The geophysical profiles are attached in **Appendix B** and spatial overlain on **Map 2 (1- 4)**.

Access to two of the study areas were limited by the private land owners. Rhenosterhoek Farm owner refused access to the land. The second target area Downes, GEOSS was allowed access to conduct geophysical and structure mapping work. However, the Land owner stipulated that he does not want drilling to take place on his land.

GEOSS took careful consideration when siting exploration boreholes on private land in order to not impact current groundwater use on the property or obstruct the works of the farm.

5.3 *Exploration Borehole sites*

Boreholes sites were selected based on the lineament mapping, geology mapping and geophysics. The exploration drill programme was broken into three phases, this was due to funding constraints during the initial phase of the project. The phases were broken down into the following criteria;

- **Phase 1:** Priority sites were selected with the highest groundwater potential.
- **Phase 2:** All sites delineated during the initial groundwater exploration phase.
- **Phase 3:** Additional sites added through exploration results **Phase 2**. Additional funding allowed for the expansion of the study site and additional explorations areas were identified.

Table 3 list the drill targets and their phase number.

Table 3: Exploration boreholes

Drill phase	Drill No.	Name	Latitude (WGS 84)	Longitude (WGS 84)
Phase 1	1	Cal_DV1	-31.455414	19.773937
Phase 1	2	Cal_DV2	-31.429912	19.785117
Phase 1	3	Cal_DV3	-31.430694	19.7883
Phase 1	4	Cal_DV4	-31.411629	19.775115
Phase 1	5	Cal-S2-1	-31.558677	19.821479
Phase 1	6	Cal-S2-3	-31.651334	19.801571
Phase 1	7	Cal-S2-3TV	-31.565842	19.828691
Phase 1	8	Cal-S1-1	-31.643388	19.883707
Phase 1	9	Cal-S1-2	-31.618573	19.893546
Phase 1	10	Cal-S1-3	-31.618808	19.893628
Phase 2	11	Cal-S2-4	-31.650359	19.801047
Phase 2	12	Cal-S2-2	-31.555085	19.818219
Phase 2	13	Cal-S2-3B	-31.650182	19.802443
Phase 2	14	Cal-S2-7	-31.650782	19.76698
Phase 2	15	Cal-S2-8	-31.649895	19.770142
Phase 2	16	Cal-S2-9	-31.65117	19.783061
Phase 2	17	Cal-S1-KB	-31.636869	19.758089
Phase 2	18	Cal-S1-KB-B	-31.643077	19.758324
Phase 2	19	Cal-S1-KB-B2	-31.642809	19.758577
Phase 2	20	Cal_S2_10	-31.617462	19.744726
Phase 2	21	Cal-S3-1	-31.598452	20.017608
Phase 2	22	Cal-S3-2	-31.384946	19.539153
Phase 2	23	Cal-S3-3	-31.593047	19.999782
Phase 2	24	Cal_Nat5	-31.435236	19.784485
Phase 2	25	Cal_Nat6	-31.451284	19.770548
Phase 3	26	Cal_Phase3_1	-31.417054	19.94251

Phase 3	27	Cal_Phase3_2	-31.393491	19.547516
Phase 3	28	Cal_Phase3_3	-31.398477	19.553632
Phase 3	29	Cal_Phase3_6	-31.357725	19.6915
Phase 3	30	Cal_Phase3_4	-31.401169	19.556679
Phase 3	31	Cal_Phase3_5	-31.396265	19.55079
Phase 3	32	Cal_Phase3_7	-31.375992	19.667129
Phase 3	33	Cal_Phase3_8	-31.630381	19.749189
Phase 3	34	Cal_Phase3_8_Alt	-31.63271	19.748168
Phase 3	35	Cal_Phase3_9	-31.632714	19.756781
Phase 3	36	Cal_Phase3_10	-31.625006	19.755166
Phase 3	37	Cal_Phase3_11	-31.619652	19.753778
Phase 3	38	Cal_phase3_12	-31.626433	19.776246
Phase 3	39	Cal_phase3_13	-31.641369	19.76428
Phase 3	40	Cal_Phase3_14	-31.59096	20.001357
Phase 3	41	Cal_Phase3_15	-31.565631	19.959059
Phase 3	42	Cal_vlok1	-31.382153	19.956044
Phase 3	43	Re-Drill 39602	-31.372864	19.970834
Phase 3	44	Cal_Vlok2	-31.401289	20.007778

6. DRILLING RESULTS

A total of 44 boreholes were sited for the exploration phase of the project (**Map 2 (1 – 4), Appendix A**). 31 boreholes were drilled by the company H&A drilling during the period of March to August 2018. Drill locations each represented its own challenges which ranged from access due to bad weather conditions and difficult drilling conditions. **Table 4** summarize the drill results. Boreholes for each location can be found in **Appendix D: Borehole logs**.

On average exploration boreholes were drilled to a depth of 150 m with the deepest borehole been drilled to a depth of 207 m. Dolerite dikes and deep-seated sills were the primary drill targets for exploration. Drilling was either stopped due to high water pressure decreasing drill bit penetration, unfavourable geology been intersected or target depth of 212 m was reached (the maximum of 212 m was due to limited drill strings been available).

A total of 13 successful borehole were drilled with a cumulative blow yield of 136 L/s. The newly boreholes were then yield tested to determine sustainability and the results are presented in **Section 8**.

Table 4: Drilling results summary

Drill Phase	Name	Latitude (DD)	Longitude (DD)	Borehole depth (m)	Fractures (mbgl)	Blow yield (L/s)	Borehole diameter 1 (casing) and Depth (m)	Borehole diameter 2 and Depth (m)
Phase 1	Cal_DV1	-31.455414	19.773937	160	144 and 155	25	#8.5" (0 - 165)	
Phase 1	Cal_DV2	-31.429912	19.785117	200		0.1	6.5" (0 -200)	
Phase 1	Cal_DV3	-31.430694	19.7883	205	189	2.7	6.5" (0 -202)	
Phase 1	Cal_DV4	-31.411629	19.775115	207	49; 82 and 85	3.1	6.5"(0 - 207)	
Phase 1	Cal-S2-3	-31.651334	19.801571	120	31	2.8	6.5" (0 - 120)	
Phase 1	Cal-S1-1	-31.643388	19.883707	180		0.1	6.5" (0 - 180)	
Phase 1	Cal-S1-2	-31.618573	19.893546	152		0.1	6.5" (0 -152)	
Phase 1	Cal-S1-3	-31.618808	19.893628	128		0.1	6.5" (0 -128)	
Phase 2	Cal-S2-4	-31.650359	19.801047	180	144 and 155	4.9	6.5" (0 -180)	
Phase 2	Cal-S2-3B	-31.650182	19.802443	120	28	0.2	6.5" (0 -120)	
Phase 2	Cal-S2-7	-31.650782	19.76698	153		0.1	6.5" (0 -153)	
Phase 2	Cal-S2-8	-31.649895	19.770142	200	-	1.3	6.5" (0 -200)	
Phase 2	Cal-S2-9	-31.65117	19.783061	180		0.3	6.5" (0 -180)	
Phase 2	Cal-S1-KB	-31.636869	19.758089	180	30	1.3	6.5" (0 -180)	
Phase 2	Cal-S1-KB-B	-31.643077	19.758324	120		0.3	6.5" (0 -120)	
Phase 2	Cal-S1-KB-B2	-31.642809	19.758577	83		0.1	6.5" (0 -83)	
Phase 2	Cal_S2_10	-31.617462	19.744726	152	79	8.2	#8" (0 - 111)	6.5" (111 - 151)
Phase 2	Cal_Nat5	-31.435236	19.784485	170	168	5	6.5" (0 - 170)	
Phase 2	Cal_Nat6	-31.451284	19.770548	200	19 and 80	3	6.5" (0 - 200)	
Phase 3	Cal_Phase3_3	-31.398477	19.553632		37 and 143	1.1	6.5" (0 - 150)	
Phase 3	Cal_Phase3_6	-31.357725	19.6915	112	92	>25	8" (0 - 112)	

Phase 3	Cal_Phase3_4A	-31.401169	19.556679	79	22, 43 and 71	> 10	8" (0 - 79)	
Phase 3	Cal_Phase3_5	-31.396265	19.55079	127			6.5" (0 - 127)	
Phase 3	Cal_Phase3_7	-31.375992	19.667129	137	70	0.1	6.5" (0 - 137)	
Phase 3	Cal_Phase3_8_Alt	-31.63271	19.748168	182		0.1	6.5" (0 - 182)	
Phase 3	Cal_Phase3_9	-31.632714	19.756781	117	36,39,62,68,72 and 96	>10	#8" (0 - 117)	
Phase 3	Cal_phase3_12	-31.626433	19.776246	180		0.1	6.5" (0 - 180)	
Phase 3	Cal_phase3_13	-31.641369	19.76428	192			6.5" (0 - 192)	
Phase 4	Cal_vlok_2	-31.401289	20.007778	152		0.1	6.5" (0 - 152)	
Phase 3	Cal_vlok_1	-31.382153	19.956044	200		0.1	6.5" (0 - 200)	
Phase 3	ReDrill 39602	-31.372864	19.970834	180	52	30	8" (0 - 60)	6.5" (60 - 180)

* Metres below ground level (approximate, from borehole logs)

borehole reamed to 8" to allow for large pumps to be installed

** figures in bold denotes main water strikes in terms of blow yield

7. PUMPING TESTS: EXISTING PRODUCTION BOREHOLE

Seven boreholes existing boreholes, six boreholes are currently been used for water supply and one borehole (Calvinia-Ceres Rd_BH) was identified during the hydrocensus phase of the project. Concerns were raised as to the groundwater levels which haven shown a decline during the drought. Revaluation of the current production boreholes were conducted in order to determine the sustainable yields of the boreholes during drought conditions for both present and future. (Map 2, Appendix A).

7.1 Ceres Road

The step test commenced on the September 2017. The rest water level (RWL) was measured at 14.01 mbgl in the borehole of 51.90 m depth. The pump was only installed to 49.10 m. The Step Test involved four steps of increasing abstraction rates and the water level was drawn down to 35 m below the RWL at the end of the 3rd step, conducted at a rate of 5.06 L/s.

Based on the borehole response to the Step Test, the CDT was conducted at an abstraction rate of the installed pump at 2 L/s. The test was conducted for 48 hours (2880 minutes). The water level was drawn down to a maximum of 17.94 m below the rest water level at the completion of the CDT.

The recovery of the water level was monitored for 40 minutes. The water level recovery was relatively fast and indicates that long pumping periods per day will be sustained. Based on the data analysis the sustainable yield of the borehole is recommended to be 2 L/s, pumping for 24 hours per day and allowing 4 hours for recovery with a pump installed at 50 m below ground level. **Figure 2** graphically indicates the CDT and recovery data.




Figure 2: Constant Discharge Test and Recovery of Ceres Road BH

7.2 Sandgat 3

The step test commenced on the 16 September 2017, with the RWL measured at 8.41 mbgl in the borehole and the pump was installed to 13.20 m. The Step Test involved four steps of increasing abstraction rates and the water level was drawn down to 1.25 m below the RWL at the end of the fourth step, conducted at a rate of 2.5 L/s.

Based on the borehole response to the Step Test, the CDT was conducted at an abstraction rate of 2.2 L/s. The test was conducted for 48 hours (2880 minutes) and the water level was drawn down to a maximum 2.77 m below the rest water level at the completion of the CDT.

The recovery of the water level was monitored for 1.5 hours (90 minutes) and is presented. The borehole's recovery is relatively quick and can be related to its unconfined nature. Based on the data analysis the sustainable yield of the borehole is recommended to be 1.2 L/s, pumping for 16 hours per day and allowing 8 hours for recovery with a pump installed at 160 m below ground level. The borehole can be pumped at 1.5 L/s for 24 hrs but monitoring of the borehole on a monthly basis will allow for refining of abstraction rate. **Figure 3** graphically indicates the CDT and recovery data.




Figure 3: Constant Discharge Test and Recovery of Sandgat3

7.3 Sandgat 4

The step test commenced on the 29 September 2017, with the RWL measured at 8.59 mbgl in the borehole and the pump was installed to 55.10 m. The Step Test involved four steps of increasing abstraction rates. The water level was drawn down to pump inlet after step 3 run at a rate of 2 L/s.

Based on the borehole response to the Step Test, the CDT was conducted at an abstraction rate of 0.85 L/s. The test was conducted for 48 hours (2880 minutes) and the water level was drawn down to a maximum 19.78 m below the rest water level at the completion of the CDT.

The recovery of the water level was monitored for 20 minutes. The borehole’s recovery is rapid, it may be linked to the unconfined nature of the borehole. The rapid recovery may indicate a highly transmissive zone around the borehole. Based on the data analysis the sustainable yield of the borehole is recommended to be 0.8 L/s, pumping for 24 hours per day and allowing 4 hours for recovery with a pump installed at 55 m below ground level. The sustainable yield of 0.8 L/s is classified as low. **Figure 4** graphically indicates the CDT and recovery data.




Figure 4: Constant Discharge Test and Recovery of Sandgat 4

7.4 Sandgat 5

The step test commenced on the 23 September 2017. The RWL was measured at 20.91 mbgl in the borehole of approximately 197 m depth. The Step Test involved four steps of increasing abstraction rates and the water level was drawn down to 25.74 m below the RWL at the end of the fourth step, conducted at a rate of 18 L/s, with the pump installed at 189.20 m.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 16 L/s. The test was conducted for 480 min and the water level was drawn down pump inlet. Due to the rapid drawdown a second CDT was conducted at 5 L/s for 48 hours, which resulted in 7.39 m of drawdown.

The recovery of the water level was monitored for 480 minutes. The borehole’s recovery is slow. Based on the data analysis the available drawdown of the borehole is limited to 30 m. The sustainable yield of the borehole is recommended to be 3 L/s, pumping for 24 hours per day with 8 hours for recovery, with a pump installed at 60 m below ground level. The sustainable yield of 3 L/s is classified as moderate. **Figure 5** graphically indicates the CDT and recovery data.




Figure 5: Constant Discharge Test and Recovery of Sandgat 5

7.5 De Vlok Bh

The step test commenced on the 26 September 2017. The RWL was measured at 22.6 mbgl in the borehole of approximately 250 m depth. The Step Test involved four steps of increasing abstraction rates and the water level was drawn down to 7.89 m below the RWL at the end of the fourth step, conducted at a rate of 18 L/s, with the pump installed at 150 m.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 16 L/s. The test was conducted for 72 hours (4320 minutes) and the water level was drawn down to 11.62 meters below rest water level.

The recovery of the water level was monitored for 480 minutes. Based on the data analysis the available drawdown is assumed to be 127 m. However, no detailed geological logs could be obtained for the hole to identify the main water strike and the pumping test did not indicate a critical drawdown. The sustainable yield of the borehole is recommended to be 16 L/s, pumping for 24 hours per day with 8 hours for recovery, with a pump installed at 150 m below ground level. Only monitoring will show if the recommended rate is correct. **Figure 6** graphically indicates the CDT and recovery data.




Figure 6: Constant Discharge Test and Recovery of De Vlok Bh

7.6 **Witvaal**

The step test commenced on the 29 September 2017. The RWL was measured at 22.90 mbgl in the borehole of approximately 193 m depth. The Step Test involved four steps of increasing abstraction rates and the water level was drawn down to 8.89 m below the RWL at the end of the fourth step, conducted at a rate of 12.25 L/s, with the pump installed at 91 m

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 10 L/s. The test was conducted for 48 hours (2880 minutes) and the water level was drawn down to 19.3 meters below rest water level.

The recovery of the water level was monitored for 480 minutes. Based on the data analysis the available drawdown is assumed to be 67.3 m. However, no detailed geological logs could be obtained for the hole to identify the main water strike and the pumping test did not indicate a critical drawdown. The sustainable yield of the borehole is recommended to be 6 L/s, pumping for 24 hours per day with 8 hours for recovery, with a pump installed at 150 m below ground level. Only monitoring will show if the recommended rate is correct. **Figure 7** graphically indicates the CDT and recovery data.




Figure 7: Constant Discharge Test and Recovery of Witvaal.

7.7 **Golf course Bh**

The step test commenced on the 26 September 2017. The RWL was measured at 36 mbgl in the borehole of approximately 225 m depth. The Step Test involved three steps of increasing abstraction rates and the water level was drawn down to 33.07 m below the RWL at the end of the third step, conducted at a rate of 12. L/s, with the pump installed at 100 m (Current depth of equipped pump).

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 3 L/s due to slow recovery results over a 24-hr period, the new RWL from the CDT was 48 mbgl. The test was conducted for 48 hours (2880 minutes) and the water level was drawn down to 30.67 meters below rest water level.

The recovery of the water level was monitored for 1140 minutes. Based on the data analysis the available drawdown is assumed to be 64 m. However, no detailed geological logs could be obtained for the hole to identify the main water strike and the pumping test did not indicate a critical drawdown. The sustainable yield of the borehole is recommended to be 2.5 L/s, pumping for 24 hours per day, with a pump installed at 150 m below ground level. Only monitoring will show if the recommended rate is correct. **Figure 8** graphically indicates the CDT and recovery data.




Figure 8: Constant Discharge Test and Recovery of Golf course

7.8 *Summary of results**Table 5: Summary of existing boreholes yield test*


BH ID	Rest water level (mbgl)	Test pump depth (mbgl)	CDT (L/s)	CDT duration (hr)	Available drawdown (m)	Max water level reached after CDT (mbgl)	Sustainable yield (L/s)
Calvinia-Ceres Rd_BH	14.01	49	2	48	35	31	2.0
Golf_course_BH	36.39	100	3	48	51	67.06	2.5
Witwal_BH	22.9	91	10	48	67.3	42.2	6.0
Sandgat_3_BH	8.41	13.20	2.2	48	5	11.4	1.2
Sandgat_4_BH	8.59	55.1	0.85	48	33	28.37	0.8
Sandgat_5_BH	20.91	189.20	5	48	30	28.31	3.0
Breccia_BH	Not tested						
Deon_Vlok_BH	22.6	150	16	72	127m (?)	34.22	16.0

8. PUMPING TEST: EXPLORATION BOREHOLES (2018)


8.1 *Cal_Nat1 (Cal_DV1)*

Exploration borehole Cal_DV1 had a blow yield of around 27 L/s and was drilled to a depth of 151 m. The step test commenced on the 9 May 2018. The rest water level was 49.5 mbgl with pump installation depth at 124 mbgl. Five 100-minute steps were conducted on the borehole, the fifth step was run at 25 L/s with the water level drawing down to 55.51 m.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 22 L/s. The test was stopped prematurely as the rate proved to be too high and the water level reached pump inlet after 8 hr (480 min). The borehole was allowed to recover for 16 hrs, however, the borehole only recovered 60%. The second CDT was run at a rate of 15 L/s. Again, the rate proved too high and reached pump inlet after 8 hrs. The borehole was allowed to recover for 36 hrs. the borehole however only recovered by 45% of the original rest water level. **Figure 9 A-B** graphically indicates both the CDT and recovery data.



(A)



(B)

Figure 9: Constant Discharge Test and Recovery of Cal_DV1. (A) 22 L/s CDT and recovery. (B) 15 L/s CDT and Recovery.

8.2 Cal_Nat2 (Cal_DV3)

The testing of exploration borehole Cal_DV3 commenced on the 16 May 2018. The borehole had a blow yield of around 2.7 L/s and was drilled to a depth of 205 m. The rest water level was 41 mbgl with pump installation depth at 147 mbgl. An intended four 100-minute steps were conducted on the borehole, on the third step the water level was drawdown down to pump inlet at a rate of 3 L/s.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 0.8 L/s. this included a drawdown of 45 m after 24 hours. The borehole recovered within 3.5 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 76 m. The sustainable yield of the borehole is recommended to be 1 L/s, pumping for 24 hours per day, with a pump installed at 150 m below ground level. monitoring will show if the recommended rate is sustainable for long term use. **Figure 10** graphically indicates the CDT and recovery data.




Figure 10: Constant Discharge Test (0.8 L/s) and Recovery of Cal_DV3

8.3 Cal_Nat3 (Cal_DV4)

The testing of exploration borehole Cal_DV4 commenced on the 20 May 2018. The borehole had a blow yield of around 2.7 L/s and was drilled to a depth of 205 m. The rest water level was 12.11 mbgl with pump installation depth at 99 mbgl. Four 100-minute steps were conducted on the borehole, the fourth step was run at 4.5 L/s with the water level drawing down to pump inlet 88 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 2.8 L/s. this included a drawdown of 54 m after 24 hours. The borehole recovered to 83 % after 10 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 80 m. The sustainable yield of the borehole is recommended to be 1.5 L/s, pumping for 24 hours per day, with a pump installed at 100 m below ground level. monitoring will show if the recommended rate is sustainable for long term use. **Figure 11** graphically indicates the CDT and recovery data.




Figure 11: Constant Discharge Test (2.8 L/s) and Recovery of Cal_DV4

8.4 Cal_KB1 (Cal_S2_3)

The testing of exploration borehole Cal_S2_3 commenced on the 25 May 2018. The borehole had a blow yield of around 2.75 L/s and was drilled to a depth of 120 m. The rest water level was 6.92 mbgl with pump installation depth at 39.15 mbgl. Four 100-minute steps were conducted on the borehole, the fourth step attempted at rate at 4.5 L/s with the water level drawing down to pump inlet 39 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 2.8 L/s. this included a drawdown of 23.97 m after 24 hours. The borehole recovered to 83 % after 10 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 25 m. The sustainable yield of the borehole is recommended to be 1.3 L/s, pumping for 24 hours per day, with a pump installed at 40 m below ground level. Exploration borehole Cal_S2_4 was monitored during the pumping test, the borehole showed a decrease in water level during the test. Therefore, it can be concluded that the boreholes are linked. **Figure 12** graphically indicates the CDT and recovery data.




Figure 12: Constant Discharge Test (2.8 L/s) and Recovery of Cal_s2-3

8.5 Cal_S2_4

The testing of exploration borehole Cal_S2_4 commenced on the 25 May 2018. The borehole had a blow yield of around 4.9 L/s and was drilled to a depth of 180 m. The rest water level was 6.29 mbgl, it must be noted that the borehole was artesian after drilling and the reported rest water level is due pumping test done on Cal_S2_3 and slow recovery. The pump installation depth at 154 mbgl. Four 100-minute steps were conducted on the borehole, the fourth step rate was run at 6.8 L/s with the water level drawing down to 72.55 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 4 L/s. this included a drawdown of 34.8 m after 24 hours. The borehole recovered to 85 % after 10 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 130 m. The sustainable yield of the borehole is recommended to be 4 L/s, pumping for 24 hours per day, with a pump installed at 150 m below ground level. Exploration borehole Cal_S2_3 was monitored during the pumping test, the borehole showed a substantial decrease in water level during the test. Based on the pumping test data, borehole Cale_S2_3 cannot be pumped at the same time as Cal_S2_4 as cone of depression caused will dewater the main Fracture at Cal_S2_3, this will make it un-useable. **Figure 13** graphically indicates the CDT and recovery data.




Figure 13: Constant Discharge Test (4 L/s) and Recovery of Cal-S2-4

8.6 Cal_S2_10

The testing of exploration borehole Cal_S2_10 commenced on the 28 June 2018. The borehole had a blow yield of around 8.8 L/s and was drilled to a depth of 151 m. The rest water level was 19.5 mbgl. The pump installation depth at 154 mbgl. Three 60-minute steps were conducted on the borehole, the duration of steps changes due time constraints. The fourth step rate was run at 19 L/s for a duration of 120-minutes during which the water level drawing down to 11.28 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 20 L/s (Max pump rate). This included a drawdown of 18.95 m after 48 hours. The borehole recovered was rapid with a 90 % after 16 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 60 m. The sustainable yield of the borehole is recommended to be 15 L/s, pumping for 24 hours per day, with a pump installed at 80 m below ground level. Monitoring will show if the recommended rate is sustainable for long term use. **Figure 14** graphically indicates the CDT and recovery data.




Figure 14: Constant Discharge Test (20 L/s) and Recovery of Cal-S2-10

8.7 *Cal_Nat 5*

The testing of exploration borehole Cal_Na5 commenced on the 5 July 2018. The borehole had a blow yield of around 5 L/s and was drilled to a depth of 200 m. The rest water level was 30 mbgl. The pump installation depth at 154 mbgl. Five 60-minute steps were conducted on the borehole. The fifth step rate was run at >5 L/s for a duration of 3-minutes during which the water level was drawn to pump inlet.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 5 L/s. This included a drawdown of 82.12 m after 24 hours. The borehole recovered was rapid with a 90 % after 0.5 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 107 m. The sustainable yield of the borehole is recommended to be 4.3 L/s, pumping for 24 hours per day, with a pump installed at 150 m below ground level. Monitoring will show if the recommended rate is sustainable for long term use. **Figure 15** graphically indicates the CDT and recovery data.




Figure 15: Constant Discharge Test (5 L/s) and Recovery of Cal_Nat 5

8.8 *Cal_Nat6*

The testing of exploration borehole Cal_Na6 commenced on the 10 July 2018. The borehole had a blow yield of around 3 L/s and was drilled to a depth of 200 m. The rest water level was 11.75 mbgl. The pump installation depth at 100 mbgl. Four 60-minute steps were conducted on the borehole. The fourth step rate was run at >5 L/s for a duration of 10-minutes during which the water level was drawn to pump inlet.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 3.5 L/s. This included a drawdown of 8 .01 m after 24 hours. The CDT rate was then increased to 4.3 L/s, the water level was drawdown to pump inlet after 3 minutes. The borehole recovered was rapid with a 90 % after 0.5 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 11 m. The sustainable yield of the borehole is recommended to be 1.2 L/s, pumping for 24 hours per day, with a pump installed at 25 m below ground level. Monitoring will show if the recommended rate is sustainable for long term use. **Figure 16** graphically indicates the CDT and recovery data.




Figure 16: Constant Discharge Test (3.5 & 4.3 L/s) and Recovery of Cal_Nat 6

8.9 Cal_Phase3_6

The testing of exploration borehole Cal_Phase3_6 commenced on the 28 August 2018. The borehole had a blow yield of around 25 - 30 L/s and was drilled to a depth of 111 m. The rest water level was 0.6 mbgl. The pump installation depth at 96 mbgl. Four 100-minute steps were conducted on the borehole. The fourth step rate was run at 25 L/s during which the water level drawing down to 70 mbgl.

Based on the borehole response to the Step Test and monitored recovery data, which in this case was extremely slow. After the step test the borehole recovery was monitored for 24-hrs in which the borehole only recovered to 55 %. A CDT was conducted at an abstraction rate of 12 L/s. This included a drawdown of 43.21 m after 36 hours. The borehole recovered was monitored for 24-hrs with 13 % recovery after cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 95 m. The sustainable yield of the borehole is recommended to be 2.5 L/s, pumping for 24 hours per day, with a pump installed at 96 m below ground level. Monitoring will show if the recommended rate is sustainable for long term use. **Figure 17** graphically indicates the CDT and recovery data.




Figure 17: Constant Discharge Test (12 L/s) and Recovery of Cal_phase3_6

8.10 *Cal_Phase3_4A*

The testing of exploration borehole Cal_Phase3_4A commenced on the 21 August 2018. The borehole had a blow yield of around > 30 L/s and was drilled to a depth of 77 m, drilling stopped due to high water pressure. The rest water level was 20.16 mbgl. The pump installation depth at 70 mbgl (as recommended by the driller). Four 100-minute steps were conducted on the borehole. The fourth step rate was run at 30 L/s during which the water level drawing down to 3.6 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 28 L/s (Pump maximum). This included a drawdown of 7.08 m after 48 hours. The borehole recovery was moderate with a 70 % after 24-hrs of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 55 m. The sustainable yield of the borehole is recommended to be 15 L/s, pumping for 24 hours per day, with a pump installed at 70 m below ground level. It is recommended that a pump be installed that is able to abstracting 25 L/s. Yield analysis data, indicated 25 L/s to be the maximum yield range, however, this will require long term monitoring to determine sustainability.

Figure 18 graphically indicates the CDT and recovery data.




Figure 18: Constant Discharge Test (28 L/s) and Recovery of Cal_Phase3_4A

8.11 Cal_Phase3_9

The testing of exploration borehole Cal_Phase3_9 commenced on the 31 August 2018. The borehole had a blow yield of around >25 L/s and was drilled to a depth of 117 m. The rest water level was 22.62 mbgl. The pump installation depth at 96 mbgl. Four 100-minute steps were conducted on the borehole. The fourth step rate was run at 30 L/s during which the water level drawdown was 7.70 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 28 L/s. This included a drawdown of 14.78 m after 48 hours. The borehole recovery was moderate with a 54 % after 24 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 75 m. The sustainable yield of the borehole is recommended to be 15 L/s, pumping for 24 hours per day, with a pump installed at 96 m below ground level. Monitoring will show if the recommended rate is sustainable for long term use. **Figure 19** graphically indicates the CDT and recovery data.




Figure 19: Constant Discharge Test (28 L/s) and Recovery of Cal_Phase3_9

8.12 **Re-Drill 39602**

The testing of exploration borehole Re-Drill 39602 commenced on the 16 August 2018. The borehole had a blow yield of around 25 L/s and was drilled to a depth of 151 m. The rest water level was 8.79 mbgl. The pump installation depth at 79.25 mbgl. Four 60-minute steps were conducted on the borehole. The fourth step rate was run at >11 L/s during which the water level drawing down to 62.17 mbgl.

Based on the borehole response to the Step Test, a CDT was conducted at an abstraction rate of 7 L/s. This included a drawdown of 28.22 m after 48 hours. The borehole recovery was rapid with a 95 % after 2.5 hours of the cessation of pumping.

Based on the data analysis the available drawdown is assumed to be 50 m. The sustainable yield of the borehole is recommended to be 4.5 L/s, pumping for 24 hours per day, with a pump installed at 80 m below ground level. Monitoring will show if the recommended rate is sustainable for long term use. **Figure 20** graphically indicates the CDT and recovery data.




Figure 20: Constant Discharge Test (7 L/s) and Recovery of Re_drill39602

8.13 *summary of results*

Table 6: Summary of exploration boreholes yield test

Borehole Name	Latitude (DD)	Longitude (DD)	Rest water level (mbgl)	Test pump depth (mbgl)	CDT (L/s)	CDT duration (hr)	Available drawdown (m)	Max water level reached after CDT (mbgl)	Sustainable yield (L/s)
Cal_DV1	-31.455414	19.773937	49.5	150	15	2 x 8	74.5	Pump inlet	5
Cal_DV3	-31.430694	19.788300	41	150	0.8	24	76	45	0.8
Cal_DV4	-31.411629	19.775115	12.11	100	2.8	24	80	45	1
Cal-S2-3	-31.651334	19.801571	6.92	35	2.8	24	25	23.97	1.3
Cal-S2-4	-31.650359	19.801047	6.29	150	4	24	130	34.8	4
Cal_S2_10	-31.617462	19.744726	19.5	80	20	48	60	18.95	15
Cal_Nat5	-31.435236	19.784485	30	178	5	24	107	82.12	4.3
Cal_Nat6	-31.451284	19.770548	11.75	100	3.5	24	11	8	1.5
Cal_Phase3_6	-31.357725	19.691500	0.6	96	12	36	95	43.21	2
Cal_Phase3_4A	-31.401169	19.556679	20	70	28	48	55	7.08	15
Cal_Phase3_9	-31.632714	19.756781	22.62	96	28	48	74	14.78	15
Re-Drill 39602	-31.372864	19.970834	8.79	79	7	48	50	28.22	4.5

9. CHEMISTRY

Groundwater samples were collected at the end of all the yield test for each borehole. The samples were submitted for inorganic chemical analysis to a SANAS accredited laboratory. Existing production boreholes samples were sent to Bemlab in the Western Cape. Exploration borehole samples were sent to A.L Abbot & Associates in the Western Cape, the change in lab was due to different phases and budget. The certificate of analysis of the samples is presented in **Appendix C**. The chemistry results obtained have been classified according to the SANS241-1: 2015 standards for domestic water. **Table 7** enables an evaluation of the water quality with regards to the various limits. **Table 8** and **Table 9** presents the water chemistry analysis results, colour coded according to the SANS241-1: 2015 drinking water assessment standards.

Table 7: Classification table for specific limits

Acute Health
Aesthetic
Chronic health
Operational
Acceptable

9.1 *Groundwater quality analysis for existing production boreholes*

The chemistry results obtained have been classified according to the SANS241-1: 2015 standards for domestic water. The groundwater chemistry analysis results, colour coded according to the SANS241-1: 2015 drinking water assessment standards are listed in the **Table 8**.

Table 8: Water chemistry of existing production boreholes

Analyses	Ceres_RD	Sandgat_4	Golf_course	Witwal_BH	Sandgat_3	Deon_Vlok	Sandgat_5	SANS 241-1:2015
pH (at 25 °C)	7.6	7.4	7.4	8.4	7.5	7.5	7.0	≥5 - ≤9.7 Operational
Conductivity (mS/m) (at 25 °C)	59.2	598.6	214.0	93.0	605.0	150.0	279.0	≤170 Aesthetic
Total Dissolved Solids (mg/l)	379.0	3831.0	1283.0	561.0	3600.0	901.0	1670.0	≤1200 Aesthetic
Turbidity (NTU)	0.6	0.3	1.4	0.4	0.2	1.4	0.4	≤5 Aesthetic ≤1 Operational
Colour (mg/l as Pt)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤15 Aesthetic
Sodium (mg/l as Na)	38.7	706.9	190.3	175.6	929.4	128.3	305.7	≤200 Aesthetic
Potassium (mg/l as K)	1.4	1.0	5.1	7.4	1.8	3.1	4.6	N/A
Magnesium (mg/l as Mg)	12.5	118.8	60.4	0.4	139.1	55.3	70.8	N/A
Calcium (mg/l as Ca)	52.5	227.6	127.7	0.0	131.8	92.1	116.1	N/A
Chloride (mg/l as Cl)	51.0	1420.0	542.8	157.3	1564.2	225.3	761.9	≤300 Aesthetic
Sulphate (mg/l as SO4)	26.0	664.0	112.0	94.0	769.0	177.0	194.0	≤250 Aesthetic ≤500 Acute Health
Nitrate Nitrogen (mg/l as N)	0.0	0.0	0.0	0.1	0.0	0.0	0.0	≤11 Acute Health
Nitrite Nitrogen (mg/l as N)	0.4	0.8	0.0	0.0	0.6	0.0	0.6	≤0.9 Acute Health
Ammonia Nitrogen (mg/l as N)	0.3	0.4	0.3	0.6	0.3	0.0	0.3	≤1.5 Aesthetic
Total Alkalinity (mg/l as CaCO3)	284.0	511.0	167.9	181.4	388.0	278.6	132.5	N/A
Fluoride (mg/l as F)	0.5	0.2	0.2	1.4	0.0	0.8	0.0	≤1.5 Chronic Health
Aluminium (mg/l as Al)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.3 Operational
Vanadium (mg/l as V)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	N/A
Total Chromium (mg/l as Cr)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.05 Chronic Health
Manganese (mg/l as Mn)	0.0	0.0	0.0	0.0	0.0	0.0	0.4	≤0.1 Aesthetic ≤0.4 Chronic Health
Iron (mg/l as Fe)	0.1	0.1	0.2	0.2	0.2	0.2	0.1	≤0.3 Aesthetic ≤2 Chronic Health
Cobalt (mg/l as Co)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	N/A
Nickel (mg/l as Ni)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.07 Chronic Health
Copper (mg/l as Cu)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤2 Chronic Health
Zinc (mg/l as Zn)	0.0	0.0	0.0	0.0	0.0	0.0	0.2	≤5 Aesthetic
Arsenic (mg/l as As)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.01 Chronic Health
Selenium (mg/l as Se)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.04 Chronic Health
Cadmium (mg/l as Cd)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.003 Chronic Health
Antimony (mg/l as Sb)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.02 Chronic Health
Mercury (mg/l as Hg)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.006 Chronic Health
Lead (mg/l as Pb)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.01 Chronic Health
Uranium (mg/l as U)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.03 Chronic Health
Cyanide (mg/l as CN-)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	≤0.2 Acute Health

9.2 *Groundwater quality analysis on newly drilled exploration boreholes 2018*

The chemistry results obtained have been classified according to the DWAF (1998) standards for domestic water. **Table 9** enables an evaluation of the water quality with regards to the various parameters measured (DWAF, 1998). **Table 10** presents the water chemistry analysis results colour coded according to the DWAF drinking water assessment standards.

Table 9: 2018 exploration borehole results classified according the SANS241-1:2015

Analyses	DV1	DV3	DV4	Cal-NAT5	Cal-NAT6	CalS2-3	SANS 241-1:2015
pH (at 25 °C)	8.4	9.6	8.3	8.2	7.4	9.2	≥5 - ≤9.7 Operational
Conductivity (mS/m) (at 25 °C)	54.5	49.5	73.5	45.0	60.5	70.5	≤170 Aesthetic
Total Dissolved Solids (mg/l)	361.0	327.0	495.0	265.0	381.0	474.0	≤1200 Aesthetic
Turbidity (NTU)	2.1	2.0	10.3	0.4	0.13	8.8	≤5 Aesthetic ≤1 Operational
Colour (mg/l as Pt)	<4	<4	<4	<4	<4	<4	≤15 Aesthetic
Sodium (mg/l as Na)	86.0	76.1	116.0	70.8	53.5	125.0	≤200 Aesthetic
Potassium (mg/l as K)	0.7	0.5	1.4	0.7	0.7	1.2	N/A
Magnesium (mg/l as Mg)	<1.1	<1.1	6.4	1.7	18.9	<1.1	N/A
Calcium (mg/l as Ca)	5.0	3.4	16.2	6.7	41.6	2.8	N/A
Chloride (mg/l as Cl)	66.4	89.9	60.7	41.7	36.6	58.1	≤300 Aesthetic
Sulphate (mg/l as SO4)	19.0	4.3	7.9	6.6	27.2	10.0	≤250 Aesthetic ≤500 Acute Health
Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	<0.2	0.2	<0.20	<0.2	0.3	≤12 Acute Health
Combined Nitrate plus Nitrite (mg/l as N)	0.22	0.22	0.23	0.22	0.22	0.23	≤1.0
Nitrate Nitrogen (mg/l as N)	<0.2	<0.2	<0.2	<0.20	<0.2	<0.2	≤11 Acute Health
Nitrite Nitrogen (mg/l as N)	<0.2	<0.2	<0.2	<0.20	<0.2	<0.2	≤0.9 Acute Health
Ammonia Nitrogen (mg/l as N)	0.20	0.28	0.23	<0.10	<0.1	0.47	≤1.5 Aesthetic
Total Alkalinity (mg/l as CaCO3)	105.0	36.3	285.0	124.0	222.0	254.0	N/A
Fluoride (mg/l as F)	3.3	6.8	3.1	5.1	1.3	3.6	≤1.5 Chronic Health
Aluminium (mg/l as Al)	0.108	0.092	0.187	0.039	<0.012	0.323	≤0.3 Operational
Total Chromium (mg/l as Cr)	<0.007	<0.007	0.014	<0.007	<0.007	0.0	≤0.05 Chronic Health
Manganese (mg/l as Mn)	<0.019	<0.019	0.037	<0.019	0.1	<0.019	≤0.1 Aesthetic ≤0.4 Chronic Health
Iron (mg/l as Fe)	0.080	0.083	0.175	<0.024	<0.024	0.294	≤0.3 Aesthetic ≤2 Chronic Health
Nickel (mg/l as Ni)	0.006	0.005	0.004	0.004	0.004	0.004	≤0.07 Chronic Health
Copper (mg/l as Cu)	0.016	0.014	0.015	<0.006	<0.006	0.015	≤2 Chronic Health
Zinc (mg/l as Zn)	0.020	0.007	0.010	0.003	0.003	0.006	≤5 Aesthetic
Arsenic (mg/l as As)	0.167	<0.003	<0.003	<0.003	<0.003	<0.003	≤0.01 Chronic Health
Selenium (mg/l as Se)	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	≤0.04 Chronic Health
Cadmium (mg/l as Cd)	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	≤0.003 Chronic Health
Antimony (mg/l as Sb)	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	≤0.02 Chronic Health
Mercury (mg/l as Hg)	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	≤0.006 Chronic Health
Lead (mg/l as Pb)	<0.007	<0.007	<0.007	<0.007	<0.007	<0.007	≤0.01 Chronic Health
Uranium (mg/l as U)	<0.015	<0.015	<0.015	<0.015	<0.015	<0.015	≤0.03 Chronic Health
Cyanide (mg/l as CN ⁻)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	≤0.2 Acute Health
Total Organic Carbon (mg/l as C)	13.2	2.1	1.0	0.82	0.58	0.98	N/A

Analyses	CalS2-4	CalS2-10	Cal-Ph3-4	Cal-Ph-3-6	Cal-Ph-3-9	Cal-39602-redrill	SANS 241-1:2015
pH (at 25 °C)	9.8	7.4	7.5	9.5	8.6	8.1	≥5 - ≤9.7 Operational
Conductivity (mS/m) (at 25 °C)	74.0	127.0	173.0	48.5	75.5	175.0	≤170 Aesthetic
Total Dissolved Solids (mg/l)	488.0	823.0	1354.0	377.0	553.0	1381.0	≤1200 Aesthetic
Turbidity (NTU)	7.20	0.4	82.0	0.6	0.2	0.5	≤5 Aesthetic ≤1 Operational
Colour (mg/l as Pt)	6.0	<4	<4	5.0	<4	5.0	≤15 Aesthetic
Sodium (mg/l as Na)	127.0	108.0	95.7	77.1	77.9	160.0	≤200 Aesthetic
Potassium (mg/l as K)	1.0	2.9	6.2	0.6	2.8	2.3	N/A
Magnesium (mg/l as Mg)	<1.1	28.0	92.7	<1.1	20.1	58.3	N/A
Calcium (mg/l as Ca)	0.4	97.0	130.0	5.7	31.8	80.2	N/A
Chloride (mg/l as Cl)	66.0	188.0	96.9	96.2	98.1	307.0	≤300 Aesthetic
Sulphate (mg/l as SO ₄)	5.5	100.0	616.0	4.4	18.0	118.0	≤250 Aesthetic ≤500 Acute Health
Nitrate & Nitrite Nitrogen (mg/l as N)	0.2	<0.2	<0.2	<0.20	<0.20	2.1	≤12 Acute Health
Combined Nitrate plus Nitrite (mg/l as N)	0.22	0.22	0.22	0.22	0.22	0.39	≤1.0
Nitrate Nitrogen (mg/l as N)	<0.2	<0.2	<0.2	<0.2	<0.2	1.9	≤11 Acute Health
Nitrite Nitrogen (mg/l as N)	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	≤0.9 Acute Health
Ammonia Nitrogen (mg/l as N)	0.31	<0.1	<0.1	<0.1	<0.1	<0.1	≤1.5 Aesthetic
Total Alkalinity (mg/l as CaCO ₃)	238.0	247.0	96.4	41.3	201.0	281.0	N/A
Fluoride (mg/l as F)	7.2	1.6	1.5	3.4	1.8	0.9	≤1.5 Chronic Health
Aluminium (mg/l as Al)	0.238	<0.012	<0.012	0.020	0.141	<0.012	≤0.3 Operational
Total Chromium (mg/l as Cr)	0.011	<0.007	<0.007	<0.007	<0.007	<0.007	≤0.05 Chronic Health
Manganese (mg/l as Mn)	<0.019	<0.019	1.0	<0.019	<0.019	<0.019	≤0.1 Aesthetic ≤0.4 Chronic Health
Iron (mg/l as Fe)	0.296	<0.024	22.4	0.027	0.053	<0.024	≤0.3 Aesthetic ≤2 Chronic Health
Nickel (mg/l as Ni)	0.004	0.005	0.010	<0.001	<0.001	<0.001	≤0.07 Chronic Health
Copper (mg/l as Cu)	0.016	<0.006	<0.006	<0.006	<0.006	<0.006	≤2 Chronic Health
Zinc (mg/l as Zn)	0.006	0.003	0.004	<0.001	0.006	0.003	≤5 Aesthetic
Arsenic (mg/l as As)	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	≤0.01 Chronic Health
Selenium (mg/l as Se)	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	≤0.04 Chronic Health
Cadmium (mg/l as Cd)	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	≤0.003 Chronic Health
Antimony (mg/l as Sb)	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	≤0.02 Chronic Health
Mercury (mg/l as Hg)	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	≤0.006 Chronic Health
Lead (mg/l as Pb)	<0.007	<0.007	<0.007	<0.007	<0.007	<0.007	<0.01 Chronic Health
Uranium (mg/l as U)	<0.015	<0.015	<0.015	<0.015	<0.015	<0.015	≤0.03 Chronic Health
Cyanide (mg/l as CN ⁻)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	≤0.2 Acute Health
Total Organic Carbon (mg/l as C)	0.79	0.52	<0.10	<0.01	<0.01	40.0	N/A

Table 10: Classification table for the groundwater results (DWAf, 1998)

Blue	(Class 0)	Ideal water quality - suitable for lifetime use.
Green	(Class I)	Good water quality - suitable for use, rare instances of negative effects.
Yellow	(Class II)	Marginal water quality - conditionally acceptable. Negative effects may occur.
Red	(Class III)	Poor water quality - unsuitable for use without treatment. Chronic effects may occur.
Purple	(Class IV)	Dangerous water quality - totally unsuitable for use. Acute effects may occur.

Table 11: Classified existing production borehole results

Sample Marked :	Ceres_RD	Sandgat_4	Golf_course	Witwal_BH	Sandgat_3	Deon_Vlok	Sandgat_5	DWA (1998) Drinking Water Assessment Guide				
								Class 0	Class I	Class II	Class III	Class IV
pH	7.6	7.4	7.4	8.4	7.5	7.5	7	5-9.5	4.5-5 & 9.5-10	4-4.5 & 10-10.5	3-4 & 10.5-11	< 3 & >11
Conductivity (mS/m)	59.2	598.6	214	93	605	150	279	<70	70-150	150-370	370-520	>520
Turbidity (NTU)	0.6	0.34	1.36	0.38	0.23	1.41	0.36	<0.1	0.1-1	1.0-20	20-50	>50
	mg/L											
Total Dissolved Solids	379	3831	1283	561	3600	901	1670	<450	450-1000	1000-2400	2400-3400	>3400
Sodium (as Na)	38.7	706.9	190.3	175.6	929.4	128.3	305.7	<100	100-200	200-400	400-1000	>1000
Potassium (as K)	1.4	1	5.1	7.4	1.8	3.1	4.6	<25	25-50	50-100	100-500	>500
Magnesium (as Mg)	12.5	118.8	60.4	0.4	139.1	55.3	70.8	<70	70-100	100-200	200-400	>400
Calcium (as Ca)	52.5	227.6	127.7	0	131.8	92.1	116.1	<80	80-150	150-300	>300	
Chloride (as Cl)	51	1420	542.8	157.3	1564.2	225.3	761.9	<100	100-200	200-600	600-1200	>1200
Sulphate (as SO4)	26	664	112	94	769	177	194	<200	200-400	400-600	600-1000	>1000
Nitrate & Nitrite (as N)	0	0	0	0	0	0	0	<6	6.0-10	10.0-20	20-40	>40
Fluoride (as F)	0.5	0.2	0.2	1.4	0	0.8	0	<0.7	0.7-1.0	1.0-1.5	1.5-3.5	>3.5
Manganese (as Mn)	0.03	0	0	0	0	0	0.38	<0.1	0.1-0.4	0.4-4	4.0-10.0	>10
Iron (as Fe)	0.1	0.1	0.2	0.2	0.2	0.2	0.1	<0.5	0.5-1.0	1.0-5.0	5.0-10.0	>10
Copper (as Cu)	0	0	0	0	0	0	0	<1	1-1.3	1.3-2	2.0-15	>15
Zinc (as Zn)	0	0	0	0	0	0	0.15	<20	>20			
Arsenic (as As)	0.007	0.005	0	0	0.0084	0	0.0072	<0.010	0.01-0.05	0.05-0.2	0.2-2.0	>2.0
Cadmium (as Cd)	0	0	0	0	0	0	0	<0.003	0.003-0.005	0.005-0.020	0.020-0.050	>0.050
Hardness (as CaCO3)	0	0	0	0	0	0	0	<200	200-300	300-600	>600	

Table 12: Classified exploration borehole results

Sample Marked :	Cal_DV1	Cal_DV3	Cal_DV4	Cal-NAT5	Cal-NAT6	CalS2-3	CalS2-4	CalS2-10	Cal-Ph3-4	Cal-Ph-3-6	Cal-Ph-3-9	Cal-39602-redrill	DWA (1998) Drinking Water Assessment Guide				
													Class 0	Class I	Class II	Class III	Class IV
pH	8.39	9.59	8.32	8.18	7.36	9.22	9.83	7.39	7.45	9.45	8.55	8.09	5-9.5	4.5-5 & 9.5-10	4-4.5 & 10-10.5	3-4 & 10.5-11	< 3 & >11
Conductivity (mS/m)	54.5	49.5	73.5	45	60.5	70.5	74	127	173	48.5	75.5	175	<70	70-150	150-370	370-520	>520
Turbidity (NTU)	2.1	2	10.3	0.37	0.13	8.8	7.2	0.37	82	0.6	0.18	0.52	<0.1	0.1-1	1.0-20	20-50	>50
	mg/L																
Total Dissolved Solids	361	327	495	265	381	474	488	823	1354	377	553	1381	<450	450-1000	1000-2400	2400-3400	>3400
Sodium (as Na)	86	76.1	116	70.8	53.5	125	127	108	95.7	77.1	77.9	160	<100	100-200	200-400	400-1000	>1000
Potassium (as K)	0.73	0.52	1.4	0.68	0.67	1.2	1	2.9	6.2	0.63	2.8	2.3	<25	25-50	50-100	100-500	>500
Magnesium (as Mg)	<1.1	<1.1	6.4	1.7	18.9	<1.1	<1.1	28	92.7	<1.1	20.1	58.3	<70	70-100	100-200	200-400	>400
Calcium (as Ca)	5	3.4	16.2	6.7	41.6	2.8	0.43	97	130	5.7	31.8	80.2	<80	80-150	150-300	>300	
Chloride (as Cl)	66.4	89.9	60.7	41.7	36.6	58.1	66	188	96.9	96.2	98.1	307	<100	100-200	200-600	600-1200	>1200
Sulphate (as SO4)	19	4.3	7.9	6.6	27.2	10	5.5	100	616	4.4	18	118	<200	200-400	400-600	600-1000	>1000
Nitrate& Nitrite (as N)	<0.20	<0.2	0.24	<0.20	<0.2	0.26	0.22	<0.2	<0.2	<0.20	<0.20	2.1	<6	6.0-10	10.0-20	20-40	>40
Fluoride (as F)	3.3	6.8	3.1	5.1	1.3	3.6	7.2	1.6	1.5	3.4	1.8	0.91	<0.7	0.7-1.0	1.0-1.5	1.5-3.5	>3.5
Manganese (as Mn)	<0.019	<0.019	0.037	<0.019	0.067	<0.019	<0.019	<0.019	1.005	<0.019	<0.019	<0.019	<0.1	0.1-0.4	0.4-4	4.0-10.0	>10
Iron (as Fe)	0.08	0.083	0.175	<0.024	<0.024	0.294	0.296	<0.024	22.4	0.027	0.053	<0.024	<0.5	0.5-1.0	1.0-5.0	5.0-10.0	>10
Copper (as Cu)	0.016	0.014	0.015	<0.006	<0.006	0.015	0.016	<0.006	<0.006	<0.006	<0.006	<0.006	<1	1-1.3	1.3-2	2.0-15	>15
Zinc (as Zn)	0.02	0.007	0.01	0.003	0.003	0.006	0.006	0.003	0.004	<0.001	0.006	0.003	<20	>20			
Arsenic (as As)	0.167	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.010	0.01-0.05	0.05-0.2	0.2-2.0	>2.0
Cadmium (as Cd)	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.003	0.003-0.005	0.005-0.020	0.020-0.050	>0.050

From the chemical results presented in **Table 11** and **Table 12** it is clear that the groundwater from the boreholes are predominantly marginal quality in terms of dissolved mineral concentrations (which is in line with the expected groundwater quality of the area). There is however, elevated levels of fluoride, sulphate, chloride and sodium in some of the groundwater samples analysed. Exploration borehole Cal_Phase3_4A water sampled showed high levels of iron. Boreholes selected for production boreholes will require treatment if used for regular human consumption.

10. DISCUSSION

The geohydrology of the area has been characterized by means of a historical data. GEOSS identified four new sites to be explored for groundwater potential. Exploration boreholes were drilled on geological structures and geophysical anomalies identified through both onsite and regional data sets. A total of 31 exploration boreholes were drilled, 12 boreholes met the yield requirements and were yield tested for sustainable yield and groundwater chemistry.

GEOSS identified two areas that could be potentially developed into wellfield for bulk water supply, Ceres Karroo area (Kruitberg) and the North-west region (study area 4).

Overall the groundwater quality is classified as good to moderate. The fluoride concentration of all the tested sites is a concern (of varying degrees) and should be addressed before production begins. Exploration borehole Cal_Phase3_4A had an anomalous high iron concentration of 22 mg/L, typical iron concentration range between 0.024 – 0.3 mg/L.

Groundwater usage needs regular monitoring and management. If a groundwater scheme is left unattended it will eventually fail. Regular monitoring and site visits to the abstraction boreholes will ensure their long-term viability. This is especially important in such a low rainfall area.

11. RECOMMENDATIONS

The newly drilled and completed boreholes should be equipped and connected to the water supply scheme and using the abstraction rates recommended by GEOSS in order to maintain sustainability. The boreholes will also require monitoring infrastructure and need to be authorised via a Water Use License Application.

It is recommended that the abstraction boreholes' water levels be monitored with in-situ logger monitoring, to be assessed quarterly for two years, before optimisation can be done, potentially reducing monitoring to bi-annual data analyses.

The following pumping recommendations and comments are made in order to begin abstraction:

Site	Latitude (WGS84)	Longitude (WGS84)	Abstraction Rate (L/s)	Pump Depth (m)
Cal_DV1	-31.455414	19.773937	5	150
Cal_DV3	-31.430694	19.788300	0.8	150
Cal_DV4	-31.411629	19.775115	1	100
Cal-S2-3	-31.651334	19.801571	1.3	35
Cal-S2-4	-31.650359	19.801047	4	150
Cal_S2_10	-31.617462	19.744726	15	80
Cal_Nat5	-31.435236	19.784485	4.3	178
Cal_Nat6	-31.451284	19.770548	1.5	100
Cal_Phase3_6	-31.357725	19.691500	2	96
Cal_Phase3_4A	-31.401169	19.556679	15	70
Cal_Phase3_9	-31.632714	19.756781	15	96
Re-Drill 39602	-31.372864	19.970834	4.5	79

It is recommended that that the Hantam Municipality look to develop the Ceres Karroo area (Kruitberg), the North-west region (study area 4) and Calvinia nature reserve into functional well fields. The wellfields should then be used in a rotation, this will allow for groundwater levels to recovery and not over stress the system.

12. ACKNOWLEDGEMENTS

The following people are gratefully thanked for their input and support into this project:


- Gert Meiring (BVi) is thanked for his guidance into the project.

13. REFERENCES


- DWAF, (1998). Quality of domestic water supplies, Volume 1: Assessment guide. Department of Water Affairs and Forestry, Department of Health, Water Research Commission, 1998.
- DWAF, 1981. Possibilities for groundwater exploitation in the Loeriesfontein Area. Technical report GH3189. P. Seward. 20 November 1981.
- National Water Act (1998). The National Water Act, No 36. Department of Water Affairs and Forestry. Pretoria.
- Telford W. M., Geldart L. P. and Sheriff R. E., (1990). Applied Geophysics: Second Edition. Cambridge University Press.
- SANS, 2005. South African National Standard. 2005 Drinking Water Specification. SANS 241:2005. Edition 6.

WRC, 2012. A Groundwater Planning Toolkit for the Main Karoo Basin: Identifying and quantifying groundwater development options incorporating the concept of wellfield yields and aquifer firm yields. WRC Report No. 1763/1/11, Pretoria, South Africa.


14. APPENDIX A: MAPS




Map 1: Location of the study areas within a regional setting




Map 2-1: The study site, Exploration borehole details (ESRI base map – Bing imagery)




Map 2-2: The study site, Exploration borehole details (ESRI base map – Bing imagery)




Map 2-3: The study site, Exploration borehole details (ESRI base map – Bing imagery)




Map 2-4: The study site, Exploration borehole details (ESRI base map – Bing imagery)



Map 3: Geological setting of the study area and exploration boreholes (Council for Geoscience map: 1:250 000 scale 3118 Calvinia)











Map 4: Regional aquifer type and yields with tested borehole yields for exploration boreholes (L/s) (Background data 1:500 000 DWAF map 3118 - Calvinia)




Map 5: Regional groundwater quality (EC in mS/m) with measured borehole quality (EC in mS/m) (Background data 1:500 000 DWAF map 3118 - Calvinia)

15. APPENDIX B: GEOPHYSICS







**16. APPENDIX C: LABORATORY RESULTS – BEMLAB/ A.L
ABBOT AND ASSOCIATES**

CERTIFICATE OF ANALYSES

Report Nr.: WT014712.DOC

Julian Conrad
 GEOSS (Pty) Ltd
 Unit 19, Technostell Building
 9 Quantum Street, Technopark
 Stellenbosch
 7600

Date received: **22-09-2017**
 Order nr.: **#2026**

Sampled by client

Water Analyses Report

SANS241

Origin	Lab. Nr.	pH @ 25°C	EC @ 25°C mS/m	Na mg/l	K mg/l	Ca mg/l	Mg mg/l	Fe mg/l	Cl mg/l	SO ₄ mg/l	B mg/l	Mn mg/l	Cu mg/l	Zn mg/l	P mg/l	NH ₄ -N mg/l	NO ₃ -N mg/l	*NO ₂ -N mg/l
Calvinia BH1/Ceres R	14712	7.6	59.2	38.7	1.4	52.5	12.5	0.1	51.0	26	0.13	0.03	<0.02	<0.03	<0.01	<0.28	0.37	0.02
Sandgat BH4	14713	7.4	598.6	706.9	1.0	227.6	118.8	0.1	1420.0	664	1.01	<0.03	<0.02	<0.03	0.02	0.44	0.82	0.02
Norm		≥5.0-≤9.7	≤170.0	≤200.0				≤2.0	≤300.0	≤500	≤2.40	≤0.40	≤2.00	≤5.00		≤1.50	≤11.00	≤0.90

Origin	Lab. Nr.	*F mg/l	*TDS mg/l	Alkalinity mg/l	Al µg/l	As µg/l	Ba µg/l	Cd µg/l	Co µg/l	Cr µg/l	*Hg µg/l	Ni µg/l	Pb µg/l	Sb µg/l	Se µg/l	*U µg/l	V µg/l	*CN µg/l	Date Sampled
Calvinia BH1/Ceres R	14712	0.5	379.0	284.00	<30	7.7	6.3	<3.1	<1	<27	5.7	0.6	<7	12.5	<12	<13.8	1.6	15.0	14/09/2017
Sandgat BH4	14713	0.2	3831.0	511.00	<30	<5	41.7	<3.1	<1	<27	8.6	0.6	<7	<2	15.8	<13.8	5.6	12.0	18/09/2017
Norm		≤1.5	≤1200.0		≤300.00	≤10.0	≤700.0	≤3.0		≤50.0	≤6.0	≤70.0	≤10.0	≤20.0	≤40.0	≤30.0		≤200.0	

Origin	Lab. Nr.	Temperature at reception (°C)	*Colour mg/l Pt	*Turbidity NTU	*TOC mg/l	*Cl ₂ (Free) mg/l	Date Analysed
Calvinia BH1/Ceres R	14712	20.5	<1	0.60	6.80	0.28	27/09/2017
Sandgat BH4	14713	20.6	<1	0.34	30.20	0.29	27/09/2017
Norm			≤15	≤5	≤10.00	≤5.00	

* = Not SANAS Accredited

Norms according to SANS 241-1:2015.

Statement: The reported results may be applied only to samples received. Any recommendations included with this report are based on the assumption that the samples were representative of the source from which they were taken.



16 Van der Berg Crescent
Gant's Centre
Strand
Tel. (021) 853-1490
Fax (021) 853-1423
E-Mail admin@bemlab.co.za
P O Box 684
Somerset Mall,
7137
Vat Reg. Nr. 4200161414

CERTIFICATE OF ANALYSES

Report Nr.: WT008965.DOC

Julian Conrad
GEOSS (Pty) Ltd
Unit 19, Technostell Building
9 Quantum Street, Technopark
Stellenbosch
7600

Date received: 19-06-2017
Order nr.: 369/Ph/JT6

Sampled by client

Water Analyses Report

SANS241

Origin	Lab. Nr.	pH @ 25°C	EC @ 25°C mS/m	Na mg/l	K mg/l	Ca mg/l	Mg mg/l	Fe mg/l	Cl mg/l	SO ₄ mg/l	B mg/l	Mn mg/l	Cu mg/l	Zn mg/l	P mg/l	NH ₄ -N mg/l	NO ₂ -N mg/l	*NO ₃ -N mg/l
Dysseldorp_Drill 3	8965	5.0	24.1	19.9	2.4	8.4	5.7	0.2	44.0	36	<0.08	0.69	<0.02	0.10	0.03	<0.28	<0.36	0.01
Vermaaks_Drill- BH1	8966	5.3	12.5	13.0	0.6	2.3	2.2	0.3	36.0	4	<0.08	<0.03	<0.02	<0.03	<0.01	<0.28	<0.36	0.02
Vermaaks_Drill- BH4	8967	5.9	18.8	16.6	2.2	3.8	4.6	1.0	45.0	10	<0.08	2.19	<0.02	<0.03	0.02	<0.28	<0.36	0.03
Norm		≥5.0-≤9.7	≤170.0	≤200.0				≤2.0	≤300.0	≤500	≤2.40	≤0.40	≤2.00	≤5.00		≤1.50	≤11.00	≤0.90

Origin	Lab. Nr.	*F mg/l	*TDS mg/l	Alkalinity mg/l	Al µg/l	As µg/l	Ba µg/l	Cd µg/l	Co µg/l	Cr µg/l	*Hg µg/l	Ni µg/l	Pb µg/l	Sb µg/l	Se µg/l	*U µg/l	V µg/l	*CN µg/l	Date Sampled
Dysseldorp_Drill 3	8965	0.1	154.0	<11.49	<30	<5	10.6	<3.1	4.3	<27	7.1	34.5	<7	8.6	27.0	19.4	2.6	9.0	12/06/2017
Vermaaks_Drill- BH1	8966	0.0	80.0	<11.49	62.69	<5	6.4	<3.1	1.8	<27	<3.1	4.7	16.1	15.1	66.2	<13.8	0.9	6.0	14/06/2017
Vermaaks_Drill- BH4	8967	0.0	120.0	20.00	<30	<5	5.2	<3.1	6.6	<27	<3.1	6.7	43.3	9.4	49.8	14.3	0.5	0.0	13/06/2017
Norm		≤1.5	≤1200.0		≤300.00	≤10.0	≤700.0	≤3.0		≤50.0	≤6.0	≤70.0	≤10.0	≤20.0	≤40.0	≤30.0		≤200.0	

Origin	Lab. Nr.	Temperature at reception (°C)	*Colour mg/l Pt	*Turbidity NTU	*TOC mg/l	*Cl ₂ (Free) mg/l	Date Analysed
Dysseldorp_Drill 3	8965	9.2	<1	1.35	7.00	0.07	20/06/2017
Vermaaks_Drill- BH1	8966	9.1	7	8.49	6.20	0.08	20/06/2017
Vermaaks_Drill- BH4	8967	9.8	6	15.20	7.20	0.17	20/06/2017
Norm			≤15	≤5	≤10.00	≤5.00	

* = Not SANAS Accredited

Norms according to SANS 241-1:2015.



16 Van der Berg Crescent
Gant's Centre
Strand
Tel. (021) 853-1490
Fax (021) 853-1423
E-Mail admin@bemlab.co.za
P O Box 684
Somerset Mall,
7137
Vat Reg. Nr. 4200161414

CERTIFICATE OF ANALYSES

Report Nr.: WT015384.DOC

Julian Conrad
GEOSS (Pty) Ltd
Unit 19, Technostell Building
9 Quantum Street, Technopark
Stellenbosch
7600

Date received: **04-10-2017**
Order nr.: **#2026**

Sampled by client

Water Analyses Report

SANS241

Origin	Lab. Nr.	pH @ 25°C	EC @ 25°C mS/m	Na mg/l	K mg/l	Ca mg/l	Mg mg/l	Fe mg/l	Cl mg/l	SO ₄ mg/l	B mg/l	Mn mg/l	Cu mg/l	Zn mg/l	P mg/l	NH ₄ -N mg/l	NO ₃ -N mg/l	*NO ₂ -N mg/l	*F mg/l
Gof Course_BH	15384	7.4	214	190.3	5.1	124.7	60.4	0.2	542.8	112	0.18	<0.03	<0.02	<0.03	<0.01	0.29	<0.36	0.02	0.2
Witwal_BH3	15385	8.4	93	175.6	7.4	<0.05	0.4	0.2	157.3	94	0.53	<0.03	<0.02	<0.03	<0.01	0.57	<0.36	0.09	1.4
Sandgat_3_BH4	15386	7.5	605	929.4	1.8	131.8	139.1	0.2	1564.2	869	1.36	<0.03	<0.02	<0.03	<0.01	0.31	0.61	0.01	0.1
Deon_Vlok_BH	15387	7.5	150	128.3	3.1	92.1	55.3	0.2	225.3	177	0.30	<0.03	<0.02	<0.03	<0.01	<0.28	<0.36	0.02	0.8
Sandgat_5_BH3	15388	7.0	279	305.7	4.6	116.1	70.8	0.1	761.9	194	0.32	<0.02	<0.02	<0.03	<0.01	0.31	0.64	0.06	0.0
Norm		≥5.0-≤9.7	≤170	≤200.0				≤2.0	≤300.0	≤500	≤2.40	≤0.40	≤2.00	≤5.00		≤1.50	≤11.00	≤0.90	≤1.5

Origin	Lab. Nr.	*TDS mg/l	Alkalinity mg/l	Al µg/l	As µg/l	Ba µg/l	Cd µg/l	Co µg/l	Cr µg/l	*Hg µg/l	Ni µg/l	Pb µg/l	Sb µg/l	Se µg/l	*U µg/l	V µg/l	*CN µg/l	Date Sampled	Temperature at reception (°C)
Gof Course_BH	15384	1283.0	167.86	<30	<5	<5	<3.1	<1	<27	<3.1	5.7	<7	11.2	<12	<13.8	<0.13	5.0	25/09/2017	13.3
Witwal_BH3	15385	561.0	181.40	<30	<5	69.2	<3.1	<1	<27	3.2	29.1	<7	13.2	<12	<13.8	<0.13	6.0	29/09/2017	13.6
Sandgat_3_BH4	15386	3600.0	388.04	<30	8.4	15.2	<3.1	<1	47.7	<3.1	23.7	9.3	11.9	<12	20.0	2.2	4.0	29/09/017	11.8
Deon_Vlok_BH	15387	901.0	278.56	<30	<5	41.3	<3.1	<1	<27	<3.1	28.8	<7	10.3	<12	15.2	1.7	7.0	29/09/017	14.3
Sandgat_5_BH3	15388	1670.0	132.51	<30	7.2	56.5	<3.1	1.2	<27	<3.1	26.6	8.1	5.5	17.5	14.4	<0.13	6.0	29/09/017	13.0
Norm		≤1200.0		≤300.00	≤10.0	≤700.0	≤3.0		≤50.0	≤6.0	≤70.0	≤10.0	≤20.0	≤40.0	≤30.0		≤200.0		

Origin	Lab. Nr.	*Colour mg/l Pt	*Turbidity NTU	*TOC mg/l	*Cl ₂ (Free) mg/l	Date Analysed
Gof Course_BH	15384	<1	1.36	4.80	0.04	05/10/2017
Witwal_BH3	15385	<1	0.38	5.90	0.06	05/10/2017
Sandgat_3_BH4	15386	<1	0.23	16.70	0.06	05/10/2017
Deon_Vlok_BH	15387	<1	1.41	8.70	0.10	05/10/2017
Sandgat_5_BH3	15388	<1	0.36	3.60	0.09	05/10/2017
Norm		≤15	≤5	≤10.00	≤5.00	

* = Not SANAS Accredited

Norms according to SANS 241-1:2015.

Statement: The reported results may be applied only to samples received. Any recommendations included with this report are based on the assumption that the samples were representative of the source from which they were taken.

Notes:

To ensure sample integrity, samples are stored only for seven days after release of the report. Thereafter it is disposed of and a fresh sample will be required if additional analyses are requested.

Results marked with "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this laboratory. These results relate to the items tested.

This test report shall not be reproduced except in full, without written approval of the laboratory.

Opinions and interpretations expressed herein are outside the scope of SANAS accreditation.

Refer to [website](#) for uncertainty of measurement and referenced methods.

Sample condition: Samples received in good condition.



Dr. Pieter Raath
General Manager



Lauren Taylor
Technical Signatory(Microbiology)

13-10-2017
Date reported

—————END OF REPORT—————

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALVINIA DV1

DATE SAMPLED : 2018/05/22
DATE RECEIVED : 2018/05/22
DATE ANALYSIS COMMENCED : 2018/05/22

OUR REF. : 2018/05/22/14687
REPORT NO. : 3606

	Sample Number	14687	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	54.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	361	≤1200 Aesthetic
27	Turbidity (NTU)	2.1	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	8.39	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	19.0	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	3.3	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	0.20	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	66.4	≤300 Aesthetic
92	Sodium (mg/l as Na)	86.0	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.02	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	167	≤10 Chronic Health
92	Barium (µg/l as Ba)	37	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



T0276

Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALVINIA DV1

DATE SAMPLED : 2018/05/22
DATE RECEIVED : 2018/05/22
DATE ANALYSIS COMMENCED : 2018/05/22

OUR REF. : 2018/05/22/14687
REPORT NO. : 3606

	Sample Number	14687	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	16	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	80	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	6	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	108	≤300 Operational
105	Total Organic Carbon (mg/l as C)	13.2	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	18.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.43	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Doc.No. 5.10/1 Rev.4

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALVINIA DV1

DATE SAMPLED : 2018/05/22
DATE RECEIVED : 2018/05/22
DATE ANALYSIS
COMMENCED : 2018/05/22

OUR REF. : 2018/05/22/14687
REPORT NO. : 3606

	Sample Number	14687	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	10	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	902	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	5.0	N/A
92	Magnesium (mg/l as Mg)	<1.1	N/A
92	Potassium (mg/l as K)	0.73	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	105	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
04 June 2018

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

**GEOSS
ANALYSIS
CALVINIA DV3**

DATE SAMPLED : 2018/05/22
DATE RECEIVED : 2018/05/22
DATE ANALYSIS COMMENCED : 2018/05/22

OUR REF. : 2018/05/22/14688
REPORT NO. : 3606

	Sample Number	14688	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	49.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	327	≤1200 Aesthetic
27	Turbidity (NTU)	2.0	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	9.59	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	4.3	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	6.8	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	0.28	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	89.9	≤300 Aesthetic
92	Sodium (mg/l as Na)	76.1	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.007	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	2	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

**GEOSS
ANALYSIS
CALVINIA DV3**

DATE SAMPLED : 2018/05/22
DATE RECEIVED : 2018/05/22
**DATE ANALYSIS
COMMENCED :** 2018/05/22

OUR REF. : 2018/05/22/14688
REPORT NO. : 3606

	Sample Number	14688	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	14	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	83	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	5	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	92	≤300 Operational
105	Total Organic Carbon (mg/l as C)	2.1	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	11.2	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

Sanas Watermark

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alsabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALVINIA DV3

DATE SAMPLED : 2018/05/22
DATE RECEIVED : 2018/05/22
DATE ANALYSIS
COMMENCED : 2018/05/22

OUR REF. : 2018/05/22/14688
REPORT NO. : 3606

	Sample Number	14688	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	7	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	3.4	N/A
92	Magnesium (mg/l as Mg)	<1.1	N/A
92	Potassium (mg/l as K)	0.52	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	36.3	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
05 June 2018

TO: 'Julian Conrad' <jconrad@geoss.co.za>

'Alison McDuling' <amcduling@geoss.co.za>

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA-CAL-DV4

DATE SAMPLED : 2018/05/21
DATE RECEIVED : 2018/05/30
DATE ANALYSIS
COMMENCED : 2018/05/30

OUR REF. : 2018/05/21/15509
REPORT NO. : 3840

	Sample Number	15509	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	73.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	495	≤1200 Aesthetic
27	Turbidity (NTU)	10.3	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	8.32	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	0.24	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.23	≤1.0
102	Sulphate (mg/l as SO ₄)	7.9	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	3.1	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	0.23	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	60.7	≤300 Aesthetic
92	Sodium (mg/l as Na)	116	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.01	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	388	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alsabbott.co.za



T0276

Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7825
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA-CAL-DV4

DATE SAMPLED : 2018/05/21
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/21/15509
REPORT NO. : 3840

	Sample Number	15509	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	14	≤50 Chronic Health
92	Copper (µg/l as Cu)	15	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	175	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	37	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	4	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	187	≤300 Operational
105	Total Organic Carbon (mg/l as C)	1.0	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	54.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	120	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	192	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	3.5	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA-CAL-DV4

DATE SAMPLED : 2018/05/21
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/21/15509
REPORT NO. : 3840

	Sample Number	15509	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	1	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	16.2	N/A
92	Magnesium (mg/l as Mg)	6.4	N/A
92	Potassium (mg/l as K)	1.4	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	285	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
13 June 2018

TO: BVI CONSULTING ENGINEERS
P O Box 1155
UPINGTON
8800

Attention : GERT MEIRING

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alsabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

KRUITBERG CALVINIA-CAL-S2-3

DATE SAMPLED : 2018/05/30
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/30/15510
REPORT NO. : 3840

	Sample Number	15510	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	70.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	474	≤1200 Aesthetic
27	Turbidity (NTU)	8.8	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	9.22	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	0.26	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.23	≤1.0
102	Sulphate (mg/l as SO4)	10.0	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	3.6	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	0.47	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	58.1	≤300 Aesthetic
92	Sodium (mg/l as Na)	125	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.006	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	10	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

KRUITBERG CALVINIA-CAL-S2-3

DATE SAMPLED : 2018/05/30
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/30/15510
REPORT NO. : 3840

	Sample Number	15510	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	11	≤50 Chronic Health
92	Copper (µg/l as Cu)	15	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	294	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	4	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	323	≤300 Operational
105	Total Organic Carbon (mg/l as C)	0.98	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	103	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	130	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	317	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	5.0	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Doc.No. 5.10/1 Rev.4

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

KRUITBERG CALVINIA-CAL-S2-3

DATE SAMPLED : 2018/05/30
DATE RECEIVED : 2018/05/30
DATE ANALYSIS
COMMENCED : 2018/05/30

OUR REF. : 2018/05/30/15510
REPORT NO. : 3840

	Sample Number	15510	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	4	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	2.8	N/A
92	Magnesium (mg/l as Mg)	<1.1	N/A
92	Potassium (mg/l as K)	1.2	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	254	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
13 June 2018

TO: BVI CONSULTING ENGINEERS
P O Box 1155
UPINGTON
8800

Attention : GERT MEIRING

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

KRUITBERG-CAL-S2-4

DATE SAMPLED : 2018/05/30
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/30/15511
REPORT NO. : 3840

	Sample Number	15511	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	6	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	74.0	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	488	≤1200 Aesthetic
27	Turbidity (NTU)	7.2	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	9.83	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	0.22	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	5.5	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	7.2	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	0.31	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	66.0	≤300 Aesthetic
92	Sodium (mg/l as Na)	127	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.006	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	2	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

KRUITBERG-CAL-S2-4

DATE SAMPLED : 2018/05/30
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/30/15511
REPORT NO. : 3840

	Sample Number	15511	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	11	≤50 Chronic Health
92	Copper (µg/l as Cu)	16	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	296	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	4	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	238	≤300 Operational
105	Total Organic Carbon (mg/l as C)	0.79	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

KRUITBERG-CAL-S2-4

DATE SAMPLED : 2018/05/30
DATE RECEIVED : 2018/05/30
DATE ANALYSIS COMMENCED : 2018/05/30

OUR REF. : 2018/05/30/15511
REPORT NO. : 3840

	Sample Number	15511	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	727	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	0.43	N/A
92	Magnesium (mg/l as Mg)	<1.1	N/A
92	Potassium (mg/l as K)	1.0	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	238	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
11 June 2018

TO: BVI CONSULTING ENGINEERS
P O Box 1155
UPINGTON
8800

Attention : GERT MEIRING

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS

ANALYSIS

CAL-NAT5-NATURE RESERVE CALVINIA

DATE SAMPLED : 2018/07/20

DATE RECEIVED : 2018/07/20

DATE ANALYSIS 2018/07/20

COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20641

REPORT NO. : 4995

	Sample Number	20641	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	45.0	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	265	≤1200 Aesthetic
27	Turbidity (NTU)	0.37	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	8.18	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	6.6	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	5.1	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	41.7	≤300 Aesthetic
92	Sodium (mg/l as Na)	70.8	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.003	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	1	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

**GEOSS
ANALYSIS**

CAL-NAT5-NATURE RESERVE CALVINIA

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
**DATE ANALYSIS
COMMENCED :** 2018/07/20

OUR REF. : 2018/07/20/20641
REPORT NO. : 4995

	Sample Number	20641	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN ⁻)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	<24	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	4	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	39	≤300 Operational
105	Total Organic Carbon (mg/l as C)	0.82	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS

ANALYSIS

CAL-NAT5-NATURE RESERVE CALVINIA

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
DATE ANALYSIS
COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20641
REPORT NO. : 4995

	Sample Number	20641	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	7	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	660	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	6.7	N/A
92	Magnesium (mg/l as Mg)	1.7	N/A
92	Potassium (mg/l as K)	0.68	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	124	N/A

JOSE DA SILVA (Cert.Sci.Nat.)
TECHNICAL MANAGER
26 July 2018

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Doc.No. 5.10/1 Rev.4

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

**GEOSS
ANALYSIS
CAL-NET6-CALVINIA**

DATE SAMPLED : 2018/07/20

DATE RECEIVED : 2018/07/20

DATE ANALYSIS

COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20642

REPORT NO. : 4995

	Sample Number	20642	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	60.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	381	≤1200 Aesthetic
27	Turbidity (NTU)	0.13	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	7.36	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	27.2	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	1.3	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	36.6	≤300 Aesthetic
92	Sodium (mg/l as Na)	53.5	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.003	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	5	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

**GEOSS
ANALYSIS
CAL-NET6-CALVINIA**

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
**DATE ANALYSIS
COMMENCED :** 2018/07/20

OUR REF. : 2018/07/20/20642
REPORT NO. : 4995

	Sample Number	20642	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	<24	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	67	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	4	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	<12	≤300 Operational
105	Total Organic Carbon (mg/l as C)	0.58	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	4	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CAL-NET6-CALVINIA

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
DATE ANALYSIS
COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20642
REPORT NO. : 4995

	Sample Number	20642	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	6	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	41.6	N/A
92	Magnesium (mg/l as Mg)	18.9	N/A
92	Potassium (mg/l as K)	0.76	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	222	N/A

JOSE DA SILVA (Cert.Sci.Nat.)
TECHNICAL MANAGER
26 July 2018

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALS2-10

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
DATE ANALYSIS COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20643
REPORT NO. : 4995

	Sample Number	20643	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	127	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	823	≤1200 Aesthetic
27	Turbidity (NTU)	0.37	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	7.39	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO4)	100	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	1.6	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	188	≤300 Aesthetic
92	Sodium (mg/l as Na)	108	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.003	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	3	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALS2-10

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
DATE ANALYSIS COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20643
REPORT NO. : 4995

	Sample Number	20643	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	<24	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	5	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	<12	≤300 Operational
105	Total Organic Carbon (mg/l as C)	0.52	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CALS2-10

DATE SAMPLED : 2018/07/20
DATE RECEIVED : 2018/07/20
DATE ANALYSIS
COMMENCED : 2018/07/20

OUR REF. : 2018/07/20/20643
REPORT NO. : 4995

	Sample Number	20643	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	<1	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	330	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	97.0	N/A
92	Magnesium (mg/l as Mg)	28.0	N/A
92	Potassium (mg/l as K)	2.9	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	247	N/A

JOSE DA SILVA (Cert.Sci.Nat.)
TECHNICAL MANAGER
26 July 2018

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS

ANALYSIS

CAL PHASE-39 (KREITZBERG)

DATE SAMPLED : 2018/08/21

DATE RECEIVED : 2018/08/21

DATE ANALYSIS

COMMENCED : 2018/08/21

OUR REF. : 2018/08/21/22876

REPORT NO. : 5505

	Sample Number	22876	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	75.0	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	531	≤1200 Aesthetic
27	Turbidity (NTU)	0.90	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	7.66	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	<1.0	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	1.7	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	95.2	≤300 Aesthetic
92	Sodium (mg/l as Na)	71.0	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.004	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	7	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CAL PHASE-39 (KREITZBERG)

DATE SAMPLED : 2018/08/21
DATE RECEIVED : 2018/08/21
DATE ANALYSIS
COMMENCED : 2018/08/21

OUR REF. : 2018/08/21/22876
REPORT NO. : 5505

	Sample Number	22876	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	25	≤50 Chronic Health
92	Copper (µg/l as Cu)	10	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	59	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<10	≤10 Chronic Health
92	Manganese (µg/l as Mn)	34	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	8	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	27	≤300 Operational
105	Total Organic Carbon (mg/l as C)	0.10	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	91.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	11.0	≤60 Chronic Health
N/A	Combined Trihalomethane	0.69	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

GEOSS
ANALYSIS
CAL PHASE-39 (KREITZBERG)

DATE SAMPLED : 2018/08/21
DATE RECEIVED : 2018/08/21
DATE ANALYSIS
COMMENCED : 2018/08/21

OUR REF. : 2018/08/21/22876
REPORT NO. : 5505

	Sample Number	22876	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	687	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	36.5	N/A
92	Magnesium (mg/l as Mg)	17.8	N/A
92	Potassium (mg/l as K)	2.6	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	207	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
24 August 2018

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA CAL PHASE 3-4

DATE SAMPLED : 2018/08/24

TIME:07H50

DATE RECEIVED : 2018/09/07

OUR REF. : 2018/08/24/24444

DATE ANALYSIS

COMMENCED : 2018/09/07

REPORT NO. : 5871

	Sample Number	24444	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	173	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	1354	≤1200 Aesthetic
27	Turbidity (NTU)	82.0	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	7.45	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	616	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	1.5	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	96.9	≤300 Aesthetic
92	Sodium (mg/l as Na)	95.7	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.004	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	15	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



T0276

Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA CAL PHASE 3-4

DATE SAMPLED : 2018/08/24
DATE RECEIVED : 2018/09/07
DATE ANALYSIS COMMENCED : 2018/09/07

OUR REF. : 2018/08/24/24444
REPORT NO. : 5871

	Sample Number	24444	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	22400	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	1005	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	10	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	<12	≤300 Operational
105	Total Organic Carbon (mg/l as C)	<0.10	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethanes (µg/l)	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA CAL PHASE 3-4

DATE SAMPLED : 2018/08/24
DATE RECEIVED : 2018/09/07
DATE ANALYSIS COMMENCED : 2018/09/07

OUR REF. : 2018/08/24/24444
REPORT NO. : 5871

	Sample Number	24444	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	<1	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	176	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	130	N/A
92	Magnesium (mg/l as Mg)	92.7	N/A
92	Potassium (mg/l as K)	6.2	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	96.4	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
17 September 2018

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA CAL PHASE 3-6

DATE SAMPLED : 2018/08/29

TIME: 01H20

DATE RECEIVED : 2018/09/07

OUR REF. : 2018/08/29/24445

DATE ANALYSIS

COMMENCED : 2018/09/07

REPORT NO. : 5871

	Sample Number	24445	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	5	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	48.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	377	≤1200 Aesthetic
27	Turbidity (NTU)	0.60	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	9.45	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	4.4	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	3.4	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	96.2	≤300 Aesthetic
92	Sodium (mg/l as Na)	77.1	≤200 Aesthetic
92	Zinc (mg/l as Zn)	<0.001	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	1	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA CAL PHASE 3-6

DATE SAMPLED : 2018/08/29
DATE RECEIVED : 2018/09/07
DATE ANALYSIS COMMENCED : 2018/09/07

OUR REF. : 2018/08/29/24445
REPORT NO. : 5871

Mthd ALA No.	Sample Number	24445	
	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN-)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	27	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	<1	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	20	≤300 Operational
105	Total Organic Carbon (mg/l as C)	<0.10	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	14.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethanes (µg/l)	0.41	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

Sampler : CUSTOMER

Refer to attached Appendix 1 : Indicating * Tests marked "SANAS Accredited", Tests Methods and Detection Limits.

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA CAL PHASE 3-6

DATE SAMPLED : 2018/08/29
DATE RECEIVED : 2018/09/07
DATE ANALYSIS COMMENCED : 2018/09/07

OUR REF. : 2018/08/29/24445
REPORT NO. : 5871

Mthd ALA No.	Analyses	Results	SANS 241-1:2015
	Sample Number	24445	
85	Total Coliform Bacteria (count per 100 ml)	2	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	264	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	5.7	N/A
92	Magnesium (mg/l as Mg)	<1.1	N/A
92	Potassium (mg/l as K)	0.63	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	41.3	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
17 September 2018

Att: Gert Meiring <gertm@bvinc.co.za>

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA KREITZBERG CAL PHASE 3-9

DATE SAMPLED : 2018/09/03

TIME:08H25

DATE RECEIVED : 2018/09/07

OUR REF. : 2018/09/03/24446

DATE ANALYSIS

COMMENCED : 2018/09/07

REPORT NO. : 5871

	Sample Number	24446	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	<4	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	75.5	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	553	≤1200 Aesthetic
27	Turbidity (NTU)	0.18	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	8.55	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	<0.20	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	<0.20	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.22	≤1.0
102	Sulphate (mg/l as SO ₄)	18.0	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	1.8	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	98.1	≤300 Aesthetic
92	Sodium (mg/l as Na)	77.9	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.006	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	8	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA KREITZBERG CAL PHASE 3-9

DATE SAMPLED : 2018/09/03

DATE RECEIVED : 2018/09/07

DATE ANALYSIS

COMMENCED : 2018/09/07

OUR REF. : 2018/09/03/24446

REPORT NO. : 5871

	Sample Number	24446	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN ⁻)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	53	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	<1	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	141	≤300 Operational
105	Total Organic Carbon (mg/l as C)	<0.10	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethanes (µg/l)	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

CALVINIA KREITZBERG CAL PHASE 3-9

DATE SAMPLED : 2018/09/03
DATE RECEIVED : 2018/09/07
DATE ANALYSIS
COMMENCED : 2018/09/07

OUR REF. : 2018/09/03/24446
REPORT NO. : 5871

	Sample Number	24446	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	7	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	132	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	31.8	N/A
92	Magnesium (mg/l as Mg)	20.1	N/A
92	Potassium (mg/l as K)	2.8	N/A
94	Total Alkalinity (mg/l as CaCO ₃)	201	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
17 September 2018

Att: Gert Meiring <gertm@bvinc.co.za>

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

SPITZHOP REDRILL 39602

DATE SAMPLED : 2018/08/19

TIME:15H15

DATE RECEIVED : 2018/09/07

OUR REF. : 2018/08/19/24447

DATE ANALYSIS
COMMENCED : 2018/09/07

REPORT NO. : 5871

	Sample Number	24447	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
97	Colour (mg/l as Pt)	5	≤15 Aesthetic
9	Conductivity (mS/m) (at 25 °C)	175	≤170 Aesthetic
7	Total Dissolved Solids (mg/l)	1381	≤1200 Aesthetic
27	Turbidity (NTU)	0.52	≤1 Operational : ≤5 Aesthetic
19	pH (at 25 °C)	8.09	≥5 - ≤9.7 Operational
66	Free Chlorine (mg/l)	<0.05	≤5 Chronic Health
N/A	Monochloramine (mg/l)	<0.05	≤3 Chronic Health
Calc	Nitrate Nitrogen (mg/l as N)	1.9	≤11 Acute Health
99	Nitrite Nitrogen (mg/l as N)	<0.20	≤0.9 Acute Health
100	Nitrate & Nitrite Nitrogen (mg/l as N)	2.1	≤12 Acute Health
N/A	Combined Nitrate plus Nitrite (mg/l as N)	0.39	≤1.0
102	Sulphate (mg/l as SO ₄)	118	≤250 Aesthetic ≤500 Acute Health
98	Fluoride (mg/l as F)	0.91	≤1.5 Chronic Health
95	Ammonia Nitrogen (mg/l as N)	<0.10	≤1.5 Aesthetic
96	Chloride (mg/l as Cl)	307	≤300 Aesthetic
92	Sodium (mg/l as Na)	160	≤200 Aesthetic
92	Zinc (mg/l as Zn)	0.003	≤5 Aesthetic
92	Antimony (µg/l as Sb)	<10	≤20 Chronic Health
92	Arsenic (µg/l as As)	<3	≤10 Chronic Health
92	Barium (µg/l as Ba)	19	≤700 Chronic Health
47	Boron (mg/l as B)	<0.10	≤2.4 Chronic Health

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

SPITZHOP REDRILL 39602

DATE SAMPLED : 2018/08/19
DATE RECEIVED : 2018/09/07
DATE ANALYSIS COMMENCED : 2018/09/07

OUR REF. : 2018/08/19/24447
REPORT NO. : 5871

	Sample Number	24447	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
92	Cadmium (µg/l as Cd)	<1	≤3 Chronic Health
92	Total Chromium (µg/l as Cr)	<7	≤50 Chronic Health
92	Copper (µg/l as Cu)	<6	≤2000 Chronic Health
51	Cyanide (µg/l as CN ⁻)	<20	≤200 Acute Health
92	Iron (µg/l as Fe)	<24	≤300 Aesthetic ≤2000 Chronic Health
92	Lead (µg/l as Pb)	<7	≤10 Chronic Health
92	Manganese (µg/l as Mn)	<19	≤100 Aesthetic ≤400 Chronic Health
92	Mercury (µg/l as Hg)	<5	≤6 Chronic Health
92	Nickel (µg/l as Ni)	<1	≤70 Chronic Health
92	Selenium (µg/l as Se)	<10	≤40 Chronic Health
92	Uranium (µg/l as U)	<15	≤30 Chronic Health
92	Aluminium (µg/l as Al)	<12	≤300 Operational
105	Total Organic Carbon (mg/l as C)	40.0	≤10 Chronic Health
N/A	Trihalomethane (Chloroform) (µg/l)	<10.0	≤300 Chronic Health
N/A	Trihalomethane (Bromoform) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Dibromochloromethane) (µg/l)	<10.0	≤100 Chronic Health
N/A	Trihalomethane (Bromodichloromethane) (µg/l)	<10.0	≤60 Chronic Health
N/A	Combined Trihalomethanes (µg/l)	0.40	≤1.0
N/A	Total Microcystin (µg/l)	<0.15	≤1
45	Phenols (mg/l)	<0.01	≤0.01 Aesthetic
84	E.coli (count per 100 ml)	<1	Not Detected

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (0833263887)
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.4

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

BVI CONSULTING ENGINEERS

ANALYSIS

SPITZHOP REDRILL 39602

DATE SAMPLED : 2018/08/19
DATE RECEIVED : 2018/09/07
DATE ANALYSIS COMMENCED : 2018/09/07

OUR REF. : 2018/08/19/24447
REPORT NO. : 5871

	Sample Number	24447	
Mthd ALA No.	Analyses	Results	SANS 241-1:2015
85	Total Coliform Bacteria (count per 100 ml)	<1	≤10 Operational
88	Heterotrophic Plate Count (count per ml)	>1000	≤1000 Operational
N/A	Somatic Coliphages (count per 10 ml)	<1	Not Detected Operational
92	Calcium (mg/l as Ca)	80.2	N/A
92	Magnesium (mg/l as Mg)	58.3	N/A
92	Potassium (mg/l as K)	2.3	N/A
94	Total Alkalinity (mg/l as CaCO3)	281	N/A

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
17 September 2018


Att: Gert Meiring <gertm@bvinc.co.za>

17. APPENDIX D: – PUMPING TEST DATA SHEETS – AB PUMPS

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: NC
FARM / VILLAGE NAME : CALVINIA- CERES RD
DATE TESTED: 12/09/2017

PROJECT #	P1848
BBR	CHRISTOPHER
PRODUCTION BONUS:	
EC meter number	

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.64347**
LONGITUDE: _____ **OR** _____ **OR** **19.74949**

BOREHOLE NO: BH01 CALVINIA -CERES RD
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: OPEN CASING
BOREHOLE DEPTH: (mbdl) 51.90

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	AVN
Date sample taken	14/09/2017		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	17H30						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M 51.90
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M 14.53
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO 0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO 1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO 0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M 50
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO 0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____
DESIGNATION: _____

SIGNATURE: _____
DATE: _____


FORM 5 E																								
STEPPED DISCHARGE TEST & RECOVERY																								
BOREHOLE TEST RECORD SHEET																								
PROJ NO:		P1848		MAP REFERENCE:		0		PROVINCE:		NC														
BOREHOLE NO:		BH01 CALVINIA - CERES RD		DISTRICT:		CALVINIA																		
ALT BH NO:		0		SITE NAME:		CALVINIA- CERES RD																		
ALT BH NO:		0		BOREHOLE DEPTH (m):		51.90		DATUM LEVEL ABOVE CASING (m):		0.23		EXISTING PUMP:		0										
WATER LEVEL (mbdl):		14.01		CASING HEIGHT: (magl):		0.20		CONTRACTOR:		AB PUMPS														
DEPTH OF PUMP (m):		49.10		DIAMPUMP INLET (mm):		210.00		PUMP TYPE:		BP50														
STEPPED DISCHARGE TEST & RECOVERY																								
DISCHARGE RATE 1				RPM		DISCHARGE RATE 2				RPM		DISCHARGE RATE 3				RPM								
DATE:		12/09/2017		TIME:		12H25		DATE:		12/09/2017		TIME:		13H25		DATE:		12/09/2017		TIME:		14H25		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	4.21		5		1	16.73		1		1	24.07		1					1			1			21.65
2	8.19		2		2	17.35		2		2	26.15		2					2			2			14.84
3	9.55		3		3	18.24		3		3	28.42	5.06	3					3			3			11.03
5	10.66	1.74	5		5	19.87	2.54	5		4	30.36		5					5			5			6.14
7	13.14		7		7	21.05		7		5	35.09	5.06	7					7			7			3.73
10	14.45	1.74	10		10	21.82	2.51	10		6	35.09	3.40	10					10			10			2.03
15	14.62		15		15	22.31		15		7	35.09	3.02	15					15			15			
20	14.74	1.73	20		20	22.53	2.51	20		7	35.09	2.88	20					20			20			
30	14.81		30		30	22.68		30					30					30			30			
40	14.89	1.70	40		40	22.73	2.53	40					40					40			40			
50	14.96		50		50	22.85		50					50					50			50			
60	15.02	1.72	60		60	22.94	2.51	60					60					60			60			
70			70		70			70					70					70			70			
80			80		80			80					80					80			80			
90			90		90			90					90					90			90			
100			100		100			100					100					100			100			
110			110		110			110					110					110			110			
120			120		120			120					120					120			120			
pH			150		pH			150		pH			150					150			150			
TEMP	21.40	°C	180		TEMP	20.80	°C	180		TEMP		°C	180					180			180			
EC	365.00	µS/cm	210		EC	376.00	µS/cm	210		EC		µS/cm	210					210			210			
DISCHARGE RATE 4				RPM		DISCHARGE RATE 5				RPM		DISCHARGE RATE 6				RPM								
DATE:				TIME:				DATE:				TIME:				DATE:				TIME:				
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1			1		1			1		1			1					1			1			
2			2		2			2		2			2					2			2			
3			3		3			3		3			3					3			3			
5			5		5			5		5			5					5			5			
7			7		7			7		7			7					7			7			
10			10		10			10		10			10					10			10			
15			15		15			15		15			15					15			15			
20			20		20			20		20			20					20			20			
30			30		30			30		30			30					30			30			
40			40		40			40		40			40					40			40			
50			50		50			50		50			50					50			50			
60			60		60			60		60			60					60			60			
70			70		70			70		70			70					70			70			
80			80		80			80		80			80					80			80			
90			90		90			90		90			90					90			90			
100			100		100			100		100			100					100			100			
110			110		110			110		110			110					110			110			
120			120		120			120		120			120					120			120			
pH			150		pH			150		pH			150					150			150			
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180					180			180			
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210					210			210			
			240					240					240					240			240			
			300					300					300					300			300			
			360					360					360					360			360			
S/WL:(mbch) 13.7																								

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P1848			MAP REFERENCE: 31.64347				PROVINCE: NC			DISTRICT: CALVINIA		
BOREHOLE NO: BH01 CALVINIA-CERES RD			19.74949				SITE NAME: CALVINIA-CERES RD					
ALT BH NO: 0							EXISTING PUMP: 0			CONTRACTOR: AB PUMPS		
ALT BH NO: 0							PUMP TYPE: BP50					
BOREHOLE DEPTH: 51.90			DATUM LEVEL ABOVE CASING (m): 0.23									
WATER LEVEL (mbdl): 14.52			CASING HEIGHT: (magl): 0.20									
DEPTH OF PUMP (m): 49.10			DIAM PUMP INLET(mm): 210									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	12/09/2017	TIME:	17H40	DATE:		TIME:		TYPE OF PUMP:				BP50
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR:		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	2.52		1	10.51	1			1			1	
2	4.07		2	7.44	2			2			2	
3	6.89	2.05	3	5.92	3			3			3	
5	8.82		5	4.11	5			5			5	
7	10.76	2.06	7	3.27	7			7			7	
10	12.29		10	2.61	10			10			10	
15	13.01	2.04	15	2.24	15			15			15	
20	14.16		20	2.07	20			20			20	
30	14.41	2.04	30	1.92	30			30			30	
40	14.55		40	1.83	40			40			40	
60	14.63	2.01	60	1.75	60			60			60	
90	14.76		90		90			90			90	
120	14.82	2.02	120		120			120			120	
150	14.87		150		150			150			150	
180	14.91	2.02	180		180			180			180	
210	14.94		210		210			210			210	
240	14.97	2.02	240		240			240			240	
300	15.00		300		300			300			300	
360	15.04	2.05	360		360			360			360	
420	15.07		420		420			420			420	
480	15.11	2.02	480		480			480			480	
540	15.13		540		540			540			540	
600	15.16	2.04	600		600			600			600	
720	15.19		720		720			720			720	
840	15.36	2.01	840		840			840			840	
960	15.48		960		960			960			960	
1080	15.64	2.01	1080		1080			1080			1080	
1200	15.82		1200		1200			1200			1200	
1320	16.05	2.03	1320		1320			1320			1320	
1440	16.23		1440		1440			1440			1440	
1560	16.49	2.00	1560		1560			1560			1560	
1680	16.57		1680		1680			1680			1680	
1800	16.70	2.04	1800		1800			1800			1800	
1920	16.79		1920		1920			1920			1920	
2040	16.91	2.04	2040		2040			2040			2040	
2160	17.16		2160		2160			2160			2160	
2280	17.27	2.06	2280		2280			2280			2280	
2400	17.41		2400		2400			2400			2400	
2520	17.55	2.02	2520		2520			2520			2520	
2640	17.63		2640		2640			2640			2640	
2760	17.78	2.02	2760		2760			2760			2760	
2880	17.94		2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880	W/L		W/L		W/L		W/L	
Average yield (l/s):				2.02								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



Ground water solutions t/a AB Pumps CC

BOREHOLE TEST RECORD

CONSULTANT: GEOS
DISTRICT: HANTAM
PROVINCE: NC
FARM / VILLAGE NAME: SANDGAT / CALVINIA
DATE TESTED: 15/09/2017

PROJECT #	P1848
BBR	
PRODUCTION BONUS:	
EC meter number	

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.49796**
LONGITUDE: _____ **OR** _____ **OR** **19.87455**

BOREHOLE NO: SANDGAT 3 BH04
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: SUBMERSIBLE
BOREHOLE DEPTH: (mbgl) 15.12

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	AVN
Date sample taken	18/07/2017		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	08h00						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	15.12
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	9.41
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	1	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P1848		MAP REFERENCE: 0				PROVINCE: NC				DISTRICT: HANTAM				
BOREHOLE NO: SANDGAT 3 BH04						SITE NAME: SANDGAT / CALVINIA								
ALT BH NO: 0														
ALT BH NO: 0														
BOREHOLE DEPTH (m): 15.12		DATUM LEVEL ABOVE CASING (m): 0.26				EXISTING PUMP: SUBMERSIBLE								
WATER LEVEL (mbdl): 8.41		CASING HEIGHT: (magl): 0.00				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 13.20		DIAMPUMP INLET (mm): 200.00				PUMP TYPE: BP50								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
DATE: 15/09/2017		TIME: 13H20			DATE: 15/09/2017		TIME: 14H20			DATE: 15/09/2017		TIME: 13H20		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	0.15		1		1	0.37		1		1	0.61		1	
2	0.17		2		2	0.38		2		2	0.63		2	
3	0.19		3		3	0.39		3		3	0.60	1.71	3	
5	0.22	0.59	5		5	0.41	1.10	5		5	0.69		5	
7	0.23		7		7	0.42		7		7	0.71	1.72	7	
10	0.24	0.57	10		10	0.44	1.10	10		10	0.73		10	
15	0.25		15		15	0.46		15		15	0.75	1.70	15	
20	0.26	0.58	20		20	0.48	1.11	20		20	0.77		20	
30	0.28		30		30	0.50		30		30	0.80	1.73	30	
40	0.30	0.29	40		40	0.52	1.10	40		40	0.84		40	
50	0.32		50		50	0.54		50		50	0.87	1.70	50	
60	0.34	0.57	60		60	0.57	1.12	60		60			60	
70			70		70			70		70			70	
80			80		80			80		80			80	
90			90		90			90		90			90	
100			100		100			100		100			100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP	19.50	°C	180		TEMP	19.10	°C	180		TEMP	19.20	°C	180	
EC	810.00	µS/cm	210		EC	820.00	µS/cm	210		EC	831.00	µS/cm	210	
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
DATE: 15/09/2017		TIME: 16H20			DATE: 15/09/2017		TIME: 17H20			DATE: 15/09/2017		TIME: 17H20		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	0.94		1		1	2.38		1	1.17	1			1	
2	0.97		2		1	3.16	4.20	2	0.92	2			2	
3	1.01		3		2	4.79		3	0.84	3			3	
5	1.03	2.66	5		2	4.79	2.94	5	0.79	5			5	
7	1.05		7		3	4.79	2.75	7	0.74	7			7	
10	1.09	2.63	10		3	4.79	2.51	10	0.69	10			10	
15	1.12		15					15	0.63	15			15	
20	1.14	2.65	20					20	0.59	20			20	
30	1.17		30					30	0.57	30			30	
40	1.20	2.64	40					40	0.54	40			40	
50	1.22		50					50	0.48	50			50	
60	1.25	2.67	60					60	0.43	60			60	
70			70					70		70			70	
80			80					80		80			80	
90			90					90		90			90	
100			100					100		100			100	
110			110					110		110			110	
120			120					120		120			120	
pH			150		pH			150		pH			150	
TEMP	17.20	°C	180		TEMP		°C	180		TEMP		°C	180	
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210	
			240					240					240	
			300					300					300	
			360					360					360	
S/WL:(mbch) 8.13														

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P1848			MAP REFERENCE: 31.49796				PROVINCE: NC		DISTRICT: HANTAM			
BOREHOLE NO: SANDGAT 3 BH04			19.87455				SITE NAME: SANDGAT / CALVINIA					
ALT BH NO: 0							EXISTING PUMP: SUBMERSIBLE		CONTRACTOR: AB PUMPS			
ALT BH NO: 0							PUMP TYPE: BP50					
BOREHOLE DEPTH: 15.12			DATUM LEVEL ABOVE CASING (m): 0.26				CONTRACTOR: AB PUMPS					
WATER LEVEL (mbdl): 8.61			CASING HEIGHT: (magl): 0.00				PUMP TYPE: BP50					
DEPTH OF PUMP (m): 13.20			DIAM PUMP INLET(mm): 200									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	16/09/2017	TIME:	08H10	DATE:		TIME:		TYPE OF PUMP:				BP50
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR: 39632		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m): 107		Distance(m):		Distance(m):		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	0.25		1	1.76	1			1			1	
2	0.36		2	1.61	2			2			2	
3	0.41		3	1.59	3			3			3	
5	0.47	2.26	5	1.58	5			5			5	
7	0.54		7	1.55	7			7			7	
10	0.62	2.28	10	1.53	10			10			10	
15	0.68		15	1.49	15			15			15	
20	0.73	2.25	20	1.45	20	0.00		20			20	
30	0.79		30	1.41	30	0.00		30			30	
40	0.85	2.27	40	1.38	40	0.00		40			40	
60	0.93		60	1.31	60	0.00		60			60	
90	1.01	2.25	90	1.25	90	0.00		90			90	
120	1.07		120	1.19	120	0.00		120			120	
150	1.12	2.27	150	1.12	150	0.00		150			150	
180	1.17		180	1.08	180	0.00		180			180	
210	1.21	2.26	210	1.06	210	0.00		210			210	
240	1.25		240	1.03	240	0.00		240			240	
300	1.32	2.28	300	0.97	300	0.00		300			300	
360	1.38		360	0.95	360	0.00		360			360	
420	1.45	2.28	420	0.91	420	0.00		420			420	
480	1.51		480	0.87	480	0.00		480			480	
540	1.53	2.26	540		540	0.00		540			540	
600	1.57		600		600	0.00		600			600	
720	1.62	2.25	720		720	0.00		720			720	
840	1.68		840		840	0.00		840			840	
960	1.74	2.27	960		960	0.00		960			960	
1080	1.81		1080		1080	0.00		1080			1080	
1200	1.89	2.25	1200		1200	0.00		1200			1200	
1320	1.96		1320		1320	0.00		1320			1320	
1440	2.03	2.28	1440		1440	0.00		1440			1440	
1560	2.10		1560		1560	0.00		1560			1560	
1680	2.18	2.25	1680		1680	0.00		1680			1680	
1800	2.26		1800		1800	0.00		1800			1800	
1920	2.34	2.28	1920		1920	0.00		1920			1920	
2040	2.43		2040		2040	0.00		2040			2040	
2160	2.49	2.25	2160		2160	0.00		2160			2160	
2280	2.53		2280		2280	0.00		2280			2280	
2400	2.58	2.27	2400		2400	0.00		2400			2400	
2520	2.62		2520		2520	0.00		2520			2520	
2640	2.67	2.25	2640		2640	0.00		2640			2640	
2760	2.73		2760		2760	0.00		2760			2760	
2880	2.77	2.25	2880		2880	0.00		2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880		W/L	9.06		W/L			W/L
Average yield (l/s):				2.25								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: PC
FARM / VILLAGE NAME: NC
 SANDGAT
DATE TESTED: 27/09/2017

PROJECT #	P1848
BBR	MORGAN
PRODUCTION BONUS:	
EC meter number	

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.50302**
LONGITUDE: _____ **OR** _____ **OR** **19.87588**

BOREHOLE NO: SANDGAT 4 BH05
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: SUBMERSIBLE PUMP
BOREHOLE DEPTH: (mbgl) 59.00

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	AVN
Date sample taken	29/09/2017		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	18H20						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	59.00
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	8.33
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E															
STEPPED DISCHARGE TEST & RECOVERY															
BOREHOLE TEST RECORD SHEET															
PROJ NO:		P1848		MAP REFERENCE:				0		PROVINCE:		PC			
BOREHOLE NO:		SANDGAT 4 BH05								DISTRICT:		CALVINIA			
ALT BH NO:		0								SITE NAME:		NC			
BOREHOLE DEPTH (m)		59.00		DATUM LEVEL ABOVE CASING (m):				0.12		EXISTING PUMP:		BP50			
WATER LEVEL (m):		8.59		CASING HEIGHT: (magl):				0.13		CONTRACTOR:		AB PUMPS			
DEPTH OF PUMP (m):		55.10		DIAMPUMP INLET (mm):				170.00		PUMP TYPE:		BP50			
STEPPED DISCHARGE TEST & RECOVERY															
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3					
RPM					RPM					RPM					
DATE:		27/09/2017		TIME:		13H15		DATE:		27/09/2017		TIME:		14H15	
DATE:		27/09/2017		TIME:		15H15		DATE:		27/09/2017		TIME:		15H15	
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	
1	1.81		1		1	15.53		1		1	25.47		1	40.89	
2	2.14		2		2	15.84		2		2	26.71	1.67	2	37.76	
3	2.42	0.67	3		3	16.01	1.04	3		3	28.12		3	35.33	
5	3.67		5		5	16.77		5		5	30.07	2.03	5	31.96	
7	4.01	0.65	7		7	17.25	1.04	7		7	35.16		7	26.30	
10	4.80		10		10	18.27		10		10	40.81	2.00	10	21.04	
15	6.75	0.67	15		15	20.09	1.03	15		15	46.51		15	12.86	
20	8.41		20		20	21.46		20		20	46.51	1.22	20	3.81	
30	11.45	0.68	30		30	23.05	1.00	30		30	46.51	1.03	30		
40	13.51		40		40	23.94		40		40	46.51	0.76	40		
50	14.54	0.67	50		50	24.61	1.02	50					50		
60	15.17		60		60	24.90		60					60		
70			70		70			70					70		
80			80		80			80					80		
90			90		90			90					90		
100			100		100			100					100		
110			110		110			110					110		
120			120		120			120					120		
pH			150		pH			150		pH			150		
TEMP	23.50	°C	180		TEMP	22.60	°C	180		TEMP		°C	180		
EC	6.24	µS/cm	210		EC	6.40	µS/cm	210		EC		µS/cm	210		
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6					
RPM					RPM					RPM					
DATE:				TIME:				DATE:				TIME:			
DATE:				TIME:				DATE:				TIME:			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	
1			1		1			1		1			1		
2			2		2			2		2			2		
3			3		3			3		3			3		
5			5		5			5		5			5		
7			7		7			7		7			7		
10			10		10			10		10			10		
15			15		15			15		15			15		
20			20		20			20		20			20		
30			30		30			30		30			30		
40			40		40			40		40			40		
50			50		50			50		50			50		
60			60		60			60		60			60		
70			70		70			70		70			70		
80			80		80			80		80			80		
90			90		90			90		90			90		
100			100		100			100		100			100		
110			110		110			110		110			110		
120			120		120			120		120			120		
pH			150		pH			150		pH			150		
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180		
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		
			240					240					240		
			300					300					300		
			360					360					360		
S/WL:(mbch) 8.32															

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P1848			MAP REFERENCE: 31.50302				PROVINCE: PC		DISTRICT: CALVINIA			
BOREHOLE NO: SANDGAT 4 BH05			19.87588				SITE NAME: NC					
ALT BH NO: 0												
ALT BH NO: 0												
BOREHOLE DEPTH: 59.00			DATUM LEVEL ABOVE CASING (m): 0.12				EXISTING PUMP: BP50					
WATER LEVEL (mbdl): 8.59			CASING HEIGHT: (magl): 0.13				CONTRACTOR: AB PUMPS					
DEPTH OF PUMP (m): 55.10			DIAM PUMP INLET(mm): 170				PUMP TYPE: BP50					
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	27/09/2017	TIME:	18H30	DATE:		TIME:		TYPE OF PUMP:	BP50			
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR:		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	1.66		1	16.06	1			1			1	
2	2.05		2	13.20	2			2			2	
3	2.65	0.75	3	11.36	3			3			3	
5	3.40	0.85	5	7.82	5			5			5	
7	4.65		7	4.38	7			7			7	
10	5.52	0.83	10	0.15	10			10			10	
15	7.08		15	0.13	15			15			15	
20	8.23	0.84	20	0.12	20			20			20	
30	9.85		30		30			30			30	
40	11.04	0.84	40		40			40			40	
60	14.45		60		60			60			60	
90	14.60	0.82	90		90			90			90	
120	14.73		120		120			120			120	
150	14.86	0.00	150		150			150			150	
180	14.98		180		180			180			180	
210	15.05	0.85	210		210			210			210	
240	15.12		240		240			240			240	
300	15.27	0.83	300		300			300			300	
360	15.37		360		360			360			360	
420	15.49	0.84	420		420			420			420	
480	15.56		480		480			480			480	
540	15.62	0.82	540		540			540			540	
600	15.68		600		600			600			600	
720	15.83	0.80	720		720			720			720	
840	15.91		840		840			840			840	
960	16.12	0.83	960		960			960			960	
1080	16.45		1080		1080			1080			1080	
1200	16.67	0.85	1200		1200			1200			1200	
1320	16.89		1320		1320			1320			1320	
1440	17.05	0.82	1440		1440			1440			1440	
1560	17.22		1560		1560			1560			1560	
1680	17.47	0.81	1680		1680			1680			1680	
1800	17.70		1800		1800			1800			1800	
1920	17.96	0.85	1920		1920			1920			1920	
2040	18.21		2040		2040			2040			2040	
2160	18.48	0.83	2160		2160			2160			2160	
2280	18.68		2280		2280			2280			2280	
2400	18.81	0.85	2400		2400			2400			2400	
2520	19.03		2520		2520			2520			2520	
2640	19.25	0.83	2640		2640			2640			2640	
2760	19.54		2760		2760			2760			2760	
2880	19.78	0.84	2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880	W/L		W/L		W/L		W/L	
Average yield (l/s):				0.80								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
rpm	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: NORTHERN CAPE
FARM / VILLAGE NAME : CALVINIA SANDGAT
DATE TESTED: 19/09/2017

PROJECT #	P1848
BBR	ISAAC
PRODUCTION BONUS:	CHRISTOPHER
	AMOS
	PIETER
	SIYABULELA
	AYANDA
EC meter number	

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **S31.50953**
LONGITUDE: _____ **OR** _____ **E019.85025**

BOREHOLE NO: SANDGAT 5 - BH 06
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: SUBMERSIBLE
BOREHOLE DEPTH: (mbgl) 197.80

COMMENTS: FIRST TEST WE INSTALLED 2.5 PUMP , WE WERE SUPPOSED TO MONITOR SANDGAT 5 BUT THE BOREHOLE IS DRY (18M - NO WATER)

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	KVN
Date sample taken	23/09/2017	If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	22H30					

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY	UNIT	QTY
STRAIGHTNESS TEST:	NO	NO	M	197.80
VERTICALLY TEST:	NO	NO	M	26.27
CASING DETECTION:	NO	YES	YES/NO	NO
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	NO	NO	YES
BOREHOLE MARKING	NO	NO	NO	NO
SITE CLEANING & FINISHING	NO	YES	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	NO	NO	NO

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E																								
STEPPED DISCHARGE TEST & RECOVERY																								
BOREHOLE TEST RECORD SHEET																								
PROJ NO:		P1848		MAP REFERENCE:				S31.50953				PROVINCE:		NORTHERN CAPE										
BOREHOLE NO:		SANDGAT 5 - BH 06						E019.85025				DISTRICT:		CALVINIA										
ALT BH NO:		0										SITE NAME:		CALVINIA SANDGAT										
ALT BH NO:		0																						
BOREHOLE DEPTH (m)				197.80				DATUM LEVEL ABOVE CASING (m):				0.75												
WATER LEVEL (mbdl):				20.91				CASING HEIGHT: (magl):				GROUND LEVEL												
DEPTH OF PUMP (m):				189.20				DIAMPUMP INLET (mm):				170.00												
								EXISTING PUMP:				SUBMERSIBLE												
								CONTRACTOR:				AB PUMPS												
								PUMP TYPE:				GW1302												
STEPPED DISCHARGE TEST & RECOVERY																								
DISCHARGE RATE 1				RPM		DISCHARGE RATE 2				RPM		DISCHARGE RATE 3				RPM								
DATE:		21/09/2017		TIME:		07H55		DATE:		21/09/2017		TIME:		08H55		DATE:		21/09/2017		TIME:		09H55		
TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY
(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)
1	0.22		1		1	3.95		1		1	6.11		1		1			1		1				
2	0.76		2		2	4.28	7.91	2		2	7.18		2		2			2		2				
3	1.03	5.05	3		3	4.40	8.05	3		3	7.72	10.50	3		3			3		3				
5	1.36		5		5	4.54		5		5	9.13		5		5			5		5				
7	1.74	5.07	7		7	4.58	8.04	7		7	9.91	12.09	7		7			7		7				
10	1.90		10		10	4.61		10		10	10.55		10		10			10		10				
15	2.06	5.04	15		15	4.70	8.08	15		15	11.64	12.04	15		15			15		15				
20	2.13		20		20	4.87		20		20	11.89		20		20			20		20				
30	2.19	5.08	30		30	5.34	8.09	30		30	12.21	12.07	30		30			30		30				
40	2.23		40		40	5.66		40		40	12.56		40		40			40		40				
50	2.29	5.07	50		50	5.78	8.05	50		50	12.93	12.11	50		50			50		50				
60	2.34		60		60	5.86		60		60	13.05		60		60			60		60				
70			70		70			70		70			70		70			70		70				
80			80		80			80		80			80		80			80		80				
90			90		90			90		90			90		90			90		90				
100			100		100			100		100			100		100			100		100				
110			110		110			110		110			110		110			110		110				
120			120		120			120		120			120		120			120		120				
pH			150		pH			150		pH			150		pH			150		150				
TEMP	20.20	°C	180		TEMP	22.80	°C	180		TEMP	24.00	°C	180		TEMP	24.00	°C	180		180				
EC	2340.00	µS/cm	210		EC	2576.00	µS/cm	210		EC	2743.00	µS/cm	210		EC	2743.00	µS/cm	210		210				
DISCHARGE RATE 4				RPM		DISCHARGE RATE 5				RPM		DISCHARGE RATE 6				RPM								
DATE:		21/09/2017		TIME:		10H55		DATE:		TIME:		DATE:		TIME:		DATE:		TIME:						
TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY
(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)
1	15.15		1	7.14	1			1		1			1		1			1		1				
2	16.81		2	5.04	2			2		2			2		2			2		2				
3	17.76	16.50	3	4.32	3			3		3			3		3			3		3				
5	18.03	18.02	5	3.88	5			5		5			5		5			5		5				
7	18.48		7	2.92	7			7		7			7		7			7		7				
10	19.96	18.08	10	2.81	10			10		10			10		10			10		10				
15	23.34		15	2.67	15			15		15			15		15			15		15				
20	24.14	18.04	20	2.48	20			20		20			20		20			20		20				
30	24.44		30		30			30		30			30		30			30		30				
40	25.02	18.09	40		40			40		40			40		40			40		40				
50	25.39		50		50			50		50			50		50			50		50				
60	25.74	18.07	60		60			60		60			60		60			60		60				
70			70		70			70		70			70		70			70		70				
80			80		80			80		80			80		80			80		80				
90			90		90			90		90			90		90			90		90				
100			100		100			100		100			100		100			100		100				
110			110		110			110		110			110		110			110		110				
120			120		120			120		120			120		120			120		120				
pH			150		pH			150		pH			150		pH			150		150				
TEMP	24.40	°C	180		TEMP		°C	180		TEMP		°C	180		TEMP		°C	180		180				
EC	2754.00	µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		210				
			240					240					240					240		240				
			300					300					300					300		300				
			360					360					360					360		360				
S/WL:(mbch)		20.22																						

FORM 5 F													
CONSTANT DISCHARGE TEST & RECOVERY													
BOREHOLE TEST RECORD SHEET													
PROJ NO:	P1848		MAP REFERENCE:		S31.50953			PROVINCE:		NORTHERN CAPE			
BOREHOLE NO:	SANDGAT 5 - BH 06				E019.85025			DISTRICT:		CALVINIA			
ALT BH NO:	0							SITE NAME:		CALVINIA SANDGAT			
BOREHOLE DEPTH:	197.80		DATUM LEVEL ABOVE CASING (m):		0.75			EXISTING PUMP:		SUBMERSIBLE			
WATER LEVEL (mbdl):	23.54		CASING HEIGHT: (magl):		GROUND			CONTRACTOR:		AB PUMPS			
DEPTH OF PUMP (m):	189.20		DIAM PUMP INLET(mm):		170			PUMP TYPE:		GW1302			
CONSTANT DISCHARGE TEST & RECOVERY													
TEST STARTED						TEST COMPLETED							
DATE:	22/09/2017		TIME:	06H40		DATE:	21/09/2017		TIME:	18H30		TYPE OF PUMP:	GW1302
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3			
						NR:		NR:		NR:			
DISCHARGE BOREHOLE						Distance(m);			Distance(m);			Distance(m);	
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	
1	0.12		1	6.23	1			1			1		
2	0.28		2	6.04	2			2			2		
3	0.44		3	5.75	3			3			3		
5	1.08	5.09	5	5.49	5			5			5		
7	1.26		7	5.36	7			7			7		
10	1.53	5.06	10	5.12	10			10			10		
15	1.64		15	4.98	15			15			15		
20	1.83	5.04	20	4.89	20			20			20		
30	1.98		30	4.80	30			30			30		
40	2.04	5.03	40	4.69	40			40			40		
60	2.15		60	4.61	60			60			60		
90	2.38	5.08	90	4.56	90			90			90		
120	2.50		120	4.49	120			120			120		
150	2.62	5.06	150	4.42	150			150			150		
180	2.71		180	4.36	180			180			180		
210	2.79	5.08	210	4.29	210			210			210		
240	2.86		240	4.23	240			240			240		
300	2.94	5.03	300	4.14	300			300			300		
360	3.09		360	4.07	360			360			360		
420	3.21	5.09	420	3.99	420			420			420		
480	3.32		480	3.91	480			480			480		
540	3.46	5.06	540		540			540			540		
600	3.53		600		600			600			600		
720	3.89	5.02	720		720			720			720		
840	4.03		840		840			840			840		
960	4.28	5.01	960		960			960			960		
1080	4.51		1080		1080			1080			1080		
1200	4.76	5.04	1200		1200			1200			1200		
1320	5.02		1320		1320			1320			1320		
1440	5.37	5.02	1440		1440			1440			1440		
1560	5.56		1560		1560			1560			1560		
1680	5.82	5.07	1680		1680			1680			1680		
1800	6.08		1800		1800			1800			1800		
1920	6.33	5.08	1920		1920			1920			1920		
2040	6.58		2040		2040			2040			2040		
2160	6.84	5.06	2160		2160			2160			2160		
2280	7.14		2280		2280			2280			2280		
2400	7.39	5.08	2400		2400			2400			2400		
2520			2520		2520			2520			2520		
2640			2640		2640			2640			2640		
2760			2760		2760			2760			2760		
2880			2880		2880			2880			2880		
3000			3000		3000			3000			3000		
3120			3120		3120			3120			3120		
3240			3240		3240			3240			3240		
3360			3360		3360			3360			3360		
3480			3480		3480			3480			3480		
3600			3600		3600			3600			3600		
3720			3720		3720			3720			3720		
3840			3840		3840			3840			3840		
3960			3960		3960			3960			3960		
4080			4080		4080			4080			4080		
4200			4200		4200			4200			4200		
4320			4320		4320			4320			4320		
Total time pumped(min):				2400	W/L		W/L		W/L		W/L		
Average yield (l/s):				5.08									

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: NC
FARM / VILLAGE NAME : DEON VLOK
DATE TESTED: 26/09/2017

PROJECT #	P1848
BBR	
PRODUCTION BONUS:	AMOS
	FRANS
EC meter number	

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.48128**
LONGITUDE: _____ **OR** _____ **OR** **19.96844**

BOREHOLE NO: G-39972
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: SUBMERSIBLE
BOREHOLE DEPTH: (mbdl) 249.37

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	AVN
Date sample taken	29/09/2017		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	17H30						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	249.37
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	28.39
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	2	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E															
STEPPED DISCHARGE TEST & RECOVERY															
BOREHOLE TEST RECORD SHEET															
PROJ NO: P1848		MAP REFERENCE: 0		PROVINCE: NC		DISTRICT: CALVINIA		SITE NAME: DEON VLOK							
BOREHOLE NO: G-39972															
ALT BH NO: 0															
ALT BH NO: 0															
BOREHOLE DEPTH (m): 249.37		DATUM LEVEL ABOVE CASING (m): 0.42		EXISTING PUMP: SUBMERSIBLE		CONTRACTOR: AB PUMPS		PUMP TYPE: GW9002							
WATER LEVEL (mbdl): 22.60		CASING HEIGHT: (magl): 0.10													
DEPTH OF PUMP (m): 150.00		DIAMPUMP INLET (mm): 210.00													
STEPPED DISCHARGE TEST & RECOVERY															
DISCHARGE RATE 1				RPM 380	DISCHARGE RATE 2				RPM 669	DISCHARGE RATE 3				RPM 795	
DATE: 26/09/2017		TIME: 10H40		DATE: 26/09/2017		TIME: 11H40		DATE: 26/09/2017		TIME: 12H40					
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	
1	0.03		1		1	0.77	4.89	1		1	3.01	12.06	1		
2	0.05	2.09	2		2	0.84	5.74	2		2	3.12		2		
3	0.08	2.86	3		3	0.87	8.02	3		3	3.14		3		
5	0.09		5		5	0.89		5		5	3.19		5		
7	0.10		7		7	0.91		7		7	3.24		7		
10	0.16		10		10	0.95	8.05	10		10	3.27	12.08	10		
15	0.21	2.81	15		15	1.09		15		15	3.41		15		
20	0.29		20		20	1.21		20		20	3.52	12.12	20		
30	0.35	2.84	30		30	1.52	8.01	30		30	3.64		30		
40	0.40		40		40	1.81		40		40	3.79	12.02	40		
50	0.43	2.80	50		50	2.12	8.00	50		50	3.90		50		
60	0.47		60		60	2.24		60		60	3.99	12.01	60		
70			70		70			70		70			70		
80			80		80			80		80			80		
90			90		90			90		90			90		
100			100		100			100		100			100		
110			110		110			110		110			110		
120			120		120			120		120			120		
pH			150		pH			150		pH			150		
TEMP	17.90	°C	180		TEMP	19.70	°C	180		TEMP	21.60	°C	180		
EC	1168.00	µS/cm	210		EC	1142.00	µS/cm	210		EC	1124.00	µS/cm	210		
DISCHARGE RATE 4				RPM	DISCHARGE RATE 5				RPM	DISCHARGE RATE 6				RPM	
DATE: 26/09/2017		TIME: 13H40		DATE:		TIME:		DATE:		TIME:					
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	
1	4.97	15.31	1	3.37	1			1		1			1		
2	5.34	18.11	2	3.29	2			2		2			2		
3	5.78		3	3.23	3			3		3			3		
5	6.03		5	3.10	5			5		5			5		
7	6.28		7	3.05	7			7		7			7		
10	6.40	18.20	10	2.90	10			10		10			10		
15	6.67		15	2.73	15			15		15			15		
20	6.80	18.24	20	2.47	20			20		20			20		
30	7.10		30	2.15	30			30		30			30		
40	7.36	18.16	40	1.89	40			40		40			40		
50	7.63		50	1.68	50			50		50			50		
60	7.89	18.21	60	1.56	60			60		60			60		
70			70	1.36	70			70		70			70		
80			80	1.17	80			80		80			80		
90			90	1.10	90			90		90			90		
100			100	1.06	100			100		100			100		
110			110	1.02	110			110		110			110		
120			120	0.95	120			120		120			120		
pH			150	0.78	pH			150		pH			150		
TEMP	20.40	°C	180		TEMP		°C	180		TEMP		°C	180		
EC	1137.00	µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		
			240					240					240		
			300					300					300		
			360					360					360		
S/WL:(mbch) 22.19															

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P1848			MAP REFERENCE: 31.48128				PROVINCE: NC		DISTRICT: CALVINIA			
BOREHOLE NO: G-39972			19.96844				SITE NAME: DEON VLOK					
ALT BH NO: 0												
ALT BH NO: 0												
BOREHOLE DEPTH: 249.37			DATUM LEVEL ABOVE CASING (m): 0.42				EXISTING PUMP: SUBMERSIBLE					
WATER LEVEL (mbdl): 23.38			CASING HEIGHT: (magl): 0.10				CONTRACTOR: AB PUMPS					
DEPTH OF PUMP (m): 150.00			DIAM PUMP INLET(mm): 210				PUMP TYPE: GW9002					
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	26/09/2017	TIME:	18h00	DATE:		TIME:		TYPE OF PUMP:	GW9002			
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR: G39594		NR: G39595		NR:		
DISCHARGE BOREHOLE						Distance(m): 23.5		Distance(m): 16.8		Distance(m):		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery	TIME (min)	Drawdown (m)
1	0.86		1	9.07	1		8.84	1			1	
2	1.29	14.62	2	9.05	2		8.82	2		DRY	2	
3	2.45	16.04	3	8.94	3		8.80	3			3	
5	2.77		5	8.86	5		8.74	5			5	
7	3.01		7	8.82	7		8.67	7			7	
10	3.14		10	8.74	10		8.57	10			10	
15	3.25		15	8.62	15		8.45	15			15	
20	3.38	16.05	20	8.49	20	2.04	8.31	20			20	
30	3.74		30	8.32	30		8.14	30		DRY	30	
40	4.01	16.05	40	8.14	40		8.01	40			40	
60	4.69		60	8.01	60	2.04	7.87	60	0.00		60	
90	5.10	16.02	90	7.84	90		7.72	90			90	
120	5.41		120	7.73	120	2.65	7.58	120	0.00		120	
150	5.79	16.00	150	7.52	150		7.32	150			150	
180	5.92		180	7.35	180	2.94	7.16	180	0.79	DRY	180	
210	6.04	16.09	210	7.19	210		7.03	210			210	
240	6.18		240	6.99	240	3.27	6.69	240	1.12		240	
300	6.39	16.12	300	6.71	300	3.59	6.55	300	1.30		300	
360	6.82		360	6.59	360	3.87	6.48	360	1.57		360	
420	6.98	16.07	420	6.45	420	4.09	6.35	420	1.72		420	
480	7.23		480	6.33	480	4.55	6.12	480	2.11	DRY	480	
540	7.54	16.02	540		540	4.89		540	2.21		540	
600	7.75		600		600	5.02		600	2.33		600	
720	7.97	16.05	720		720	5.23		720	2.51		720	
840	8.20		840		840	5.48		840	2.59		840	
960	8.41	16.03	960		960	5.72		960	2.67		960	
1080	8.60		1080		1080	5.90		1080	2.81		1080	
1200	8.79	16.05	1200		1200	6.10		1200	2.97		1200	
1320	8.94		1320		1320	6.24		1320	3.50		1320	
1440	9.15	16.02	1440		1440	6.36		1440	3.88		1440	
1560	9.39		1560		1560	6.59		1560	4.12		1560	
1680	9.62	16.05	1680		1680	6.71		1680	4.49		1680	
1800	9.83	16.08	1800		1800	6.88		1800	4.82		1800	
1920	9.91		1920		1920	6.95		1920	5.01		1920	
2040	9.96	16.08	2040		2040	7.11		2040	5.43		2040	
2160	10.02		2160		2160	7.35		2160	5.87		2160	
2280	10.08	16.01	2280		2280	7.50		2280	5.93		2280	
2400	10.28		2400		2400	7.60		2400	6.24		2400	
2520	10.36	16.06	2520		2520	7.69		2520	6.54		2520	
2640	10.53		2640		2640	7.80		2640	6.65		2640	
2760	10.68	16.03	2760		2760	7.94		2760	DRY		2760	
2880	10.79		2880		2880	8.09		2880			2880	
3000	10.92	16.02	3000		3000	8.16		3000			3000	
3120	11.08		3120		3120	8.33		3120			3120	
3240	11.24	16.08	3240		3240	8.48		3240			3240	
3360	11.31		3360		3360	8.54		3360			3360	
3480	11.36	16.04	3480		3480	8.69		3480			3480	
3600	11.41		3600		3600	8.78		3600			3600	
3720	11.50	16.06	3720		3720	8.80		3720			3720	
3840	11.54		3840		3840	8.89		3840			3840	
3960	11.56	16.01	3960		3960	8.95		3960			3960	
4080	11.59		4080		4080	8.96		4080			4080	
4200	11.61	16.05	4200		4200	8.97		4200			4200	
4320	11.62		4320		4320	8.98		4320			4320	
Total time pumped(min):				4320		W/L	23.45		W/L	23.07		W/L
Average yield (l/s):				16.07								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
rpm	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOSS _____
DISTRICT: CALVINIA _____
PROVINCE: NORTHERN CAPE _____
FARM / VILLAGE NAME : CALVINIA _____
DATE TESTED: 21/09/2017 _____

PROJECT #	P1848
BBR	PIETER MUNYAI
PRODUCTION BONUS:	AMOS
	CHRISTOPHER
	SIYA
	AYANDA
	ISAAC
EC meter number	

MAP REFERENCE: _____

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **S31.48297**
LONGITUDE: _____ **OR** _____ **E10.76389**

BOREHOLE NO: GOLD COURSE _____
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: SUBMERSIBLE PUMP _____
BOREHOLE DEPTH: (mbgl) 225.90 _____

COMMENTS: ROD STRIPPED AT THE 4TH STEP SO WE HAD TO REMOVE IT TO FIX IT, SO WE DID OTHER STEPS ON HIGH RATE

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	KVN
Date sample taken	25/09/2017	If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	08H20					

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	NO	BOREHOLE DEPTH AFTER TEST:	M	225.90
VERTICALLY TEST:	NO	NO	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	58.08
CASING DETECTION:	NO	YES	SAND/GRAVEL/SILT PUMPED?	YES/NO	NO
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	NO	DATA REPORTING AND RECORDING	NO	YES
BOREHOLE MARKING	NO	NO	SLUG TEST:	NO	NO
SITE CLEANING & FINISHING	NO	YES	LAYFLAT (M):	M	50
LOGGERS FOR WATERLEVEL MONITORING	NO	NO	LOGGERS FOR pH AND EC:	NO	NO

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____

FORM 5 E																	
STEPPED DISCHARGE TEST & RECOVERY																	
BOREHOLE TEST RECORD SHEET																	
PROJ NO: P1848		MAP REFERENCE: S31.48297				PROVINCE: NORTHERN CAPE											
BOREHOLE NO: GOLD COURSE		E10.76389				DISTRICT: CALVINIA											
ALT BH NO: 0						SITE NAME: CALVINIA											
ALT BH NO: 0																	
BOREHOLE DEPTH (m): 225.90		DATUM LEVEL ABOVE CASING (m): 0.52				EXISTING PUMP: SUBMERSIBLE											
WATER LEVEL (mbdl): 36.39		CASING HEIGHT: (magl): 0.03				CONTRACTOR: AB PUMPS											
DEPTH OF PUMP (m): 100.00		DIAMPUMP INLET (mm): 210.00				PUMP TYPE: BP50											
STEPPED DISCHARGE TEST & RECOVERY																	
DISCHARGE RATE 1				RPM		DISCHARGE RATE 2				RPM		DISCHARGE RATE 3				RPM	
DATE: 22/09/2017		TIME: 10H20				DATE: 22/09/2017		TIME: 11H20				DATE: 22/09/2017		TIME: 12H20			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)
1	1.47		1		1	12.79	6.89	1		1	23.41		1		2		29.42
2	1.81		2		2	13.46		2		2	23.62	11.63	2		2		29.24
3	2.20	5.03	3		3	13.64	7.04	3		3	24.19		3		3		29.05
5	2.76		5		5	14.00		5		5	25.11	12.03	5		5		28.79
7	3.14		7		7	14.45		7		7	25.63		7		7		28.59
10	3.53	5.00	10		10	15.48	7.02	10		10	26.06		10		10		28.40
15	4.90		15		15	17.02		15		15	27.21	12.05	15		15		28.00
20	5.90		20		20	18.04		20		20	28.44		20		20		27.60
30	8.29	5.04	30		30	18.72	7.06	30		30	30.41		30		30		27.15
40	9.62		40		40	20.01		40		40	31.53	12.04	40		40		27.00
50	10.65		50		50	21.64		50		50	32.64		50		50		26.75
60	12.00		60		60	22.37		60		60	33.07		60		60		25.60
70			70		70			70		70			70		70		25.36
80			80		80			80		80			80		80		25.10
90			90		90			90		90			90		90		25.00
100			100		100			100		100			100		100		24.90
110			110		110			110		110			110		110		24.75
120			120		120			120		120			120		120		24.32
pH			150		pH			150		pH			150		150		23.40
TEMP	23.20	°C	180		TEMP	22.50	°C	180		TEMP		°C	180		180		23.13
EC	80.00	µS/cm	210		EC	80.00	µS/cm	210		EC		µS/cm	210		210		22.53
DISCHARGE RATE 4				RPM		DISCHARGE RATE 5				RPM		DISCHARGE RATE 6				RPM	
DATE: 21/09/2017		TIME: 21H00				DATE:		TIME:				DATE:		TIME: 420		20.30	
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)
1	13.85		1	12.40	1			1		1			1		960		14.86
2	14.02		2	12.39	2			2		2			2		1140		12.75
3	14.39		3	12.33	3			3		3			3				
5			5	12.25	5			5		5			5				
7			7	12.18	7			7		7			7				
10			10	12.12	10			10		10			10				
15			15	11.95	15			15		15			15				
20			20	11.70	20			20		20			20				
30			30	11.43	30			30		30			30				
40			40	11.27	40			40		40			40				
50			50	11.12	50			50		50			50				
60			60	10.97	60			60		60			60				
70			70	10.76	70			70		70			70				
80			80	10.55	80			80		80			80				
90			90	10.30	90			90		90			90				
100			100	10.12	100			100		100			100				
110			110	9.59	110			110		110			110				
120			120	9.03	120			120		120			120				
pH			150	8.67	pH			150		pH			150				
TEMP		°C	180	8.14	TEMP		°C	180		TEMP		°C	180				
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210				
			240					240					240				
			300					300					300				
			360					360					360				
S/WL:(mbch) 31.13																	

FORM 5 F															
CONSTANT DISCHARGE TEST & RECOVERY															
BOREHOLE TEST RECORD SHEET															
PROJ NO:	P1848				MAP REFERENCE:	S31.48297				PROVINCE:	NORTHERN CAPE				
BOREHOLE NO:	GOLD COURSE					E10.76389				DISTRICT:	CALVINIA				
ALT BH NO:	0									SITE NAME:	CALVINIA				
ALT BH NO:	0														
BOREHOLE DEPTH:	225.90				DATUM LEVEL ABOVE CASING (m):	0.52				EXISTING PUMP:	SUBMERSIBLE				
WATER LEVEL (mbdl):	48.74				CASING HEIGHT: (magl):	0.03				CONTRACTOR:	AB PUMPS				
DEPTH OF PUMP (m):	100.00				DIAM PUMP INLET(mm):	210				PUMP TYPE:	BP50				
CONSTANT DISCHARGE TEST & RECOVERY															
TEST STARTED						TEST COMPLETED									
DATE:	23/09/2017			TIME:	08H30		DATE:	25/09/2017		TIME:	16H30		TYPE OF PUMP:	BP50	
						OBSERVATION HOLE 1	OBSERVATION HOLE 2				OBSERVATION HOLE 3				
						NR:	NR:				NR:				
DISCHARGE BOREHOLE						Distance(m);			Distance(m);			Distance(m);			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)			
1	0.46		1	29.83	1			1			1				
2	0.61		2	29.80	2			2			2				
3	0.71	2.87	3	29.77	3			3			3				
5	1.00		5	29.74	5			5			5				
7	1.25	3.03	7	29.72	7			7			7				
10	1.55		10	29.69	10			10			10				
15	2.00		15	29.63	15			15			15				
20	2.40	3.02	20	29.59	20			20			20				
30	3.53		30	29.53	30			30			30				
40	4.79		40	29.47	40			40			40				
60	5.60	3.00	60	29.34	60			60			60				
90	7.05		90	29.19	90			90			90				
120	8.70		120	29.04	120			120			120				
150	9.97	3.04	150	28.92	150			150			150				
180	11.00		180	28.85	180			180			180				
210	12.08		210	28.71	210			210			210				
240	12.77	3.03	240	28.63	240			240			240				
300	14.70		300	28.44	300			300			300				
360	15.79		360	28.22	360			360			360				
420	17.00	3.05	420	28.06	420			420			420				
480	17.81		480	27.03	480			480			480				
540	18.72	3.05	540		540			540			540				
600	19.67		600		600			600			600				
720	20.84	3.03	720		720			720			720				
840	21.46		840		840			840			840				
960	22.55	3.04	960		960			960			960				
1080	23.73		1080		1080			1080			1080				
1200	24.19	3.04	1200		1200			1200			1200				
1320	25.33		1320		1320			1320			1320				
1440	25.91	3.02	1440		1440			1440			1440				
1560	26.37		1560		1560			1560			1560				
1680	26.83	3.00	1680		1680			1680			1680				
1800	27.22		1800		1800			1800			1800				
1920	27.74	3.05	1920		1920			1920			1920				
2040	28.13		2040		2040			2040			2040				
2160	28.62	3.03	2160		2160			2160			2160				
2280	28.97		2280		2280			2280			2280				
2400	29.48	3.01	2400		2400			2400			2400				
2520	29.71		2520		2520			2520			2520				
2640	30.04	3.04	2640		2640			2640			2640				
2760	30.36		2760		2760			2760			2760				
2880	30.67	3.02	2880		2880			2880			2880				
3000			3000		3000			3000			3000				
3120			3120		3120			3120			3120				
3240			3240		3240			3240			3240				
3360			3360		3360			3360			3360				
3480			3480		3480			3480			3480				
3600			3600		3600			3600			3600				
3720			3720		3720			3720			3720				
3840			3840		3840			3840			3840				
3960			3960		3960			3960			3960				
4080			4080		4080			4080			4080				
4200			4200		4200			4200			4200				
4320			4320		4320			4320			4320				
Total time pumped(min):				2880	W/L			W/L			W/L				
Average yield (l/s):				3.02											

FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P1848		MAP REFERENCE: 0				PROVINCE: NC				DISTRICT: HANTAM				
BOREHOLE NO: WITVAL BH03						SITE NAME: WITVAL / CALVINIA								
ALT BH NO: 0														
ALT BH NO: 0														
BOREHOLE DEPTH (m): 193.80		DATUM LEVEL ABOVE CASING (m): 0.50				EXISTING PUMP: SUBMERSIBLE								
WATER LEVEL (mbdl): 22.90		CASING HEIGHT: (magl): 0.00				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 91.10		DIAMPUMP INLET (mm): 170.00				PUMP TYPE: BP50								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
RPM					RPM					RPM				
DATE: 26/09/2017		TIME: 16H30			DATE: 26/09/2017		TIME: 17H30			DATE: 26/09/2017		TIME: 18H30		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	0.09		1		1	0.73		1		1	3.02		1	
2	0.13		2		2	0.79		2		2	3.78		2	
3	0.16		3		3	0.86		3		3	4.06		3	
5	0.18	0.68	5		5	0.95	3.01	5		5	4.42	10.12	5	
7	0.19		7		7	1.02		7		7	4.73		7	
10	0.21	0.68	10		10	1.07	3.01	10		10	4.91	10.10	10	
15	0.25		15		15	1.15		15		15	5.23		15	
20	0.29	0.67	20		20	1.20	3.03	20		20	5.45	10.09	20	
30	0.34		30		30	1.32		30		30	5.82		30	
40	0.38	0.69	40		40	1.39	3.02	40		40	5.94	10.13	40	
50	0.40		50		50	1.45		50		50	6.09		50	
60	0.42	0.67	60		60	1.52	3.02	60		60	6.35	10.11	60	
70			70		70			70		70			70	
80			80		80			80		80			80	
90			90		90			90		90			90	
100			100		100			100		100			100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP	22.00	°C	180		TEMP	21.80	°C	180		TEMP	20.10	°C	180	
EC	550.00	µS/cm	210		EC	543.00	µS/cm	210		EC	545.00	µS/cm	210	
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
RPM					RPM					RPM				
DATE: 26/09/2017		TIME: 19H30			DATE:		TIME:			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	7.06		1	5.24	1			1		1			1	
2	7.12		2	4.53	2			2		2			2	
3	7.44		3	4.28	3			3		3			3	
5	7.53	12.26	5	4.06	5			5		5			5	
7	7.62		7	3.81	7			7		7			7	
10	7.73	12.24	10	3.40	10			10		10			10	
15	7.89		15	3.23	15			15		15			15	
20	8.04	12.26	20	3.05	20			20		20			20	
30	8.29		30	2.93	30			30		30			30	
40	8.49	12.26	40	2.86	40			40		40			40	
50	8.71		50	2.75	50			50		50			50	
60	8.89	12.25	60	2.66	60			60		60			60	
70			70	2.52	70			70		70			70	
80			80	2.40	80			80		80			80	
90			90	2.34	90			90		90			90	
100			100	2.21	100			100		100			100	
110			110	2.13	110			110		110			110	
120			120	1.90	120			120		120			120	
pH			150	1.63	pH			150		pH			150	
TEMP	19.10	°C	180	1.40	TEMP		°C	180		TEMP		°C	180	
EC	550.00	µS/cm	210	1.25	EC		µS/cm	210		EC		µS/cm	210	
			240	1.08				240					240	
			300					300					300	
			360					360					360	
S/WL:(mbch) 22.4														

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P1848			MAP REFERENCE: 31.45243			PROVINCE: NC			DISTRICT: HANTAM			
BOREHOLE NO: WITWAL BH03			19.8114			SITE NAME: WITVAL / CALVINIA						
ALT BH NO: 0						EXISTING PUMP: SUBMERSIBLE			CONTRACTOR: AB PUMPS			
ALT BH NO: 0						PUMP TYPE: BP50						
BOREHOLE DEPTH: 193.80			DATUM LEVEL ABOVE CASING (m): 0.50									
WATER LEVEL (mbdl): 23.80			CASING HEIGHT: (magl): 0.00									
DEPTH OF PUMP (m): 91.10			DIAM PUMP INLET(mm): 170									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	27/09/2017	TIME:	07H30	DATE:		TIME:		TYPE OF PUMP:		BP50		
OBSERVATION HOLE 1						OBSERVATION HOLE 2			OBSERVATION HOLE 3			
NR: WITWAL BH01						NR:			NR:			
DISCHARGE BOREHOLE						Distance(m): 51.3			Distance(m):			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	1.98		1	16.56	1		14.10	1			1	
2	2.17		2	16.40	2		14.05	2			2	
3	2.79		3	16.28	3		13.96	3			3	
5	3.32	10.03	5	16.02	5		13.87	5			5	
7	3.60		7	15.84	7		13.74	7			7	
10	3.93	10.03	10	15.61	10	0.21	13.61	10			10	
15	4.30		15	15.24	15	0.44	13.40	15			15	
20	4.52	10.02	20	15.09	20	0.61	13.22	20			20	
30	4.97		30	14.80	30	0.94	13.04	30			30	
40	5.28	10.01	40	14.58	40	1.26	12.83	40			40	
60	5.87		60	14.26	60	1.70	12.50	60			60	
90	6.36	10.03	90	13.92	90	2.17	12.27	90			90	
120	6.82		120	13.65	120	2.60	11.97	120			120	
150	7.17	10.05	150	13.30	150	2.93	11.73	150			150	
180	7.52		180	13.06	180	3.31	11.54	180			180	
210	7.80	10.02	210	12.84	210	3.54	11.38	210			210	
240	8.12		240	12.72	240	3.86	11.21	240			240	
300	8.59	10.04	300	12.34	300	4.30	10.97	300			300	
360	9.02		360	12.06	360	4.60	10.72	360			360	
420	9.50	10.01	420	11.89	420	5.11	10.55	420			420	
480	9.90		480	11.42	480	5.50	10.30	480			480	
540	10.26	10.03	540		540	5.77		540			540	
600	10.60		600		600	6.09		600			600	
720	11.30	10.04	720		720	6.70		720			720	
840	11.85		840		840	7.27		840			840	
960	12.30	10.02	960		960	7.70		960			960	
1080	12.89		1080		1080	8.29		1080			1080	
1200	13.34	10.04	1200		1200	8.60		1200			1200	
1320	13.78		1320		1320	8.98		1320			1320	
1440	14.35	10.03	1440		1440	9.62		1440			1440	
1560	14.86		1560		1560	10.09		1560			1560	
1680	15.24	10.01	1680		1680	10.45		1680			1680	
1800	15.79		1800		1800	10.97		1800			1800	
1920	16.17	10.04	1920		1920	11.28		1920			1920	
2040	16.63		2040		2040	11.70		2040			2040	
2160	17.00	10.02	2160		2160	12.13		2160			2160	
2280	17.46		2280		2280	12.45		2280			2280	
2400	17.95	10.03	2400		2400	12.81		2400			2400	
2520	18.78		2520		2520	13.26		2520			2520	
2640	18.64	10.01	2640		2640	13.69		2640			2640	
2760	18.97		2760		2760	13.85		2760			2760	
2880	19.30	10.04	2880		2880	14.16		2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880	W/L		23.39	W/L			W/L	
Average yield (l/s):				10.04								


FORM 5 E			
STEPPED DISCHARGE TEST & RECOVERY			
BOREHOLE TEST RECORD SHEET			
PROJ NO:	P2009	MAP REFERENCE:	0
BOREHOLE NO:	CAL-DV01	PROVINCE:	WC
ALT BH NO:	0	DISTRICT:	CALVINIA
ALT BH NO:	0	SITE NAME:	0
BOREHOLE DEPTH (m)	151.26	DATUM LEVEL ABOVE CASING (m)	0.71
		EXISTING PUMP:	0

FORM 5 F														
CONSTANT DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009			MAP REFERENCE: 31.4553			PROVINCE: WC			DISTRICT: CALVINIA			SITE NAME: 0		
BOREHOLE NO: CAL-DV01			19.77385			EXISTING PUMP: 0			CONTRACTOR: AB PUMPS			PUMP TYPE: WA110-2		
ALT BH NO: 0						DATUM LEVEL ABOVE CASING (m): 0.71			CASING HEIGHT: (magl): 0.15			DIAM PUMP INLET(mm): 221		
BOREHOLE DEPTH: 151.26						WATER LEVEL (mbdl): 88.76								
DEPTH OF PUMP (m): 124.30														
CONSTANT DISCHARGE TEST & RECOVERY														
TEST STARTED						TEST COMPLETED								
DATE:	12/05/2018		TIME:	10H00		DATE:			TIME:			TYPE OF PUMP:	WA110-2	
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3				
						NR:		NR:		NR:				
DISCHARGE BOREHOLE						Distance(m);			Distance(m);			Distance(m);		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)		
1	1.39		1	31.47	1			1			1			
2	1.59		2	31.12	2			2			2			
3	1.72	9.10	3	30.10	3			3			3			
5	1.96	11.49	5	28.97	5			5			5			
7	3.97	13.29	7	28.47	7			7			7			
10	4.77	15.06	10	27.94	10			10			10			
15	5.97	15.06	15	27.30	15			15			15			
20	6.89	15.06	20	26.84	20			20			20			
30	8.57	15.05	30	25.62	30			30			30			
40	9.72	15.06	40	25.27	40			40			40			
60	11.80	15.06	60	24.60	60			60			60			
90	14.19	15.07	90	23.49	90			90			90			
120	16.76	15.04	120	22.43	120			120			120			
150	16.42	15.06	150	21.78	150			150			150			
180	20.18	15.00	180	21.12	180			180			180			
210	21.78	15.04	210	20.80	210			210			210			
240	23.20	15.05	240	19.47	240			240			240			
300	24.80	15.06	300	18.67	300			300			300			
360	28.03	15.01	360	17.10	360			360			360			
420	30.33	15.03	420	16.35	420			420			420			
480	32.45	15.05	480	15.77	480			480			480			
540	34.81		540	14.87	540			540			540			
	34.81	14.54	600	14.16	600			600			600			
	34.81	14.08	720	13.21	720			720			720			
	34.81	13.99	840	11.55	840			840			840			
			960	10.35	960			960			960			
			1080	9.25	1080			1080			1080			
			1200	8.10	1200			1200			1200			
			1320	7.18	1320			1320			1320			
			1440	6.32	1440			1440			1440			
			1560	5.97	1560			1560			1560			
			1680	5.32	1680			1680			1680			
			1800	4.53	1800			1800			1800			
			1920	3.90	1920			1920			1920			
			2040	2.22	2040			2040			2040			
			2160	1.38	2160			2160			2160			
			2280		2280			2280			2280			
			2400		2400			2400			2400			
			2520		2520			2520			2520			
			2640		2640			2640			2640			
			2760		2760			2760			2760			
			2880		2880			2880			2880			
			3000		3000			3000			3000			
			3120		3120			3120			3120			
			3240		3240			3240			3240			
			3360		3360			3360			3360			
			3480		3480			3480			3480			
			3600		3600			3600			3600			
			3720		3720			3720			3720			
			3840		3840			3840			3840			
			3960		3960			3960			3960			
			4080		4080			4080			4080			
			4200		4200			4200			4200			
			4320		4320			4320			4320			
Total time pumped(min):				540	W/L				W/L				W/L	
Average yield (l/s):				15.05										

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
rpm	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: NORTHERN CAPE
FARM / VILLAGE NAME:
DATE TESTED: 19/05/2018

PROJECT #	P2009
BBR	JOHAN
PRODUCTION BONUS:	ABEL
	ERNEST
	SIMON
	BRIGHT
	HENRY
EC meter number	#51

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: hddd ° mm ' ss.s " hddd ° mm.mmm ' hddd.ddddd

LATITUDE: ° ' " OR ° ' " OR 31.41163
LONGITUDE: ° ' " OR ° ' " OR 19.77509

BOREHOLE NO: CAL-DV 4
TRANSMISSIVITY VALUE:
TYPE INSTALLATION: NEW BOREHOLE
BOREHOLE DEPTH: (mbgl) 205.00

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	NAOMI
Date sample taken	21/05/2018		If consultant took sample, give name:			DATA CHECKED BY:	ALENE
Time sample taken	08H00						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY	DESCRIPTION:	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	205.00
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	14.51
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	30
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E															
STEPPED DISCHARGE TEST & RECOVERY															
BOREHOLE TEST RECORD SHEET															
PROJ NO: P2009		MAP REFERENCE: 31.41163		PROVINCE: NORTHERN CAPE		BOREHOLE NO: CAL-DV 4		19.77509		DISTRICT: CALVINIA		SITE NAME: 0			
ALT BH NO: 0															
ALT BH NO: 0															
BOREHOLE DEPTH (m): 205.00		DATUM LEVEL ABOVE CASING (m): 0.56		EXISTING PUMP: 0		WATER LEVEL (mbdl): 10.25		CASING HEIGHT: (magl): 0.34		CONTRACTOR: AB PUMPS		PUMP TYPE: DW2402			
DEPTH OF PUMP (m): 99.15		DIAMPUMP INLET (mm): 117.00													
STEPPED DISCHARGE TEST & RECOVERY															
DISCHARGE RATE 1				RPM 139	DISCHARGE RATE 2				RPM 347	DISCHARGE RATE 3				RPM 529	
DATE: 19/05/2018		TIME: 07H30		DATE: 19/05/2018		TIME: 09H10		DATE: 19/05/2018		TIME: 10H50					
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	
1	0.90		1		1	9.30		1		1	21.41	2.70	1		
2	1.67	0.96	2		2	9.78	1.58	2		2	23.18	2.83	2		
3	2.27	1.06	3		3	10.90	1.90	3		3	23.86	2.96	3		
5	3.40	1.05	5		5	12.23	1.00	5		5	25.52	2.98	5		
7	3.78	1.06	7		7	13.06	2.00	7		7	27.03	3.07	7		
10	4.48	1.07	10		10	13.76	2.02	10		10	28.74	3.06	10		
15	5.39	1.05	15		15	15.06	2.01	15		15	29.72	3.03	15		
20	5.94	1.06	20		20	15.76	2.03	20		20	30.70	3.05	20		
30	6.65	1.04	30		30	17.36	2.02	30		30	32.23	3.03	30		
40	7.24	1.07	40		40	18.12	2.03	40		40	33.15	3.02	40		
50	7.61	1.05	50		50	18.71	2.05	50		50	33.98	3.03	50		
60	7.93	1.06	60		60	19.17	2.04	60		60	34.58	3.02	60		
70	8.22	1.01	70		70	19.58	2.05	70		70	35.10	3.05	70		
80	8.40	1.04	80		80	20.10	2.05	80		80	35.60	3.05	80		
90	8.58	1.07	90		90	20.48	2.03	90		90	36.30	3.03	90		
100	8.72		100		100	20.87		100		100	36.74		100		
110			110		110			110		110			110		
120			120		120			120		120			120		
pH			150		pH			150		pH			150		
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180		
EC	378.00	µS/cm	210		EC	405.00	µS/cm	210		EC	413.00	µS/cm	210		
DISCHARGE RATE 4				RPM	DISCHARGE RATE 5				RPM	DISCHARGE RATE 6				RPM	
DATE: 19/05/2018		TIME: 12H30		DATE:		TIME:		DATE:		TIME:					
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	
1	37.15		1	87.94	1			1		1			1		
2	37.63		2	76.60	2			2		2			2		
3	38.03		3	62.96	3			3		3			3		
5	38.66	4.70	5	51.61	5			5		5			5		
7	38.98		7	33.17	7			7		7			7		
10	39.47	5.10	10	29.20	10			10		10			10		
15	45.55	5.80	15	22.69	15			15		15			15		
20	65.83	5.82	20	20.29	20			20		20			20		
30	88.05		30	17.46	30			30		30			30		
	88.05	4.75	40	11.93	40			40		40			40		
	88.05	4.30	50	10.73	50			50		50			50		
	88.05	4.18	60	9.53	60			60		60			60		
			70	8.39	70			70		70			70		
			80	7.75	80			80		80			80		
			90	7.29	90			90		90			90		
			100	6.74	100			100		100			100		
			110	6.44	110			110		110			110		
			120	6.20	120			120		120			120		
pH			150		pH			150		pH			150		
TEMP		°C	180	4.85	TEMP		°C	180		TEMP		°C	180		
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		
			240	4.16				240					240		
			300	3.63				300					300		
			360					360					360		
S/WL:(mbch)															

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: 31.41163				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA			
BOREHOLE NO: CAL-DV 4			19.77509				SITE NAME: 0					
ALT BH NO: 0							EXISTING PUMP: 0					
ALT BH NO: 0							CONTRACTOR: AB PUMPS					
BOREHOLE DEPTH: 205.00			DATUM LEVEL ABOVE CASING (m): 0.56				PUMP TYPE: DW2402					
WATER LEVEL (mbdl): 12.11			CASING HEIGHT: (magl): 0.34									
DEPTH OF PUMP (m): 99.15			DIAM PUMP INLET(mm): 117									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	20/05/2018	TIME:	08H00	DATE:	22/05/2018	TIME:	08H00	TYPE OF PUMP:	DW2402			
OBSERVATION HOLE 1						OBSERVATION HOLE 2			OBSERVATION HOLE 3			
NR:						NR:			NR:			
DISCHARGE BOREHOLE						Distance(m);			Distance(m);			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	1.28		1	52.05	1			1			1	
2	2.78	2.70	2	47.91	2			2			2	
3	7.21	2.80	3	43.81	3			3			3	
5	10.66		5	39.39	5			5			5	
7	12.61	2.80	7	36.89	7			7			7	
10	14.29	2.85	10	33.90	10			10			10	
15	17.45	2.84	15	30.70	15			15			15	
20	19.48	2.82	20	28.13	20			20			20	
30	21.17	2.80	30	24.33	30			30			30	
40	24.94	2.80	40	22.61	40			40			40	
60	25.03	2.81	60	19.55	60			60			60	
90	27.07	2.84	90	16.30	90			90			90	
120	28.40	2.82	120	14.61	120			120			120	
150	30.78	2.81	150	13.12	150			150			150	
180	32.17	2.80	180	12.02	180			180			180	
210	33.10	2.85	210	11.10	210			210			210	
240	33.91	2.83	240	10.54	240			240			240	
300	34.97	2.82	300	9.45	300			300			300	
360	35.84	2.82	360	8.73	360			360			360	
420	36.75	2.83	420	8.07	420			420			420	
480	37.85	2.83	480	7.47	480			480			480	
540	38.88	2.83	540	7.02	540			540			540	
600	39.92	2.84	600	6.58	600			600			600	
720	41.68	2.83	720	6.12	720			720			720	
840	43.77	2.80	840	5.67	840			840			840	
960	46.12	2.82	960	5.20	960			960			960	
1080	48.24	2.83	1080	4.74	1080			1080			1080	
1200	50.44	2.84	1200	4.29	1200			1200			1200	
1320	52.02	2.85	1320	3.33	1320			1320			1320	
1440	54.30		1440	3.11	1440			1440			1440	
1560			1560		1560			1560			1560	
1680			1680		1680			1680			1680	
1800			1800		1800			1800			1800	
1920			1920		1920			1920			1920	
2040			2040		2040			2040			2040	
2160			2160		2160			2160			2160	
2280			2280		2280			2280			2280	
2400			2400		2400			2400			2400	
2520			2520		2520			2520			2520	
2640			2640		2640			2640			2640	
2760			2760		2760			2760			2760	
2880			2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				1440	W/L				W/L			
Average yield (l/s):				2.83								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
rpm	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: NORTHERN CAPE
FARM / VILLAGE NAME:
DATE TESTED: 15/05/2018

PROJECT #	P2009
BBR	JOHAN
PRODUCTION BONUS:	ABEL
	ERNEST
	HENRY
	REX
	BRIGHT
EC meter number	#51

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: hddd ° mm ' ss.s " hddd ° mm.mmm ' hddd.ddddd

LATITUDE: ° ' " OR ° ' " OR 31.43108
LONGITUDE: ° ' " OR ° ' " OR 19.78912

BOREHOLE NO: CAL-DV3
TRANSMISSIVITY VALUE:
TYPE INSTALLATION: NEW BOREHOLE
BOREHOLE DEPTH: (mbgl) 205.86

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	NAOMI
Date sample taken	17/05/2018		If consultant took sample, give name:			DATA CHECKED BY:	ALENE
Time sample taken	10H43						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY	DESCRIPTION:	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	205.86
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	41.62
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009		MAP REFERENCE: 31.43108				PROVINCE: NORTHERN CAPE								
BOREHOLE NO: CAL-DV3		19.78912				DISTRICT: CALVINIA								
ALT BH NO: 0						SITE NAME: 0								
ALT BH NO: 0														
BOREHOLE DEPTH (m): 205.86		DATUM LEVEL ABOVE CASING (m): 0.74				EXISTING PUMP: 0								
WATER LEVEL (m bdl): 41.11		CASING HEIGHT: (magl): 0.20				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 147.15		DIAMPUMP INLET (mm): 117.00				PUMP TYPE: DW 2402								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
RPM					RPM					RPM				
DATE: 15/05/2018		TIME: 16H00			DATE: 15/05/2018		TIME: 17H40			DATE: 15/05/2018		TIME: 19H20		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	1.73		1		1	37.59		1		1	102.40		1	101.11
2	2.54		2		2	37.68	1.25	2		2	102.53		2	97.20
3	3.56		3		3	37.90	1.84	3		3	103.12	2.38	3	82.40
5	6.94	0.48	5		5	41.48	1.73	5		5	104.76		5	78.38
7	5.97	0.52	7		7	45.34	1.85	7		7	104.76	1.77	7	72.11
10	9.41	0.83	10		10	49.42	1.96	10		10	104.76	1.61	10	66.24
15	15.21	1.01	15		15	55.84	2.02	15		15	104.76	1.45	15	58.11
20	18.94	1.01	20		20	59.88	2.01	20		20			20	43.70
30	23.46	1.00	30		30	65.24	2.04	30		30			30	37.16
40	27.03	1.03	40		40	69.44	2.05	40		40			40	25.94
50	30.45	1.06	50		50	76.78	2.05	50		50			50	22.01
60	32.50	1.03	60		60	79.33	2.03	60		60			60	18.45
70	34.12	1.00	70		70	80.96	2.02	70		70			70	15.97
80	35.28	1.02	80		80	89.90	2.00	80		80			80	13.27
90	36.48	1.01	90		90	95.64	2.01	90		90			90	11.78
100	37.34		100		100	101.54		100		100			100	10.29
110			110		110			110		110			110	8.98
120			120		120			120		120			120	7.98
pH			150		pH			150		pH			150	5.67
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180	3.96
EC	327.00	µS/cm	210		EC	335.00	µS/cm	210		EC		µS/cm	210	2.93
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
RPM					RPM					RPM				
DATE:		TIME:			DATE:		TIME:			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1			1		1			1		1			1	
2			2		2			2		2			2	
3			3		3			3		3			3	
5			5		5			5		5			5	
7			7		7			7		7			7	
10			10		10			10		10			10	
15			15		15			15		15			15	
20			20		20			20		20			20	
30			30		30			30		30			30	
40			40		40			40		40			40	
50			50		50			50		50			50	
60			60		60			60		60			60	
70			70		70			70		70			70	
80			80		80			80		80			80	
90			90		90			90		90			90	
100			100		100			100		100			100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180	
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210	
			240					240					240	
			300					300					300	
			360					360					360	
S/WL:(mbch)														

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: 31.43108				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA			
BOREHOLE NO: CAL-DV3			19.78912				SITE NAME: 0					
ALT BH NO: 0							EXISTING PUMP: 0		CONTRACTOR: AB PUMPS			
ALT BH NO: 0							PUMP TYPE: DW 2402					
BOREHOLE DEPTH: 205.86			DATUM LEVEL ABOVE CASING (m): 0.74									
WATER LEVEL (mbdl): 41.41			CASING HEIGHT: (magl): 0.20									
DEPTH OF PUMP (m): 147.15			DIAM PUMP INLET(mm): 117									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	16/05/2018	TIME:	11:30	DATE:		TIME:		TYPE OF PUMP:	DW 2402			
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR:		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m);		Distance(m);		Distance(m);		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	2.34		1	45.82	1			1			1	
2	3.98		2	41.48	2			2			2	
3	4.78	0.75	3	36.33	3			3			3	
5	6.39	0.78	5	33.31	5			5			5	
7	8.59	0.78	7	30.57	7			7			7	
10	10.22	0.80	10	28.11	10			10			10	
15	14.30	0.81	15	26.57	15			15			15	
20	16.50	0.82	20	23.66	20			20			20	
30	21.10	0.80	30	19.76	30			30			30	
40	24.29	0.83	40	17.07	40			40			40	
60	26.81	0.81	60	12.11	60			60			60	
90	30.88	0.80	90	9.18	90			90			90	
120	34.71	0.82	120	6.59	120			120			120	
150	36.85	0.80	150	5.10	150			150			150	
180	38.21	0.83	180	4.08	180			180			180	
210	39.02	0.84	210	3.38	210			210			210	
240	41.38	0.82	240	2.85	240			240			240	
300	43.48	0.81	300	2.15	300			300			300	
360	44.53	0.80	360	1.84	360			360			360	
420	44.88	0.80	420		420			420			420	
480	45.18	0.81	480		480			480			480	
540	45.38	0.83	540		540			540			540	
600	45.59	0.82	600		600			600			600	
720	45.78	0.80	720		720			720			720	
840	46.01	0.81	840		840			840			840	
960	46.19	0.83	960		960			960			960	
1080	46.45	0.80	1080		1080			1080			1080	
1200	46.45	0.84	1200		1200			1200			1200	
1320	47.00	0.81	1320		1320			1320			1320	
1440	48.55		1440		1440			1440			1440	
1560			1560		1560			1560			1560	
1680			1680		1680			1680			1680	
1800			1800		1800			1800			1800	
1920			1920		1920			1920			1920	
2040			2040		2040			2040			2040	
2160			2160		2160			2160			2160	
2280			2280		2280			2280			2280	
2400			2400		2400			2400			2400	
2520			2520		2520			2520			2520	
2640			2640		2640			2640			2640	
2760			2760		2760			2760			2760	
2880			2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				1440	W/L		W/L		W/L		W/L	
Average yield (l/s):				0.80								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
rpm	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



Ground water solutions t/a AB Pumps CC

BOREHOLE TEST RECORD

CONSULTANT: GEOS - KES MURRAY
DISTRICT: CALVINIA
PROVINCE: NORTHERN CAPE
FARM / VILLAGE NAME: NATURE RESERVE
DATE TESTED: 06/07/2018

PROJECT #	P2009
BBR	MICHAEL
PRODUCTION BONUS:	ABEL
	ERNEST
	PHINEAS
	SIMON
	HENRY
EC meter number	51

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: hddd ° mm ' ss.s " hddd ° mm.mmm ' hddd.ddddd

LATITUDE: ° ' " OR ° ' " OR **S 31.43522**
LONGITUDE: ° ' " OR ° ' " OR **E 19.78445**

BOREHOLE NO: CAL-NAT 5
TRANSMISSIVITY VALUE:
TYPE INSTALLATION: NEW BOREHOLE
BOREHOLE DEPTH: (mbgl) 199.80

COMMENTS: ROD STRIPPED ON THE 1ST DATA SHEET. BOREHOLE BOOMED AT 860 MIN .CONSTANT RATE WAS 6 HOURS.
 WE RESTARTED AGAIN FOR 5 HOURS FOR 24HOURS

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	EM
Date sample taken	07/07/2018		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	10H25						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	199.70
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	30.68
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	NO
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009		MAP REFERENCE: 0				PROVINCE: NORTHERN CAPE								
BOREHOLE NO: CAL-NAT 5						DISTRICT: CALVINIA								
ALT BH NO: 0						SITE NAME: NATURE RESERVE								
ALT BH NO: 0														
BOREHOLE DEPTH (m): 199.80		DATUM LEVEL ABOVE CASING (m): 0.72				EXISTING PUMP: NEW BOREHOLE								
WATER LEVEL (mbdl): 25.32		CASING HEIGHT: (magl): 0.11				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 154.04		DIAMPUMP INLET (mm): 178.00				PUMP TYPE: DW 4002								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
RPM 154					RPM 210.5					RPM 517				
DATE: 04/07/2018		TIME: 08H30			DATE: 04/07/2018		TIME: 09H30			DATE: 04/07/2018		TIME: 10H30		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	2.96		1		1	16.92		1		1	23.32		1	
2	5.22		2		2	18.84	1.79	2		2	24.30	2.86	2	
3	8.09		3		3	19.77	2.22	3		3	25.23	3.02	3	
5	11.60		5		5	20.94	2.23	5		5	27.62	3.02	5	
7	13.02	1.50	7		7	21.54	2.23	7		7	28.87	3.03	7	
10	14.12	1.51	10		10	22.09	2.22	10		10	29.47	3.02	10	
15	14.64	1.50	15		15	22.31	2.21	15		15	29.68	3.02	15	
20	14.87	1.51	20		20	22.36	2.21	20		20	29.80	3.01	20	
30	14.99	1.51	30		30	22.38	2.23	30		30	29.77	3.03	30	
40	15.09	1.50	40		40	22.41	2.22	40		40	29.77	3.03	40	
50	15.21	1.51	50		50	22.43	2.22	50		50	29.77	3.02	50	
60	15.23	1.50	60		60	22.44	2.20	60		60	30.21		60	
70			70		70			70		70			70	
80			80		80			80		80			80	
90			90		90			90		90			90	
100			100		100			100		100			100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180	
EC	498	µS/cm	210		EC	508	µS/cm	210		EC	452	µS/cm	210	
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
RPM 789					RPM					RPM				
DATE: 04/07/2018		TIME: 11H30			DATE: 04/07/2018		TIME: 12H30			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	32.57		1		1	86.73		1	58.34	1			1	
2	39.20	4.46	2		2	89.33	5.89	2	42.30	2			2	
3	44.68	4.79	3		3	89.41		3	30.61	3			3	
5	58.25	4.91	5		5			5	13.54	5			5	
7	63.70	5.05	7		7			7	6.60	7			7	
10	70.69	5.04	10		10			10	4.29	10			10	
15	75.65	5.03	15		15			15	3.77	15			15	
20	78.27	5.02	20		20			20	1.47	20			20	
30	83.37	5.02	30		30			30	3.27	30			30	
40	84.27	5.00	40		40			40	3.09	40			40	
50	84.48	5.03	50		50			50	3.00	50			50	
60	84.66		60		60			60	2.92	60			60	
70			70		70			70	2.85	70			70	
80			80		80			80	2.81	80			80	
90			90		90			90	2.79	90			90	
100			100		100			100	2.76	100			100	
110			110		110			110	2.74	110			110	
120			120		120			120	2.72	120			120	
pH			150		pH			150	2.69	pH			150	
TEMP		°C	180		TEMP		°C	180	2.66	TEMP		°C	180	
EC	483	µS/cm	210		EC		µS/cm	210	2.56	EC		µS/cm	210	
			240					240	2.53				240	
			300					243	2.49				300	
			360					244					360	
S/WL:(mbch) 24.6														

FORM 5 F														
CONSTANT DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009			MAP REFERENCE: S 31.43522			PROVINCE: NORTHERN CAPE			DISTRICT: CALVINIA			SITE NAME: NATURE RESERVE		
BOREHOLE NO: CAL-NAT 5			E 19.78445			EXISTING PUMP: NEW BOREHOLE			CONTRACTOR: AB PUMPS			PUMP TYPE: DW 4002		
ALT BH NO: 0						DATUM LEVEL ABOVE CASING (m): 0.72			CASING HEIGHT: (magl): 0.11			DIAM PUMP INLET(mm): 178		
ALT BH NO: 0						WATER LEVEL (mbdl): 30.03			DEPTH OF PUMP (m): 154.04					
CONSTANT DISCHARGE TEST & RECOVERY														
TEST STARTED						TEST COMPLETED								
DATE:	05/07/2108		TIME:	08H00		DATE:	06/07/2108		TIME:			TYPE OF PUMP:	DW 4002	
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3				
						NR:		NR:		NR:				
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):				
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)		
1	4.95		1	64.08	1			1			1			
2	13.97		2	49.01	2			2			2			
3	23.29	4.91	3	34.45	3			3			3			
5	40.64	4.95	5	15.33	5			5			5			
7	49.59		7	7.51	7			7			7			
10	57.27	5.03	10	6.02	10			10			10			
15	64.82	5.05	15	5.45	15			15			15			
20	70.63	5.03	20	5.16	20			20			20			
30	72.89	5.02	30	4.86	30			30			30			
40	73.85	5.01	40	4.63	40			40			40			
60	77.03	5.03	60	4.39	60			60			60			
90	77.54	5.02	90	4.05	90			90			90			
120	77.76	5.01	120	3.84	120			120			120			
150	78.03	5.01	150	3.65	150			150			150			
180	78.14	5.00	180	3.48	180			180			180			
210	78.40	5.03	210	3.35	210			210			210			
240	78.84	5.02	240	3.20	240			240			240			
300	79.25	5.02	300	3.02	300			300			300			
360	79.27	5.00	360	2.77	360			360			360			
420	79.46	5.00	420	2.58	420			420			420			
480	80.08	5.03	480	2.43	480			480			480			
540	80.33	5.02	540	2.27	540			540			540			
600	80.52	5.03	600	2.10	600			600			600			
720	80.94	5.05	720	1.81	720			720			720			
840	81.04	5.02	840		840			840			840			
960	81.11	5.03	960		960			960			960			
1080	81.36	5.01	1080		1080			1080			1080			
1200	81.63	5.02	1200		1200			1200			1200			
1320	82.12	5.01	1320		1320			1320			1320			
1440	82.12	5.00	1440		1440			1440			1440			
			1560		1560			1560			1560			
			1680		1680			1680			1680			
			1800		1800			1800			1800			
			1920		1920			1920			1920			
			2040		2040			2040			2040			
			2160		2160			2160			2160			
			2280		2280			2280			2280			
			2400		2400			2400			2400			
			2520		2520			2520			2520			
			2640		2640			2640			2640			
			2760		2760			2760			2760			
			2880		2880			2880			2880			
			3000		3000			3000			3000			
			3120		3120			3120			3120			
			3240		3240			3240			3240			
			3360		3360			3360			3360			
			3480		3480			3480			3480			
			3600		3600			3600			3600			
			3720		3720			3720			3720			
			3840		3840			3840			3840			
			3960		3960			3960			3960			
			4080		4080			4080			4080			
			4200		4200			4200			4200			
			4320		4320			4320			4320			
Total time pumped(min):				860		W/L		W/L		W/L		W/L		
Average yield (l/s):				6.03										

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



Ground water solutions t/a AB Pumps CC

BOREHOLE TEST RECORD

CONSULTANT: GEOS- KES MURRAY
DISTRICT: CALVINIA
PROVINCE: NORTHERN CAPE
FARM / VILLAGE NAME : NATURE RESERVE CALVINIA
DATE TESTED: 08/07/2018

PROJECT #	P2009
BBR	MICHAEL
PRODUCTION BONUS:	ABEL
	ERNEST
	PHINIAS/SIMON
	SIMON
	HENRY
EC meter number	51

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: hddd ° mm ' ss.s " hddd ° mm.mmm ' hddd.ddddd

LATITUDE: ° ' " OR ° ' " OR S 31.45129
 LONGITUDE: ° ' " OR ° ' " OR E 19.77058

BOREHOLE NO: CAL-NAT-6
TRANSMISSIVITY VALUE:
TYPE INSTALLATION: NEW BOREHOLE
BOREHOLE DEPTH: (mbgl) 200M

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	ELZAAN
Date sample taken	10/07/2018		If consultant took sample, give name:			DATA CHECKED BY:	
Time sample taken	06H25						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY	DESCRIPTION:	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	200.00
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	12.57
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	50
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ SIGNATURE: _____
 DESIGNATION: _____ DATE: _____


FORM 5 E																		
STEPPED DISCHARGE TEST & RECOVERY																		
BOREHOLE TEST RECORD SHEET																		
PROJ NO: P2009		MAP REFERENCE: 0				PROVINCE: NORTHERN CAPE				DISTRICT: CALVINIA								
BOREHOLE NO: CAL-NAT-6						SITE NAME: NATURE RESERVE				CALVINIA								
ALT BH NO: 0						EXISTING PUMP: NEW BOREHOLE				CONTRACTOR: AB PUMPS								
ALT BH NO: 0						PUMP TYPE: DW 4002												
BOREHOLE DEPTH (m): 200M		DATUM LEVEL ABOVE CASING (m): 0.69																
WATER LEVEL (mbdl): 11.75		CASING HEIGHT: (magl): 0.13																
DEPTH OF PUMP (m): 100.04		DIAMPUMP INLET (mm): 178.00																
STEPPED DISCHARGE TEST & RECOVERY																		
DISCHARGE RATE 1				RPM 99.1		DISCHARGE RATE 2				RPM 174.9		DISCHARGE RATE 3				RPM 308		
DATE: 08/07/2018		TIME: 15H00				DATE: 07/07/2018		TIME: 16H00				DATE: 08/07/2018		TIME: 17H00				
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	
1	0.70		1		1	1.51	1.69	1		1	3.66	3.02	1					
2	0.72	1.00	2		2	1.81	1.81	2		2	4.72		2					
3	0.74	1.03	3		3	2.01	2.07	3		3	5.22	3.21	3					
5	0.76	1.05	5		5	2.27	2.05	5		5	5.68	3.55	5					
7	0.77	1.04	7		7	2.34	2.04	7		7	5.79	4.02	7					
10	0.80	1.05	10		10	2.37	2.03	10		10	6.63	4.03	10					
15	0.81	1.05	15		15	2.41	2.03	15		15	6.89	4.02	15					
20	0.83	1.04	20		20	2.43	2.02	20		20	6.92	4.00	20					
30	0.85	1.04	30		30	2.47	2.01	30		30	6.96	4.00	30					
40	0.86	1.04	40		40	2.49	2.04	40		40	7.03	4.02	40					
50	0.87	1.03	50		50	2.52	2.03	50		50	7.09	4.01	50					
60	0.88	1.02	60		60	2.53	2.03	60		60	7.20		60					
70			70		70			70		70			70					
80			80		80			80		80			80					
90			90		90			90		90			90					
100			100		100			100		100			100					
110			110		110			110		110			110					
120			120		120			120		120			120					
pH			150		pH			150		pH			150					
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180					
EC	291	µS/cm	210		EC	393	µS/cm	210		EC	397	µS/cm	210					
DISCHARGE RATE 4				RPM 678		DISCHARGE RATE 5				RPM		DISCHARGE RATE 6				RPM		
DATE: 08/07/2018		TIME: 18H00				DATE:		TIME:				DATE:		TIME:				
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	
1	8.85		1	75.48	1			1		1			1					
2	11.98	5.30	2	59.72	2			2		2			2					
3	20.43	6.18	3	43.97	3			3		3			3					
5	43.31	7.53	5	15.36	5			5		5			5					
7	87.53		7	0.71	7			7		7			7					
8	87.53	3.60	10	0.60	10			10		10			10					
9	87.53	3.43	15	0.49	15			15		15			15					
10	87.53	3.40	20	0.45	20			20		20			20					
30			30	0.38	30			30		30			30					
40			40	0.35	40			40		40			40					
50			50	0.33	50			50		50			50					
60			60	0.31	60			60		60			60					
70			70	0.28	70			70		70			70					
80			80	0.27	80			80		80			80					
90			90	0.26	90			90		90			90					
100			100	0.25	100			100		100			100					
110			110	0.24	110			110		110			110					
120			120	0.23	120			120		120			120					
pH			150	0.20	pH			150		pH			150					
TEMP		°C	180	0.19	TEMP		°C	180		TEMP		°C	180					
EC		µS/cm	187	0.19	EC		µS/cm	210		EC		µS/cm	210					
			240					240					240					
			300					300					300					
			360					360					360					
S/WL:(mbch) 11.1																		

FORM 5 F													
CONSTANT DISCHARGE TEST & RECOVERY													
BOREHOLE TEST RECORD SHEET													
PROJ NO: P2009			MAP REFERENCE: S 31.45129				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA				
BOREHOLE NO: CAL-NAT-6			E 19.77058				SITE NAME: NATURE RESERVE		CALVINIA				
ALT BH NO: 0							EXISTING PUMP: NEW BOREHOLE						
ALT BH NO: 0							CONTRACTOR: AB PUMPS						
BOREHOLE DEPTH: 200M			DATUM LEVEL ABOVE CASING (m): 0.69				PUMP TYPE: DW 4002						
WATER LEVEL (mbdl): 11.80			CASING HEIGHT: (magl): 0.13										
DEPTH OF PUMP (m): 100.04			DIAM PUMP INLET(mm): 178										
CONSTANT DISCHARGE TEST & RECOVERY													
TEST STARTED						TEST COMPLETED							
DATE:	09/07/2018		TIME:	08H00		DATE:	01/07/2018		TIME:	11H30		TYPE OF PUMP:	DW 4002
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3			
						NR:		NR:		NR:			
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	
1	2.60		1	79.72	1			1			1		
2	4.46		2	74.32	2			2			2		
3	5.03	2.89	3	53.30	3			3			3		
5	5.20		5	30.18	5			5			5		
7	5.21	3.52	7	4.66	7			7			7		
10	5.26	3.55	10	1.98	10			10			10		
15	5.36	3.52	15	1.85	15			15			15		
20	5.41	3.51	20	1.82	20			20			20		
30	5.47	3.52	30	1.76	30			30			30		
40	5.54	3.52	40	1.73	40			40			40		
60	5.62	3.51	60	1.69	60			60			60		
90	5.71	3.53	90	1.62	90			90			90		
120	5.80	3.52	120	1.59	120			120			120		
150	5.85	3.50	150	1.54	150			150			150		
180	5.87	3.53	180	1.49	180			180			180		
210	5.94	3.52	210		210			210			210		
240	5.98	3.53	240		240			240			240		
300	6.09	3.52	300		300			300			300		
360	6.16	3.53	360		360			360			360		
420	6.28	3.52	420		420			420			420		
480	6.34	3.51	480		480			480			480		
540	6.43	3.53	540		540			540			540		
600	6.44	3.53	600		600			600			600		
720	6.56	3.52	720		720			720			720		
840	6.66	3.51	840		840			840			840		
960	6.77	3.53	960		960			960			960		
1080	6.87	3.52	1080		1080			1080			1080		
1200	6.98	3.51	1200		1200			1200			1200		
1320	7.41	3.53	1320		1320			1320			1320		
1440	8.01	3.52	1440		1440			1440			1440		
1470	87.07	4.32	1560		1560			1560			1560		
1471	87.07	4.11	1680		1680			1680			1680		
1472	87.07	3.80	1800		1800			1800			1800		
1473	87.07	3.51	1920		1920			1920			1920		
2040			2040		2040			2040			2040		
2160			2160		2160			2160			2160		
2280			2280		2280			2280			2280		
2400			2400		2400			2400			2400		
2520			2520		2520			2520			2520		
2640			2640		2640			2640			2640		
2760			2760		2760			2760			2760		
2880			2880		2880			2880			2880		
3000			3000		3000			3000			3000		
3120			3120		3120			3120			3120		
3240			3240		3240			3240			3240		
3360			3360		3360			3360			3360		
3480			3480		3480			3480			3480		
3600			3600		3600			3600			3600		
3720			3720		3720			3720			3720		
3840			3840		3840			3840			3840		
3960			3960		3960			3960			3960		
4080			4080		4080			4080			4080		
4200			4200		4200			4200			4200		
4320			4320		4320			4320			4320		
Total time pumped(min):				1470	W/L		W/L		W/L		W/L		
Average yield (l/s):				3.52									

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS
DISTRICT: CALVINIA
PROVINCE: NORTHERN CAPE
FARM / VILLAGE NAME:
 21/08/2018
DATE TESTED:

PROJECT #	P2009
BBR	MICHAEL
PRODUCTION BONUS:	ABEL
	ERNEST
	PHINEAS
	SIMON
EC meter number	51

MAP REFERENCE:

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **S 31.40048**
LONGITUDE: _____ **OR** _____ **E 19.55587**

BOREHOLE NO: CAL-PHASE 3.4A
TRANSMISSIVITY VALUE:
TYPE INSTALLATION: NEW BOREHOLE
BOREHOLE DEPTH: (mbgl) 77.20

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	ELZAAN
Date sample taken	24/08/2018		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	07H50						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	77.20
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	22.1
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____

FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009		MAP REFERENCE: 0				PROVINCE: NORTHERN CAPE								
BOREHOLE NO: CAL-PHASE 3.4A						DISTRICT: CALVINIA								
ALT BH NO: 0						SITE NAME: 0								
ALT BH NO: 0														
BOREHOLE DEPTH (m): 77.20		DATUM LEVEL ABOVE CASING (m): 0.40				EXISTING PUMP: NEW BOREHOLE								
WATER LEVEL (mbdl): 20.16		CASING HEIGHT: (magl): 0.38				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 70.25		DIAM PUMP INLET (mm): 310.00				PUMP TYPE: GW 9602								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
RPM 531					RPM 1138					RPM 1719				
DATE: 21/08/2018		TIME: 12H20			DATE: 21/08/2018		TIME: 40H00			DATE: 21/08/2018		TIME: 15H40		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	0.09		1		1	0.52		1		1	1.48		1	
2	0.13		2		2	0.56	11.25	2		2	1.52		2	
3	0.17	5.08	3		3	0.63	13.25	3		3	1.64	24.97	3	
5	0.20	5.10	5		5	0.75	15.10	5		5	1.75	20.05	5	
7	0.21	5.07	7		7	0.80	15.07	7		7	1.77	25.07	7	
10	0.22	5.10	10		10	0.84	15.05	10		10	1.84	25.05	10	
15	0.25	5.05	15		15	0.89	15.08	15		15	1.86	25.03	15	
20	0.26	5.09	20		20	0.93	15.10	20		20	1.91	25.00	20	
30	0.29	5.10	30		30	1.01	15.10	30		30	2.06	25.05	30	
40	0.32	5.08	40		40	1.05	15.11	40		40	2.17	25.07	40	
50	0.34	5.08	50		50	1.11	15.09	50		50	2.24	25.03	50	
60	0.37	5.04	60		60	1.17	15.10	60		60	2.34	25.05	60	
70	0.38	5.06	70		70	1.23	15.10	70		70	2.41	25.02	70	
80	0.40	5.08	80		80	1.26	15.08	80		80	2.49	25.04	80	
90	0.41	5.09	90		90	1.30	15.10	90		90	2.56	25.06	90	
100	0.42		100		100	1.35		100		100	2.65		100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180	
EC	1519	µS/cm	210		EC	1569	µS/cm	210		EC	1531	µS/cm	210	
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
RPM 2127					RPM					RPM				
DATE: 21/08/2018		TIME: 17H20			DATE:		TIME:			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	5.00		1	3.12	1			1		1			1	
2	2.75		2	2.76	2			2		2			2	
3	2.78	29.44	3	2.61	3			3		3			3	
5	2.89	29.91	5	2.41	5			5		5			5	
7	2.90	30.15	7	2.27	7			7		7			7	
10	2.92	30.11	10	2.21	10			10		10			10	
15	2.98	30.15	15	2.10	15			15		15			15	
20	3.02	30.12	20	2.01	20			20		20			20	
30	3.11	30.10	30	1.86	30			30		30			30	
40	3.19	30.16	40	1.74	40			40		40			40	
50	3.27	30.11	50	1.62	50			50		50			50	
60	3.34	30.12	60	1.57	60			60		60			60	
70	3.41	30.10	70	1.51	70			70		70			70	
80	3.47	30.13	80	1.45	80			80		80			80	
90	3.53	30.11	90	1.36	90			90		90			90	
100	3.59		100	1.25	100			100		100			100	
110			110	1.19	110			110		110			110	
120			120	1.14	120			120		120			120	
pH			150	1.10	pH			150		pH			150	
TEMP		°C	180	1.07	TEMP		°C	180		TEMP		°C	180	
EC	1505	µS/cm	210	1.05	EC		µS/cm	210		EC		µS/cm	210	
			240	1.02				240					240	
			300	0.98				300					300	
			360	0.94										
			400	0.89				360					360	

S/WL:(mbch) 19.76

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: S 31.40048				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA			
BOREHOLE NO: CAL-PHASE 3.4A			E 19.55587				SITE NAME: 0					
ALT BH NO: 0							EXISTING PUMP: NEW BOREHOLE					
ALT BH NO: 0							CONTRACTOR: AB PUMPS					
BOREHOLE DEPTH: 77.20			DATUM LEVEL ABOVE CASING (m): 0.40				PUMP TYPE: GW 9602					
WATER LEVEL (mbdl): 20.40			CASING HEIGHT: (magl): 0.38									
DEPTH OF PUMP (m): 70.25			DIAM PUMP INLET(mm): 310									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	22/08/2018	TIME:	08H00	DATE:	25/08/2018	TIME:	08H00	TYPE OF PUMP:	GW 9602			
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR:		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m);			Distance(m);			Distance(m);
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	0.21		1	6.68	1			1			1	
2	0.34	13.56	2	6.40	2			2			2	
3	0.44	17.74	3	6.27	3			3			3	
5	0.58	21.30	5	6.16	5			5			5	
7	0.81	25.61	7	6.09	7			7			7	
10	1.18	28.09	10	6.02	10			10			10	
15	1.31	28.11	15	5.89	15			15			15	
20	1.42	28.17	20	5.81	20			20			20	
30	1.59	28.13	30	5.65	30			30			30	
40	1.77	28.10	40	5.53	40			40			40	
60	2.00	28.12	60	5.28	60			60			60	
90	2.31	28.11	90	5.03	90			90			90	
120	2.53	28.00	120	4.79	120			120			120	
150	2.75	28.09	150	4.57	150			150			150	
180	2.94	28.07	180	4.37	180			180			180	
210	3.22	28.05	210	4.20	210			210			210	
240	3.38	28.09	240	4.09	240			240			240	
300	3.66	28.10	300	3.74	300			300			300	
360	3.90	28.12	360	3.50	360			360			360	
420	4.10	28.10	420	3.28	420			420			420	
480	4.30	28.08	480	3.09	480			480			480	
540	4.66	28.11	540	2.95	540			540			540	
600	4.68	28.07	600	2.77	600			600			600	
720	4.87	28.17	720	2.57	720			720			720	
840	5.12	28.11	840	2.37	840			840			840	
960	5.34	28.14	960	2.27	960			960			960	
1080	5.50	28.11	1080	2.19	1080			1080			1080	
1200	5.66	28.11	1200	2.14	1200			1200			1200	
1320	5.80	28.09	1320	2.09	1320			1320			1320	
1440	5.95	28.10	1440	2.04	1440			1440			1440	
1560	6.08	28.06	1560		1560			1560			1560	
1680	6.18	28.11	1680		1680			1680			1680	
1800	6.27	28.13	1800		1800			1800			1800	
1920	6.37	28.09	1920		1920			1920			1920	
2040	6.45	28.05	2040		2040			2040			2040	
2160	6.57	28.09	2160		2160			2160			2160	
2280	6.68	28.12	2280		2280			2280			2280	
2400	6.74	28.09	2400		2400			2400			2400	
2520	6.85	28.11	2520		2520			2520			2520	
2640	6.91	28.13	2640		2640			2640			2640	
2760	6.99	28.10	2760		2760			2760			2760	
2880	7.08		2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880	W/L			W/L			W/L	
Average yield (l/s):				28.11								

FORM 5 E			
STEPPED DISCHARGE TEST & RECOVERY			
BOREHOLE TEST RECORD SHEET			
PROJ NO:	P2009	MAP REFERENCE:	0
BOREHOLE NO:	CAL -PHASE 3-6	PROVINCE:	NORTHERN CAPE
ALT BH NO:	0	DISTRICT:	CALVINIA
ALT BH NO:	0	SITE NAME:	0

FORM 5 F													
CONSTANT DISCHARGE TEST & RECOVERY													
BOREHOLE TEST RECORD SHEET													
PROJ NO: P2009			MAP REFERENCE: S 31.35771				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA				
BOREHOLE NO: CAL -PHASE 3-6			E 19.69145				SITE NAME: 0						
ALT BH NO: 0							EXISTING PUMP: NEW BOREHOLE						
ALT BH NO: 0							CONTRACTOR: AB PUMPS						
BOREHOLE DEPTH: 111.42			DATUM LEVEL ABOVE CASING (m): 0.54				PUMP TYPE: WA 110-2						
WATER LEVEL (mbdl): 39.17			CASING HEIGHT: (magl): 0.21										
DEPTH OF PUMP (m): 96.85			DIAM PUMP INLET(mm): 226										
CONSTANT DISCHARGE TEST & RECOVERY													
TEST STARTED						TEST COMPLETED							
DATE: 27/08/2018		TIME: 13H30		DATE: 30/08/2018		TIME: 01H30		TYPE OF PUMP: WA 110-2					
OBSERVATION HOLE 1						OBSERVATION HOLE 2			OBSERVATION HOLE 3				
NR:						NR:			NR:				
DISCHARGE BOREHOLE				Distance(m):			Distance(m):			Distance(m):			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	
1	0.15		1	43.07	1			1			1		
2	0.27		2	42.95	2			2			2		
3	0.40	11.65	3	42.86	3			3			3		
5	0.70	11.96	5	42.70	5			5			5		
7	1.68		7	42.55	7			7			7		
10	2.26	12.15	10	42.36	10			10			10		
15	3.36	12.07	15	42.10	15			15			15		
20	4.28	12.09	20	41.99	20			20			20		
30	6.21	12.10	30	41.63	30			30			30		
40	8.36	12.07	40	41.38	40			40			40		
60	11.34	12.11	60	41.04	60			60			60		
90	14.94	12.09	90	40.72	90			90			90		
120	17.74	12.15	120	40.56	120			120			120		
150	19.90	12.13	150	40.44	150			150			150		
180	21.67	12.03	180	40.32	180			180			180		
210	23.19	12.05	210	40.22	210			210			210		
240	24.79	12.09	240	40.15	240			240			240		
300	26.68	12.06	300	40.03	300			300			300		
360	28.34	12.04	360	39.91	360			360			360		
420	29.77	12.02	420	39.79	420			420			420		
480	30.84	12.06	480	39.66	480			480			480		
540	31.77	12.10	540	39.55	540			540			540		
600	32.57	12.07	600	39.42	600			600			600		
720	33.87	12.04	720	39.17	720			720			720		
840	35.15	12.36	840	38.93	840			840			840		
960	36.33	12.10	960	38.67	960			960			960		
1080	37.35	12.13	1080	38.44	1080			1080			1080		
1200	38.43	12.11	1200	38.22	1200			1200			1200		
1320	39.25	12.09	1320	38.09	1320			1320			1320		
1440	39.97	12.12	1440	37.85	1440			1440			1440		
1560	40.60	12.10	1560		1560			1560			1560		
1680	41.16	12.07	1680		1680			1680			1680		
1800	41.67	12.07	1800		1800			1800			1800		
1920	42.16	12.06	1920		1920			1920			1920		
2040	42.68	12.09	2040		2040			2040			2040		
2160	43.21		2160		2160			2160			2160		
2280			2280		2280			2280			2280		
2400			2400		2400			2400			2400		
2520			2520		2520			2520			2520		
2640			2640		2640			2640			2640		
2760			2760		2760			2760			2760		
2880			2880		2880			2880			2880		
3000			3000		3000			3000			3000		
3120			3120		3120			3120			3120		
3240			3240		3240			3240			3240		
3360			3360		3360			3360			3360		
3480			3480		3480			3480			3480		
3600			3600		3600			3600			3600		
3720			3720		3720			3720			3720		
3840			3840		3840			3840			3840		
3960			3960		3960			3960			3960		
4080			4080		4080			4080			4080		
4200			4200		4200			4200			4200		
4320			4320		4320			4320			4320		
Total time pumped(min):				2160	W/L			W/L			W/L		
Average yield (l/s):				12.07									


FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009		MAP REFERENCE: 0				PROVINCE: NORTHERN CAPE				DISTRICT: CALVINIA				
BOREHOLE NO: CAL-PHASE 3.9						SITE NAME: KREITZBERG								
ALT BH NO: 0														
ALT BH NO: 0														
BOREHOLE DEPTH (m): 62.15		DATUM LEVEL ABOVE CASING (m): 0.42				EXISTING PUMP: NEW BOREHOLE								
WATER LEVEL (mbdl): 19.19		CASING HEIGHT: (magl): 0.36				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 58.00		DIAMPUMP INLET (mm): 170.00				PUMP TYPE: BP 50								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
RPM 557					RPM 960					RPM 1223				
DATE: 14/08/2018		TIME: 07H30			DATE: 14/08/2018		TIME: 08H30			DATE: 14/08/2018		TIME: 09H30		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	0.10		1		1	0.42		1		1	0.99	10.46	1	
2	0.10		2		2	0.44	8.24	2		2	1.00		2	
3	0.11		3		3	0.47		3		3	1.03	11.27	3	
5	0.11	3.79	5		5	0.50	8.21	5		5	1.07		5	
7	0.12	4.21	7		7	0.55		7		7	1.10	11.28	7	
10	0.12		10		10	0.62	8.23	10		10	1.15		10	
15	0.13	4.20	15		15	0.65		15		15	1.21		15	
20	0.18		20		20	0.68		20		20	1.27	11.26	20	
30	0.24	4.21	30		30	0.77	8.25	30		30	1.36		30	
40	0.26		40		40	0.85		40		40	1.43		40	
50	0.32	4.22	50		50	0.90	8.23	50		50	1.49	11.28	50	
60	0.36		60		60	0.95		60		60	1.55		60	
70			70		70			70		70			70	
80			80		80			80		80			80	
90			90		90			90		90			90	
100			100		100			100		100			100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP	14.30	°C	180		TEMP	15.60	°C	180		TEMP	20.90	°C	180	
EC	502	µS/cm	210		EC	522	µS/cm	210		EC	534	µS/cm	210	
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
RPM 1405					RPM					RPM				
DATE: 14/08/2018		TIME: 10H30			DATE:		TIME:			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	1.65		1	1.96	1			1		1			1	
2	1.66	13.87	2	1.88	2			2		2			2	
3	1.67		3	1.81	3			3		3			3	
5	1.68	14.05	5	1.72	5			5		5			5	
7	1.73		7	1.60	7			7		7			7	
10	1.76	14.01	10	1.53	10			10		10			10	
15	1.80		15	1.42	15			15		15			15	
20	1.84	14.03	20	1.37	20			20		20			20	
30	1.95		30	1.26	30			30		30			30	
40	2.03		40	1.17	40			40		40			40	
50	2.11	14.04	50	1.09	50			50		50			50	
60	2.17		60	1.05	60			60		60			60	
70			70	1.00	70			70		70			70	
80			80	0.97	80			80		80			80	
90			90	0.94	90			90		90			90	
100			100	0.90	100			100		100			100	
110			110	0.88	110			110		110			110	
120			120	0.87	120			120		120			120	
pH			150	0.82	pH			150		pH			150	
TEMP	20.10	°C	180	0.79	TEMP		°C	180		TEMP		°C	180	
EC	518	µS/cm	210	0.76	EC		µS/cm	210		EC		µS/cm	210	
			240					240					240	
			300					300					300	
			360					360					360	
S/WL:(mbch) 18.77														

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: S 31.63272			PROVINCE: NORTHERN CAPE			DISTRICT: CALVINIA			
BOREHOLE NO: CAL-PHASE 3.9			E 19.75683			SITE NAME: KREITZBERG						
ALT BH NO: 0												
ALT BH NO: 0												
BOREHOLE DEPTH: 62.15			DATUM LEVEL ABOVE CASING (m): 0.42			EXISTING PUMP: NEW BOREHOLE						
WATER LEVEL (mbdl):			CASING HEIGHT: (magl): 0.36			CONTRACTOR: AB PUMPS						
DEPTH OF PUMP (m): 58.00			DIAM PUMP INLET(mm): 170			PUMP TYPE: BP 50						
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:		TIME:		DATE:		TIME:		TYPE OF PUMP:		BP 50		
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR:		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m):		Distance(m):		Distance(m):		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	0.21		1	6.68	1			1			1	
2	0.34		2	6.40	2			2			2	
3	0.44		3	6.27	3			3			3	
5	0.58		5	6.16	5			5			5	
7	0.81		7	6.09	7			7			7	
10	1.18		10	6.02	10			10			10	
15	1.31		15	5.89	15			15			15	
20	1.42		20	5.81	20			20			20	
30	1.59		30	5.65	30			30			30	
40	1.77		40	5.53	40			40			40	
60	2.00		60	5.28	60			60			60	
90	2.31		90	5.03	90			90			90	
120	2.53		120	4.79	120			120			120	
150	2.75		150	4.57	150			150			150	
180	2.94		180	4.37	180			180			180	
210	3.22		210	4.20	210			210			210	
240	3.38		240	4.09	240			240			240	
300	3.66		300	3.74	300			300			300	
360	3.90		360	3.50	360			360			360	
420	4.10		420	3.28	420			420			420	
480	4.30		480	3.09	480			480			480	
540	4.66		540	2.95	540			540			540	
600	4.68		600	2.77	600			600			600	
720	4.87		720	2.57	720			720			720	
840	5.12		840	2.37	840			840			840	
960	5.34		960	2.27	960			960			960	
1080	5.50		1080	2.19	1080			1080			1080	
1200	5.66		1200	2.14	1200			1200			1200	
1320	5.80		1320	2.09	1320			1320			1320	
1440	5.95		1440	2.04	1440			1440			1440	
1560	6.08		1560		1560			1560			1560	
1680	6.18		1680		1680			1680			1680	
1800	6.27		1800		1800			1800			1800	
1920	6.37		1920		1920			1920			1920	
2040	6.45		2040		2040			2040			2040	
2160	6.57		2160		2160			2160			2160	
2280	6.68		2280		2280			2280			2280	
2400	6.74		2400		2400			2400			2400	
2520	6.85		2520		2520			2520			2520	
2640	6.91		2640		2640			2640			2640	
2760	6.99		2760		2760			2760			2760	
2880	7.08		2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):						W/L		W/L		W/L		
Average yield (l/s):												

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOSS _____
DISTRICT: HANTAM _____
PROVINCE: NORTHERN CAPE _____
FARM / VILLAGE NAME : KRUITBURG CALVINIA _____
DATE TESTED: 25/05/2018 _____

PROJECT #	P2009
BBR	JOHAN
PRODUCTION BONUS:	ABEL
	ERNEST
	SIMON
	BRIGHT
	HENRY
EC meter number	#51

MAP REFERENCE: _____

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm ' hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.65036**
LONGITUDE: _____ **OR** _____ **OR** **19.80109**

BOREHOLE NO: CAL-S2-4 _____
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: NEW BOREHOLE _____
BOREHOLE DEPTH: (mbgl) 185.96 _____

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	NAOMI
Date sample taken	27/05/2018		If consultant took sample, give name:			DATA CHECKED BY:	ALENE
Time sample taken	07H45						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	185.96
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	16.46
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	1	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E																	
STEPPED DISCHARGE TEST & RECOVERY																	
BOREHOLE TEST RECORD SHEET																	
PROJ NO: P2009		MAP REFERENCE: 31.65036		PROVINCE: NORTHERN CAPE		BOREHOLE NO: CAL-S2-4		19.80109		DISTRICT: HANTAM		SITE NAME: KRUITBURG CALVINIA					
ALT BH NO: 0				EXISTING PUMP: 0		CONTRACTOR: AB PUMPS				PUMP TYPE: DW 4002							
BOREHOLE DEPTH (m): 185.96		DATUM LEVEL ABOVE CASING (m): 0.65		WATER LEVEL (mbdl): 6.29		CASING HEIGHT: (magl): 0.18		DEPTH OF PUMP (m): 154.09		DIAMPUMP INLET (mm): 117.00							
STEPPED DISCHARGE TEST & RECOVERY																	
DISCHARGE RATE 1				RPM		DISCHARGE RATE 2				RPM		DISCHARGE RATE 3				RPM	
DATE: 25/05/2018		TIME: 13H40		DATE: 25/05/2018		TIME: 15H20		DATE: 25/05/2018		TIME: 17H00							
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)			
1	1.16		1		1	7.22	2.32	1		1	13.12		1				
2	1.54		2		2	7.39	2.58	2		2	13.37		2				
3	1.68		3		3	7.78	2.81	3		3	15.32	4.21	3				
5	1.88	1.31	5		5	8.39	3.07	5		5	16.21	4.41	5				
7	1.94	1.50	7		7	8.88	3.06	7		7	16.61	4.53	7				
10	2.10	2.03	10		10	9.21	3.07	10		10	16.96	4.52	10				
15	3.16	2.03	15		15	9.83	3.07	15		15	17.46	4.50	15				
20	3.66	2.02	20		20	10.20	3.05	20		20	17.77	4.50	20				
30	4.39	2.02	30		30	10.77	3.05	30		30	18.37	4.50	30				
40	4.97	2.01	40		40	11.17	3.05	40		40	18.80	4.50	40				
50	5.26	2.02	50		50	11.37	3.04	50		50	19.15	4.54	50				
60	5.64	2.01	60		60	11.64	3.04	60		60	20.25	4.53	60				
70	5.95	2.00	70		70	12.01	3.04	70		70	20.73	4.33	70				
80	6.22	2.00	80		80	12.33	3.06	80		80	21.17	4.52	80				
90	6.61	2.01	90		90	12.73	3.05	90		90	21.62	4.52	90				
100	6.89		100		100	13.02		100		100	22.01		100				
110			110		110			110		110			110				
120			120		120			120		120			120				
pH			150		pH			150		pH			150				
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180				
EC	486.00	µS/cm	210		EC	480.00	µS/cm	210		EC	524.00	µS/cm	210				
DISCHARGE RATE 4				RPM		DISCHARGE RATE 5				RPM		DISCHARGE RATE 6				RPM	
DATE: 25/05/2018		TIME: 18H40		DATE:		TIME:		DATE:		TIME:							
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)			
1	22.52	6.58	1	70.22	1			1		1			1				
2	20.23		2	40.11	2			2		2			2				
3	28.86		3	28.98	3			3		3			3				
5	33.37	6.61	5	25.12	5			5		5			5				
7	37.50	6.60	7	22.91	7			7		7			7				
10	43.11	6.62	10	21.54	10			10		10			10				
15	49.11	6.61	15	19.82	15			15		15			15				
20	53.21	6.68	20	18.92	20			20		20			20				
30	59.24	6.86	30	17.29	30			30		30			30				
40	62.22	6.84	40	16.16	40			40		40			40				
50	64.25	6.85	50	14.22	50			50		50			50				
60	67.76	6.83	60	13.16	60			60		60			60				
70	68.66	6.84	70	13.15	70			70		70			70				
80	70.71	6.84	80	12.57	80			80		80			80				
90	71.48	6.80	90	11.80	90			90		90			90				
100	72.55		100	11.20	100			100		100			100				
110			110	10.40	110			110		110			110				
120			120	10.02	120			120		120			120				
pH			150	9.12	pH			150		pH			150				
TEMP		°C	180	8.15	TEMP		°C	180		TEMP		°C	180				
EC		µS/cm	210	7.50	EC		µS/cm	210		EC		µS/cm	210				
			240	6.82				240					240				
			300	6.01				300					300				
			360	5.36													
			400	4.20				360					360				
S/WL:(mbch) 6.08																	

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: 31.65036				PROVINCE: NORTHERN CAPE		DISTRICT: HANTAM			
BOREHOLE NO: CAL-S2-4			19.80109				SITE NAME: KRUITBURG CALVINIA					
ALT BH NO: 0							EXISTING PUMP: 0					
ALT BH NO: 0							CONTRACTOR: AB PUMPS					
BOREHOLE DEPTH: 185.96			DATUM LEVEL ABOVE CASING (m): 0.65				PUMP TYPE: DW 4002					
WATER LEVEL (mbdl): 9.18			CASING HEIGHT: (magl): 0.18									
DEPTH OF PUMP (m): 154.09			DIAM PUMP INLET(mm): 117									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	26/05/2018	TIME:	08H00	DATE:		TIME:		TYPE OF PUMP:	DW 4002			
OBSERVATION HOLE 1						OBSERVATION HOLE 2			OBSERVATION HOLE 3			
NR: CAL S2-3						NR:			NR:			
DISCHARGE BOREHOLE						Distance(m): 900			Distance(m):			Distance(m):
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	1.55		1	27.78	1			1			1	
2	3.32		2	26.35	2			2			2	
3	4.21	2.20	3	25.35	3			3			3	
5	5.39	4.02	5	24.50	5	0.03	15.50	5			5	
7	5.72		7	23.84	7			7			7	
10	7.28	4.04	10	23.00	10	0.08	15.42	10			10	
15	8.56	4.09	15	22.47	15	0.18	15.21	15			15	
20	9.37	4.09	20	21.01	20	0.31	15.00	20			20	
30	11.72	4.07	30	20.81	30	0.60	14.78	30			30	
40	12.52	4.05	40	20.01	40	0.88	14.61	40			40	
60	13.87	4.05	60	18.72	60	1.39	14.33	60			60	
90	15.32	4.05	90	17.18	90	2.11	13.87	90			90	
120	16.79	4.04	120	16.12	120	2.73	13.35	120			120	
150	17.85	4.04	150	15.17	150	3.33	12.83	150			150	
180	18.87	4.08	180	14.13	180	3.87	12.38	180			180	
210	19.32	4.08	210	13.54	210	4.43	11.92	210			210	
240	20.24	4.06	240	12.70	240	4.84	11.55	240			240	
300	21.89	4.06	300	11.58	300	5.85	10.76	300			300	
360	23.75	4.08	360	10.80	360	6.59	9.83	360			360	
420	24.81	4.05	420	9.25	420	7.32	9.47	420			420	
480	25.81	4.09	480	9.21	480	7.97	9.05	480			480	
540	26.63	4.09	540	8.57	540	8.48	8.49	540			540	
600	28.17	4.09	600	7.80	600	9.18	7.93	600			600	
720	29.60	4.07	720		720	10.33		720			720	
840	30.59	4.03	840		840	11.05		840			840	
960	31.77	4.03	960		960	11.59		960			960	
1080	32.47	4.04	1080		1080	12.20		1080			1080	
1200	33.58	4.02	1200		1200	13.65		1200			1200	
1320	34.11		1320		1320	14.53		1320			1320	
1440	34.86		1440		1440	15.55		1440			1440	
1560			1560		1560			1560			1560	
1680			1680		1680			1680			1680	
1800			1800		1800			1800			1800	
1920			1920		1920			1920			1920	
2040			2040		2040			2040			2040	
2160			2160		2160			2160			2160	
2280			2280		2280			2280			2280	
2400			2400		2400			2400			2400	
2520			2520		2520			2520			2520	
2640			2640		2640			2640			2640	
2760			2760		2760			2760			2760	
2880			2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				1440		W/L	14.93		W/L			W/L
Average yield (l/s):				4.03								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



Ground water solutions t/a AB Pumps CC

BOREHOLE TEST RECORD

CONSULTANT: GEOS _____
DISTRICT: CALVINIA _____
PROVINCE: NORTHERN CAPE _____
FARM / VILLAGE NAME : CALVINIA _____
DATE TESTED: 28/06/2018 _____

PROJECT #	P2009
BBR	MICHAEL
PRODUCTION BONUS:	ABEL
	ERNST/PHINEAS
	SIMON
	HENRY
EC meter number	#31

MAP REFERENCE: _____

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.61755**
LONGITUDE: _____ **OR** _____ **OR** **19.74473**

BOREHOLE NO: CAL-S2-10 _____
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: NEW BOREHOLE _____
BOREHOLE DEPTH: (mbgl) 151.16 _____

COMMENTS:

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	NAOMI
Date sample taken	01/07/2018		If consultant took sample, give name:			DATA CHECKED BY:	ALENE
Time sample taken	09H10						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY	DESCRIPTION:	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	151.15
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	20.55
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E																	
STEPPED DISCHARGE TEST & RECOVERY																	
BOREHOLE TEST RECORD SHEET																	
PROJ NO: P2009		MAP REFERENCE: 31.61755		PROVINCE: NORTHERN CAPE		BOREHOLE NO: CAL-S2-10		19.74473		DISTRICT: CALVINIA		ALT BH NO: 0		SITE NAME: CALVINIA			
BOREHOLE DEPTH (m): 151.16		DATUM LEVEL ABOVE CASING (m): 0.54		EXISTING PUMP: 0		WATER LEVEL (mbdl): 19.44		CASING HEIGHT: (magl): 0.22		CONTRACTOR: AB PUMPS		DEPTH OF PUMP (m): 100.15		DIAMPUMP INLET (mm): 178.00		PUMP TYPE: WA-110-2	
STEPPED DISCHARGE TEST & RECOVERY																	
DISCHARGE RATE 1				RPM 98.8	DISCHARGE RATE 2				RPM 190	DISCHARGE RATE 3				RPM 459			
DATE: 28/06/2018		TIME: 12H00		DATE: 28/06/2018		TIME: 13H00		DATE: 28/06/2018		TIME: 14H00							
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)			
1	0.18		1		1	0.48		1		1	0.94		1				
2	0.20		2		2	0.57	4.14	2		2	0.96		2				
3	0.21	2.33	3		3	0.66	4.69	3		3	0.98	5.78	3				
5	0.23	2.30	5		5	0.73	4.95	5		5	1.03	6.81	5				
7	0.24	2.31	7		7	0.77	5.04	7		7	1.05	7.99	7				
10	0.25	2.37	10		10	0.79	5.07	10		10	2.03	8.51	10	19.50			
15	0.25	2.36	15		15	0.81	5.10	15		15	2.98	12.31	15				
20	0.25	2.35	20		20	0.85	5.10	20		20	3.42	12.22	20				
30	0.27	2.36	30		30	0.87	5.07	30		30	3.73	12.28	30				
40	0.27	2.36	40		40	0.88	5.05	40		40	3.73	12.25	40				
50	0.28	2.35	50		50	0.90	5.07	50		50	3.82	12.24	50				
60	0.29	2.35	60		60	0.91	5.07	60		60	3.93		60				
70			70		70			70		70			70				
80			80		80			80		80			80				
90			90		90			90		90			90				
100			100		100			100		100			100				
110			110		110			110		110			110				
120			120		120			120		120			120				
pH			150		pH			150		pH			150				
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180				
EC	810.00	µS/cm	210		EC	778.00	µS/cm	210		EC	812.00	µS/cm	210				
DISCHARGE RATE 4				RPM 706.8	DISCHARGE RATE 5				RPM	DISCHARGE RATE 6				RPM			
DATE: 28/06/2018		TIME: 15H00		DATE:		TIME:		DATE:		TIME:							
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)			
1	3.95		1	2.72	1			1		1			1				
2	3.99	13.81	2	1.55	2			2		2			2				
3	4.42	14.56	3	1.24	3			3		3			3				
5	4.67	15.72	5	1.05	5			5		5			5				
7	6.41	17.54	7	0.93	7			7		7			7				
10	7.66	18.50	10	0.82	10			10		10			10				
15	9.11	18.96	15	0.76	15			15		15			15				
20	9.51	19.20	20	0.68	20			20		20			20				
30	9.94	19.06	30	0.60	30			30		30			30				
40	10.08	19.04	40	0.55	40			40		40			40				
50	10.56	19.07	50	0.51	50			50		50			50				
60	10.64	19.11	60	0.49	60			60		60			60				
70	10.83	19.12	70	0.44	70			70		70			70				
80	10.94	19.10	80	0.41	80			80		80			80				
90	11.03	19.04	90	0.39	90			90		90			90				
100	11.09	19.03	100	0.37	100			100		100			100				
110	11.17	19.00	110	0.36	110			110		110			110				
120	11.28	19.02	120	0.35	120			120		120			120				
pH			150	0.31	pH			150		pH			150				
TEMP		°C	180	0.29	TEMP		°C	180		TEMP		°C	180				
EC		µS/cm	210	0.27	EC		µS/cm	210		EC		µS/cm	210				
			240	0.25				240					240				
			300	0.21				300					300				
			360					360					360				
S/WL:(mbch) 18.96																	

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: 31.61755				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA			
BOREHOLE NO: CAL-S2-10			19.74473				SITE NAME: CALVINIA					
ALT BH NO: 0							EXISTING PUMP: 0					
ALT BH NO: 0							CONTRACTOR: AB PUMPS					
BOREHOLE DEPTH: 151.16			DATUM LEVEL ABOVE CASING (m): 0.54				PUMP TYPE: WA-110-2					
WATER LEVEL (mbdl): 19.59			CASING HEIGHT: (magl): 0.22									
DEPTH OF PUMP (m): 100.15			DIAM PUMP INLET(mm): 178									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	29/06/2018	TIME:	09H20	DATE:		TIME:		TYPE OF PUMP:	WA-110-2			
OBSERVATION HOLE 1						OBSERVATION HOLE 2			OBSERVATION HOLE 3			
NR:						NR:			NR:			
DISCHARGE BOREHOLE						Distance(m);			Distance(m);			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	4.72		1	4.79	1			1			1	
2	5.40	16.47	2	4.35	2			2			2	
3	6.61	19.78	3	4.24	3			3			3	
5	8.59	20.05	5	4.09	5			5			5	
7	9.26	20.00	7	3.98	7			7			7	
10	9.87	20.10	10	3.88	10			10			10	
15	10.37	20.15	15	3.76	15			15			15	
20	10.64	20.24	20	3.68	20			20			20	
30	11.08	20.15	30	3.55	30			30			30	
40	11.36	20.10	40	3.43	40			40			40	
60	11.66	20.08	60	3.30	60			60			60	
90	11.98	20.20	90	3.13	90			90			90	
120	12.32	20.13	120	3.04	120			120			120	
150	12.61	20.12	150	2.90	150			150			150	
180	12.83	20.10	180	2.79	180			180			180	
210	12.96	20.09	210	2.70	210			210			210	
240	13.12	20.15	240	2.64	240			240			240	
300	13.43	20.13	300	2.52	300			300			300	
360	13.66	20.15	360	2.43	360			360			360	
420	13.90	20.13	420	2.35	420			420			420	
480	14.11	20.10	480	2.31	480			480			480	
540	14.21	20.15	540	2.26	540			540			540	
600	14.50	20.11	600	2.18	600			600			600	
720	14.89	20.13	720	2.11	720			720			720	
840	15.17	20.16	840	2.06	840			840			840	
960	15.46	20.10	960	2.02	960			960			960	
1080	15.73	20.01	1080	1.98	1080			1080			1080	
1200	15.94	20.05	1200	1.93	1200			1200			1200	
1320	16.23	20.01	1320	1.88	1320			1320			1320	
1440	16.57	20.05	1440	1.85	1440			1440			1440	
1560	16.71	20.07	1560	1.82	1560			1560			1560	
1680	16.96	20.09	1680	1.80	1680			1680			1680	
1800	17.07	20.10	1800	1.75	1800			1800			1800	
1920	17.69	20.08	1920	1.71	1920			1920			1920	
2040	17.88	20.05	2040	1.67	2040			2040			2040	
2160	18.12	20.04	2160	1.65	2160			2160			2160	
2280	18.35	20.02	2280	1.61	2280			2280			2280	
2400	18.41	20.15	2400	1.58	2400			2400			2400	
2520	18.54	20.12	2520	1.55	2520			2520			2520	
2640	18.73	20.10	2640	1.53	2640			2640			2640	
2760	18.94	20.09	2760	1.51	2760			2760			2760	
2880	18.95	20.07	2880	1.48	2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880	W/L				W/L			
Average yield (l/s):				20.09	W/L				W/L			

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOSS _____
DISTRICT: CALVINIA _____
PROVINCE: NORTHERN CAPE _____
FARM / VILLAGE NAME : SPITZKOP _____
DATE TESTED: 16/08/2018 _____

PROJECT #	P2009
BBR	MICHAEL
PRODUCTION BONUS:	ABEL
	PHINEAS
	ERNEST
	SIMON
EC meter number	51

MAP REFERENCE: _____

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm '** **hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **S 31.37297**
LONGITUDE: _____ **OR** _____ **E 19.97083**

BOREHOLE NO: REDRILL - 39602 _____
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: NEW BOREHOLE _____
BOREHOLE DEPTH: (mbgl) 151.00 _____

COMMENTS: _____

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	ELZAAN
Date sample taken	19/082018		If consultant took sample, give name:			DATA CHECKED BY:	AVN
Time sample taken	15H55						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	151.00
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	8.53
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	100
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____


FORM 5 E														
STEPPED DISCHARGE TEST & RECOVERY														
BOREHOLE TEST RECORD SHEET														
PROJ NO: P2009		MAP REFERENCE: 0				PROVINCE: NORTHERN CAPE				DISTRICT: CALVINIA				
BOREHOLE NO: REDRILL - 39602						SITE NAME: SPITZKOP								
ALT BH NO: 0														
ALT BH NO: 0														
BOREHOLE DEPTH (m): 151.00		DATUM LEVEL ABOVE CASING (m): 0.40				EXISTING PUMP: NEW BOREHOLE								
WATER LEVEL (mbdl): 8.15		CASING HEIGHT: (magl): 0.34				CONTRACTOR: AB PUMPS								
DEPTH OF PUMP (m): 79.25		DIAM PUMP INLET (mm): 310.00				PUMP TYPE: GW 9602								
STEPPED DISCHARGE TEST & RECOVERY														
DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
RPM 224.5					RPM 653					RPM				
DATE: 16/08/2018		TIME: 13H30			DATE: 16/08/2018		TIME: 15H10			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1	1.57		1		1	12.13		1	24.61	1			1	
2	1.65		2		2	13.51	7.50	2	20.59	2			2	
3	1.93	3.72	3		3	14.79	8.10	3	15.24	3			3	
5	2.28	4.50	5		5	16.66	10.24	5	10.88	5			5	
7	2.56		7		7	23.53	11.43	7	8.90	7			7	
10	3.75	4.90	10		10	33.27	13.17	10	7.73	10			10	
15	5.50	5.01	15		15	48.31	14.50	15	6.71	15			15	
20	6.34	5.00	20		20	69.91	15.10	20	4.96	20			20	
30	7.46	5.08	30			69.91	13.11	30	3.98	30			30	
40	8.52	5.09	40			69.91	12.00	40	3.06	40			40	
50	9.16	5.06	50			69.91	11.64	50	2.63	50			50	
60	9.67	5.06	60					60	2.11	60			60	
70	10.06	5.09	70					70	1.87	70			70	
80	10.58	5.08	80					80	1.23	80			80	
90	10.91	5.07	90					90	0.77	90			90	
100	11.08	5.09	100					100	0.51	100			100	
110			110					110	0.37	110			110	
120			120					120	0.26	120			120	
pH			150		pH			150	0.19	pH			150	
TEMP		°C	180		TEMP		°C	180	0.18	TEMP		°C	180	
EC	1181	µS/cm	210		EC		µS/cm	210		EC		µS/cm	210	
DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
RPM					RPM					RPM				
DATE:		TIME:			DATE:		TIME:			DATE:		TIME:		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)
1			1		1			1		1			1	
2			2		2			2		2			2	
3			3		3			3		3			3	
5			5		5			5		5			5	
7			7		7			7		7			7	
10			10		10			10		10			10	
15			15		15			15		15			15	
20			20		20			20		20			20	
30			30		30			30		30			30	
40			40		40			40		40			40	
50			50		50			50		50			50	
60			60		60			60		60			60	
70			70		70			70		70			70	
80			80		80			80		80			80	
90			90		90			90		90			90	
100			100		100			100		100			100	
110			110		110			110		110			110	
120			120		120			120		120			120	
pH			150		pH			150		pH			150	
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180	
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210	
			240					240					240	
			300					300					300	
			360					360					360	
S/WL:(mbch) 7.75														

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: S 31.37297				PROVINCE: NORTHERN CAPE		DISTRICT: CALVINIA			
BOREHOLE NO: REDRILL - 39602			E 19.97083				SITE NAME: SPITZKOP					
ALT BH NO: 0							EXISTING PUMP: NEW BOREHOLE					
ALT BH NO: 0							CONTRACTOR: AB PUMPS					
BOREHOLE DEPTH: 151.00			DATUM LEVEL ABOVE CASING (m): 0.40				PUMP TYPE: GW 9602					
WATER LEVEL (mbdl): 8.79			CASING HEIGHT: (magl): 0.34									
DEPTH OF PUMP (m): 79.25			DIAM PUMP INLET(mm): 310									
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE:	17/08/2018	TIME:	16H00	DATE:		TIME:		TYPE OF PUMP:	GW 9602			
						OBSERVATION HOLE 1		OBSERVATION HOLE 2		OBSERVATION HOLE 3		
						NR:		NR:		NR:		
DISCHARGE BOREHOLE						Distance(m);		Distance(m);		Distance(m);		
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	2.74		1	17.24	1			1			1	
2	5.22	5.35	2	15.67	2			2			2	
3	5.85	6.51	3	15.24	3			3			3	
5	9.03	7.08	5	13.72	5			5			5	
7	10.42	7.07	7	13.29	7			7			7	
10	11.01	7.09	10	12.50	10			10			10	
15	12.71	7.08	15	11.08	15			15			15	
20	14.21	7.09	20	9.73	20			20			20	
30	15.68	7.06	30	7.79	30			30			30	
40	17.40	7.07	40	5.98	40			40			40	
60	18.90	7.10	60	4.22	60			60			60	
90	20.55	7.10	90	2.52	90			90			90	
120	21.47	7.08	120	1.70	120			120			120	
150	21.98	7.09	150	1.27	150			150			150	
180	22.36	7.10	180		180			180			180	
210	23.10	7.07	210		210			210			210	
240	23.39	7.04	240		240			240			240	
300	23.75	7.04	300		300			300			300	
360	23.89	7.01	360		360			360			360	
420	24.06	7.03	420		420			420			420	
480	24.98	7.06	480		480			480			480	
540	25.38	7.01	540		540			540			540	
600	25.72	7.09	600		600			600			600	
720	26.18	7.04	720		720			720			720	
840	26.83	7.06	840		840			840			840	
960	27.04	7.10	960		960			960			960	
1080	27.04	7.08	1080		1080			1080			1080	
1200	27.04	7.10	1200		1200			1200			1200	
1320	27.22	7.06	1320		1320			1320			1320	
1440	27.34	7.09	1440		1440			1440			1440	
1560	27.49	7.10	1560		1560			1560			1560	
1680	27.61	7.08	1680		1680			1680			1680	
1800	27.68	7.09	1800		1800			1800			1800	
1920	27.75	7.07	1920		1920			1920			1920	
2040	27.81	7.08	2040		2040			2040			2040	
2160	27.89	7.05	2160		2160			2160			2160	
2280	27.97	7.09	2280		2280			2280			2280	
2400	28.02	7.10	2400		2400			2400			2400	
2520	28.16	7.08	2520		2520			2520			2520	
2640	28.19	7.10	2640		2640			2640			2640	
2760	28.21	7.07	2760		2760			2760			2760	
2880	28.22		2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				2880	W/L		W/L		W/L			
Average yield (l/s):				7.10								

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Telephone: 043-732 1211
 Fax no: 043-732 1422
 Fax to e-mail: 0866 717 732
 E mail: office@abpumps.co.za

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
RPW	Rates per minute
S/W/L	Static water level
µS/cm	Microsiemens per centimeter



BOREHOLE TEST RECORD

Ground water solutions t/a AB Pumps CC

CONSULTANT: GEOS _____
DISTRICT: _____
PROVINCE: NORTHERN CAPE _____
FARM / VILLAGE NAME : KRUITBERG CALVINIA _____
DATE TESTED: 22/05/2018 _____

PROJECT #	P2009
BBR	JOHAN
PRODUCTION BONUS:	ABEL
	ERNEST
	PHINEAS
	SIMON
	HENRY
EC meter number	

MAP REFERENCE: _____

CO-ORDINATES:

FORMAT ON GPS: **hddd ° mm ' ss.s "** **hddd ° mm.mmm ' hddd.ddddd**

LATITUDE: _____ **OR** _____ **OR** **31.65122**
LONGITUDE: _____ **OR** _____ **OR** **19.80162**

BOREHOLE NO: CAL-S2-3 _____
TRANSMISSIVITY VALUE: _____
TYPE INSTALLATION: NEW BOREHOLE _____
BOREHOLE DEPTH: (mbgl) 121M _____

COMMENTS: _____

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	Test for:	macro	bacterio-logical	DATA CAPTURED BY:	NAOMI
Date sample taken	24/05/2018		If consultant took sample, give name:			DATA CHECKED BY:	ALENE
Time sample taken	08H48						

CONSULTANT GUIDELINES

BOREHOLE DEPTH:	m	STEP 1:	l/s	WATER STRIKE 1:	m
BLOW YIELD:	m	STEP 2:	l/s	WATER STRIKE 2:	m
STATIC WATER LEVEL:	m	STEP 3:	l/s	WATER STRIKE 3:	m
PUMP INSTALLATION DEPTH:	m	STEP 4:	l/s	COMMENTS:	
RECOVERY:		STEP 5:	l/s		
AFTER STEPS:	h	STEP 6:	l/s	TELEPHONE NUMBERS PHONE : (NAME & TEL)	
AFTER CONSTANT:	h	STEP DURATION:	min		

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	120.98
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	14.81
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	30
LOGGERS FOR WATERLEVEL MONITORING	NO	1	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ **SIGNATURE:** _____
DESIGNATION: _____ **DATE:** _____

FORM 5 E																		
STEPPED DISCHARGE TEST & RECOVERY																		
BOREHOLE TEST RECORD SHEET																		
PROJ NO: P2009		MAP REFERENCE: 31.65122				PROVINCE: NORTHERN CAPE												
BOREHOLE NO: CAL-S2-3		19.80162				DISTRICT: 0												
ALT BH NO: ABEL						SITE NAME: KRUITBERG CALVINIA												
ALT BH NO: 0																		
BOREHOLE DEPTH (m): 121M		DATUM LEVEL ABOVE CASING (m): 0.75				EXISTING PUMP: 0												
WATER LEVEL (mbdl): 6.92		CASING HEIGHT: (magl): 0.10				CONTRACTOR: AB PUMPS												
DEPTH OF PUMP (m): 39.15		DIAMPUMP INLET (mm): 117.00				PUMP TYPE: GW2402												
STEPPED DISCHARGE TEST & RECOVERY																		
DISCHARGE RATE 1				RPM		DISCHARGE RATE 2				RPM		DISCHARGE RATE 3				RPM		
DATE: 22/05/2018		TIME: 15H00				DATE: 22/05/2018		TIME: 16H40				DATE: 23/05/2018		TIME: 18H20				
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	
1	0.58		1		1	3.83	1.30	1		1	8.12	2.40	1					
2	0.80	0.72	2		2	3.97	1.60	2		2	8.63	2.71	2					
3	0.93	0.86	3		3	4.34	1.74	3		3	8.98	2.82	3					
5	1.09	0.92	5		5	4.92	1.94	5		5	9.64	3.08	5					
7	1.28	1.01	7		7	5.25	1.98	7		7	10.24	3.05	7					
10	1.63	1.01	10		10	5.74	2.02	10		10	10.64	3.07	10					
15	1.94	1.00	15		15	6.06	2.04	15		15	11.13	3.06	15					
20	2.16	1.01	20		20	6.35	2.02	20		20	11.42	3.05	20					
30	2.46	1.02	30		30	6.68	2.01	30		30	12.01	3.08	30					
40	2.70	1.03	40		40	6.93	2.02	40		40	12.40	3.05	40					
50	2.89	1.02	50		50	7.17	2.01	50		50	12.82	3.05	50					
60	3.05	1.02	60		60	7.42	2.00	60		60	13.03	3.04	60					
70	3.19	1.00	70		70	7.48	2.01	70		70	13.31	3.03	70					
80	3.33	1.02	80		80	7.68	2.01	80		80	13.64	3.04	80					
90	3.48	1.01	90		90	7.91	2.01	90		90	13.84	3.05	90					
100	3.54		100		100	8.04		100		100	14.03		100					
110			110		110			110		110			110					
120			120		120			120		120			120					
pH			150		pH			150		pH			150					
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180					
EC	469.00	µS/cm	210		EC	498.00	µS/cm	210		EC	491.00	µS/cm	210					
DISCHARGE RATE 4				RPM		DISCHARGE RATE 5				RPM		DISCHARGE RATE 6				RPM		
DATE: 22/05/2018		TIME: 20H00				DATE:		TIME:				DATE:		TIME:				
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	
1	14.88	3.85	1	30.79	1			1		1			1					
2	16.44	4.22	2	22.70	2			2		2			2					
3	17.66		3	15.68	3			3		3			3					
5	20.08	4.50	5	12.10	5			5		5			5					
7	22.20		7	10.72	7			7		7			7					
10	25.37	4.70	10	9.48	10			10		10			10					
15	30.65	4.76	15	8.63	15			15		15			15					
20	31.48		20	7.98	20			20		20			20					
		4.51	30	7.06	30			30		30			30					
		4.44	40	6.36	40			40		40			40					
		4.42	50	5.93	50			50		50			50					
			60	5.55	60			60		60			60					
			70	5.39	70			70		70			70					
			80	5.12	80			80		80			80					
			90	4.90	90			90		90			90					
			100	4.91	100			100		100			100					
			110	4.52	110			110		110			110					
			120	4.13	120			120		120			120					
pH			150	3.73	pH			150		pH			150					
TEMP		°C	180	3.35	TEMP		°C	180		TEMP		°C	180					
EC		µS/cm	210	3.07	EC		µS/cm	210		EC		µS/cm	210					
			240	2.69				240					240					
			300	2.48				300					300					
			360	2.27				360					360					

S/WL:(mbch) 6.14

FORM 5 F												
CONSTANT DISCHARGE TEST & RECOVERY												
BOREHOLE TEST RECORD SHEET												
PROJ NO: P2009			MAP REFERENCE: 31.65122			PROVINCE: NORTHERN CAPE			DISTRICT: 0			
BOREHOLE NO: CAL-S2-3			19.80162			SITE NAME: KRUITBERG CALVINIA						
ALT BH NO: ABEL												
ALT BH NO: 0												
BOREHOLE DEPTH: 121M			DATUM LEVEL ABOVE CASING (m): 0.75			EXISTING PUMP: 0						
WATER LEVEL (mbdl): 8.92			CASING HEIGHT: (magl): 0.10			CONTRACTOR: AB PUMPS						
DEPTH OF PUMP (m): 39.15			DIAM PUMP INLET(mm): 117			PUMP TYPE: GW2402						
CONSTANT DISCHARGE TEST & RECOVERY												
TEST STARTED						TEST COMPLETED						
DATE: 23/05/2018		TIME: 08H50		DATE: 25/05/2018		TIME: 08H42		TYPE OF PUMP:		GW2402		
OBSERVATION HOLE 1						OBSERVATION HOLE 2			OBSERVATION HOLE 3			
NR: CAL S2-4						NR:			NR:			
DISCHARGE BOREHOLE						Distance(m): 900			Distance(m):			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)	Recovery (m)	TIME (min)	Drawdown (m)
1	1.39	2.08	1	20.66	1			1			1	
2	2.09	2.49	2	19.02	2			2			2	
3	2.96	2.43	3	17.97	3			3			3	
5	4.85	2.82	5	16.70	5	0.06		5			5	
7	5.61	2.86	7	16.32	7		13.08	7			7	
10	6.61	2.88	10	15.34	10	0.01	13.04	10			10	
15	7.41	2.85	15	14.94	15	0.24	12.96	15			15	
20	8.70	2.81	20	14.67	20	0.39	12.85	20			20	
30	8.88	2.82	30	13.64	30	0.68	12.69	30			30	
40	9.57	2.80	40	13.22	40	0.98	12.48	40			40	
60	10.57	2.82	60	12.68	60	1.54	12.10	60			60	
90	11.46	2.80	90	12.02	90	2.30	11.63	90			90	
120	12.27	2.80	120	11.53	120	2.99	11.25	120			120	
150	12.88	2.81	150	11.17	150	3.63	10.84	150			150	
180	13.39	2.83	180	10.76	180	4.20	10.52	180			180	
210	13.90	2.81	210	10.39	210	4.68	10.19	210			210	
240	14.26	2.80	240	10.17	240	5.15	9.97	240			240	
300	15.01	2.81	300	9.70	300	6.01	9.47	300			300	
360	15.70	2.80	360	9.27	360	6.72	9.04	360			360	
420	16.32	2.82	420	8.94	420	7.36	8.68	420			420	
480	16.88	2.82	480	8.58	480	7.94	8.35	480			480	
540	17.39	2.81	540	8.28	540	8.44	8.05	540			540	
600	17.83	2.80	600	7.98	600	8.92	7.76	600			600	
720	18.96	2.82	720	7.42	720	9.73	7.24	720			720	
840	19.78	2.82	840	7.28	840	10.43	6.36	840			840	
960	20.68	2.81	960	7.05	960	11.04	6.14	960			960	
1080	21.06	2.81	1080	6.87	1080	11.62	5.86	1080			1080	
1200	21.98	2.80	1200	6.32	1200	12.10	5.41	1200			1200	
1320	22.87	2.81	1320	5.14	1320	12.57	5.08	1320			1320	
1440	23.97	2.82	1440	4.87	1440	13.14	4.82	1440			1440	
1560			1560		1560			1560			1560	
1680			1680		1680			1680			1680	
1800			1800		1800			1800			1800	
1920			1920		1920			1920			1920	
2040			2040		2040			2040			2040	
2160			2160		2160			2160			2160	
2280			2280		2280			2280			2280	
2400			2400		2400			2400			2400	
2520			2520		2520			2520			2520	
2640			2640		2640			2640			2640	
2760			2760		2760			2760			2760	
2880			2880		2880			2880			2880	
3000			3000		3000			3000			3000	
3120			3120		3120			3120			3120	
3240			3240		3240			3240			3240	
3360			3360		3360			3360			3360	
3480			3480		3480			3480			3480	
3600			3600		3600			3600			3600	
3720			3720		3720			3720			3720	
3840			3840		3840			3840			3840	
3960			3960		3960			3960			3960	
4080			4080		4080			4080			4080	
4200			4200		4200			4200			4200	
4320			4320		4320			4320			4320	
Total time pumped(min):				1440		W/L	1.7		W/L			W/L
Average yield (l/s):				2.18								

18. APPENDIX E: – BOREHOLE LOGS – H & A DRILLING

Log of Borehole No.:		Cal_DV4		
Location:	Calvinia	Latitude:	-31.411618	
Date:	30/4/2018	Longitude:	19.775263	
Client:	BVI Engineering	Ground Elevation:	1117 m	
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike	
Clay (0 - 9)	0		6.5" Steel casing	
Dolerite (9 - 13)	13		Water level (35m)	
	20		6.5" Open Hole	
	40		Water strike (49m)	
	60			
Shale (13 - 207)	60			
	80		Water strike (82m)	
	80		Water strike (85m)	
	100			
	120			
	140			
	160			
	180			
	200			
	207			
Drilled By:	H&A Drilling		Remarks:	Blow Yield - 3 L/s
Drill Method:	Air percussion			
Logged By:	Charles Peek			



Log of Borehole No.:		Cal_DV1	
Location:	Calvinia	Latitude:	-31.455414
Date:	30/4/2018	Longitude:	19.773937
Client:	BVI Engineering	Ground Elevation:	1009 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Clay (0 - 5)	0		8" Steel casing (0 - 6)
Dolerite (5 - 10)	10		
	20		
	30		
	40		
	50		
Shale (10 - 140)	60		
	70		
	80		
	90		
	100		
	110		
	120		
	130		
	140		Water strike (144 m)
	150		Water strike (155 m)
Baked shale Shale (10 - 140)	160		
Drilled By:	H&A Drilling	Remarks:	Blow Yield - 25 L/s
Drill Method:	Air percussion		
Logged By:	Charles Peek		





Log of Borehole No.:		Cal_DV3	164
GEOSS Report No. 2018/10-18			23 October 2018
Location:	Calvinia	Latitude:	-31.430694
Date:	30/4/2018	Longitude:	19.7883





Log of Borehole No.:		Cal_S1_KB		
Location:	Calvinia	Latitude:	-31.636869	
Date:	30/4/2018	Longitude:	19.758089	
Client:	BVI Engineering	Ground Elevation:	1081 m	
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike	
Clay (0 - 2)	0		6.5" Steel casing (0 - 6)	
Shale (2 - 62)	20		Water level (35m)	
	40		6.5" Open Hole (6 - 180)	
	60		Water strike (48m)	
Dolerite (62 - 110)	80			
	100			
	120			
	140			
Shale (110 - 180)	160			
	180			
Drilled By:	H&A Drilling		Remarks:	Blow Yield - 1.25 L/s
Drill Method:	Air percussion			
Logged By:	Charles Peek			



Log of Borehole No.:		Cal_S2_3B	
Location:	Calvinia	Latitude:	-31.650182
Date:	30/5/2018	Longitude:	19.802443
Client:	BVI Engineering	Ground Elevation:	1160 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Clay (0 - 2)	0		6.5" Steel casing (0 - 4)
	10		6.5" Open Hole (4 - 122)
Shale (2 - 52)	20		Water strike (33m)
	30		
	40		
	50		
	60		
	70		
Dolerite (52 - 102)	80		
	90		
	100		
Shale (102 - 122)	110		
	120		
Drilled By:	H&A Drilling	Remarks:	Blow Yield - 0.2 L/s
Drill Method:	Air percussion		
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_Nat5	
Location:	Calvinia	Latitude:	-31.435236
Date:	30/5/2018	Longitude:	19.784485
Client:	BVI Engineering	Ground Elevation:	1036m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 70)			6.5" Steel casing (0-6) 6.5" Open Hole (6-170)
Dolerite (70 - 168)			Water strike (168m)
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield - 5 L/s	
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_S1-2	
Location:	Calvinia	Latitude:	-31.61826
Date:	30/4/2018	Longitude:	19.893412
Client:	BVI Engineering	Ground Elevation:	1136 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Clay/sand (0 - 10)			6.5" Steel casing (0 - 6)
Shale (10 - 152)			6.5" Open Hole (6 - 152)
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield - 0.1 L/s	
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_S1-3	
Location:	Calvinia	Latitude:	-31.618808
Date:	30/4/2018	Longitude:	19.893628
Client:	BVI Engineering	Ground Elevation:	1136 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Clay/sand (0 - 15)			6.5" Steel casing (0 - 6)
Shale (15 - 120)			6.5" Open Hole (6 - 120)
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield - 0.1 L/s	
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_S2_3	
Location:	Calvinia	Latitude:	-31.651334
Date:	30/5/2018	Longitude:	19.801571
Client:	BVI Engineering	Ground Elevation:	1161 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
	0		
	10		
Shale (0 - 42)	20		6.5" Steel casing (0 - 4)
	30		6.5" Open Hole (4 - 122)
	40		Water strike (23m)
	50		Water strike (27m)
Dolerite (42 - 56)	60		Water strike (31m)
	70		
Shale (56 - 92)	80		
	90		
Dolerite (92 - 102)	100		
	110		
Shale (102 - 122)	120		
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion		Blow Yield - 2.78 L/s
Logged By:	Charles Peek		






Log of Borehole No.:		Cal_S2_4			
Location:	Calvinia	Latitude:	-31.650359		
Date:	30/4/2018	Longitude:	19.801047		
Client:	BVI Engineering	Ground Elevation:	1154 m		
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike		
Shale (0 - 187)			6.5" Steel casing (0 - 4.5)		
	6.5" Open Hole (4.5 - 187)				
	Water strike (146m)				
	Water strike (155m)				
	Water strike (168m)				
	Drilled By:		H&A Drilling	Remarks:	Blow Yield - 3.8 L/s
	Drill Method:		Air percussion		
	Logged By:		Charles Peek		














Log of Borehole No.:		Cal_Phase3_5	
Location:	Calvinia	Latitude:	-31.396265
Date:	28/09/2018	Longitude:	19.55079
Client:	BVI Engineering	Ground Elevation:	901 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 17)			6.5" Steel casing (0 - 6)
Baked Shale (17 - 111)			6.5" Open Hole (6 - 127)
Shale (111- 127)			
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield - 0.1 L/s	
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_Phase3_12	
Location:	Calvinia	Latitude:	-31.626433
Date:	28/09/2018	Longitude:	19.776246
Client:	BVI Engineering	Ground Elevation:	1089 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Sand (0 - 5)	0		6.5" Steel casing (0 - 6)
Baked Dolerite (5 - 7)			water strike 32 m
	20		6.5" Open Hole (6 - 182)
	40		water strike 52 m
	60		
	80		
Baked Shale (7- 182)	80		water strike 115 m
	100		
	120		
	140		
	160		
	180		
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield - 2 L/s	
Logged By:	Charles Peek		





Log of Borehole No.:		Cal_Phase3_9	
Location:	Calvinia	Latitude:	-31.632714
Date:	30/5/2018	Longitude:	19.756781
Client:	BVI Engineering	Ground Elevation:	1136 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 31)	0 10 20 30	<p>8" Steel casing (0-6)</p> <p>8" Open Hole (6-100)</p> <p>Water strike (27-30m)</p> <p>Water strike (52m)</p> <p>Water strike (59m)</p> <p>Water strike (88m)</p>	8" Steel casing (0-6)
	40 50		Water strike (52m)
	60 70		Water strike (59m)
	80 90		Water strike (88m)
Dolerite (31 - 100)	100		
	110		6.5" Open Hole (100-117)
Shale (100 - 117)			
Drilled By:	H&A Drilling	Remarks:	Blow Yield - 25 L/s
Drill Method:	Air percussion		
Logged By:	Charles Peek		

Log of Borehole No.:		ReDrill39602	
Location:	Calvinia	Latitude:	-31.372864
Date:	30/5/2018	Longitude:	19.970834
Client:	BVI Engineering	Ground Elevation:	1092 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 31)			8" Steel casing (0 - 54)
Dolerite (31 - 70)			Water strike (47 - 50 m)
Shale (70 - 150)			8" Open Hole (54 - 100)
			6.5" Open Hole (100 - 150)
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield -> 25 L/s	
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_vlok2	
Location:	Calvinia	Latitude:	-31.401289
Date:	30/5/2018	Longitude:	20.007778
Client:	BVI Engineering	Ground Elevation:	1092 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 60)			6.5" Steel casing (0 - 6) 6.5" Open Hole (6 - 152) Water strike (39 m) Water strike (59 m)
Dolerite (60 - 87)			
Shale (87 - 152)			
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion	Blow Yield -0.1 L/s	
Logged By:	Charles Peek		

Log of Borehole No.:		Cal_Phase3_4A	
Location:	Calvinia	Latitude:	-31.435236
Date:	30/5/2018	Longitude:	19.556679
Client:	BVI Engineering	Ground Elevation:	902 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 30)			8" Steel casing (0 - 6) 8" Open Hole (6 - 79)
			Water strike (22m)
			Water strike (43m)
Dolerite (30 - 79)			Water strike (79m)
			Water strike (79m)
			Water strike (79m)
			Water strike (79m)
			Water strike (79m)
Drilled By:	H&A Drilling	Remarks:	Blow Yield - >30 L/s
Drill Method:	Air percussion		
Logged By:	Charles Peek		
			

Log of Borehole No.:		Cal_Phase3_7	
Location:	Calvinia	Latitude:	-31.435236
Date:	30/5/2018	Longitude:	19.667129
Client:	BVI Engineering	Ground Elevation:	956 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 45)			6.5" Steel casing (0 - 6) 6.5" Open Hole (6 - 137)
Dolerite (45 - 133)			Water strike (70m)
Shale (133 - 137)			
Drilled By:	H&A Drilling	Remarks:	
Drill Method:	Air percussion		
Logged By:	Charles Peek	Blow Yield - 0.1 L/s	

Log of Borehole No.:		Cal_Phase3_6	
Location:	Calvinia	Latitude:	-31.357725
Date:	30/5/2018	Longitude:	19.6915
Client:	BVI Engineering	Ground Elevation:	906 m
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Shale (0 - 25)			6.5" Steel casing (0 - 6) 6.5" Open Hole (6 - 112)
Dolerite (25 - 112)			Water strike (92m)
Drilled By:	H&A Drilling	Remarks:	 
Drill Method:	Air percussion		
Logged By:	Charles Peek		

(last page)